



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **18-48 Eisenhower and Riverdahl Asbestos Abatement**

DATE: **April 20, 2018**

RE: **ADDENDUM NO. 2**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 2nd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing



DATE: April 20, 2018

TO:

Guy Carynski – Rockford Public Schools	guy.carynski@rps205.com
Dane Youngblood – Rockford Public Schools	dane.youngblood@rps205.com
Tim Holian – Holian	tim@holianins.com
Guido Gorniak – Abel Plus	paul@abelplusservices.com
Stephen Harlfinger	sharlfinger@colfaxcorp.net
Jim Cholke – Luse	jcholke@luse.com
Tomasz Stogowski	tomasz.husar1@gmail.com
Evan Christian	echristian@calttd.com
Rod Harvey	rharvey@calttd.com

SUBJECT: ADDENDUM NO. 2 TO THE BIDDING DOCUMENTS
PROJECT MANUAL Rockford Public Schools District #205 – Eisenhower
and Riverdahl Schools – Summer 2018 dated March 21, 2018

This addendum forms a part to the bidding and contract documents and modifies the original bidding documents, dated March 21, 2018. **ALL CONTRACTORS SHALL ACKNOWLEDGE WRITTEN RECEIPT OF THIS ADDENDUM ON THEIR BID FORM. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.** This addendum consists of two (2) pages.

Request for Information Responses in Red

1. Appendix B Environmental Scope Sheets states that the 1st and 2nd floor corridors can be done using non- friable methods the drawings state gross removal methods throughout. Can we bid the corridors using non-friable methods at Eisenhower?
The Abatement Contractor may elect to use non-friable removal methods for flooring as stated in Bid Documents. However, if tiles become broken, cracked, or damaged, the Abatement Contractor must switch to gross removal methods. If should be noted that the Abatement Contractor is responsible to meeting the schedule provided in the Bid Documents.
2. Lab tops fume hoods are not building materials. IDPH allows removal of non-building materials as intact or non-friable methods. Will we be able to bid the lab tops and fume hoods as intact removal? Yes

Except as modified herein, Addendum No. 2, Project Manual dated March 21, 2018 remain in full force and effect.

Sincerely,

CARNOW, CONIBEAR & ASSOC., LTD.

A handwritten signature in blue ink, appearing to read "R. Harvey", is positioned above a solid black horizontal line.

Rod Harvey, PE, CIH, CSP
Director, Client Services