



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 20-28 Interior Renovations at Flinn & Kennedy Middle Schools

DATE: March 19, 2020

RE: **ADDENDUM NO. 2**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 2nd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing

ADDENDUM TWO

RPS205 Project No.: **20-28**

RLJA Project No.: **19-089-2**

Date: **MARCH 19, 2020**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **KENNEDY & FLINN MIDDLE SCHOOL PAINTING & FLOORING WORK
ROCKFORD, ILLINOIS 61103**

Bids Due: **2:00PM (CST), THURSDAY, MARCH 26, 2020**

From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Richard L. Johnson, Principal

This Addendum consists of:

- a. Pages 1 thru 2

CHANGES to the PROJECT MANUAL

1. CLARIFICATIONS

- 1.1 Access panels on walls being painted shall be painted to match wall color.
- 1.2 Any drywall walls with damage must be repaired, patched and made ready for painting.
- 1.3 Auditorium seating will remain in place at Flinn Middle School Auditorium.

CHANGES to the DRAWINGS

2. SHEET A110 OF KENNEDY MIDDLE SCHOOL

- 2.1. Corridor in Boiler Room and Storage Room area shall not be painted.

BIDDING QUESTIONS AND ANSWER LOG

All questions have been addressed in items noted above or in Pre-Bid Meeting Notes.

END ADDENDUM NUMBER 2