



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521


Sample ID#: 249509
Sample Type: Drinking Water
Sampler: PD
PWS ID: CT0570212

Sample Date: 7/9/2020 9:30 AM
Receipt Date: 7/9/2020 3:10 PM
Report Date: 7/16/2020
Sample Site: ENTRY POINT

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Metals						
Antimony	ND	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Arsenic	ND	mg/L	EPA 200.5	0.002	7/13/2020	TJB
Barium	0.009	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Beryllium	ND	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Cadmium	ND	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Chromium(T)	ND	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Cyanide	ND	mg/L	EPA 335.4	0.05	7/13/2020	KH
Mercury	ND	mg/L	EPA 245.2	0.0002	7/15/2020	KH
Nickel	ND	mg/L	EPA 200.5	0.001	7/13/2020	TJB
Selenium	ND	mg/L	EPA 200.5	0.002	7/13/2020	TJB
Silver	ND	mg/L	EPA 200.5	0.002	7/13/2020	TJB
Thallium	ND	mg/L	EPA 200.8	0.001	7/10/2020	TJB
Minerals						
Chloride	220.4	mg/L	EPA 300.0	1	7/15/2020	KH
Fluoride	ND	mg/L	EPA 300.0	0.1	7/13/2020	TJB
Sodium	38.0	mg/L	EPA 200.5	1	7/13/2020	TJB
Sulfate	20.0	mg/L	EPA 300.0	2	7/13/2020	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.