

## Indoor Air Quality Test Summary

**BUILDING:** J.C Solmonese Elementary School

**Room Tested:** 127

Date:	08/28/20
Time:	1:15 PM
Number Of Occupants:	2
Total Area Of Room:	8000 Cu. ft
CFM From Unit:	978 CFM
CFM Into Exhaust:	215 CFM
Total Air Exchanges Per Hour:	7.33
Outside Air Temperature:	73 °F
Outside Air Relative Humidity:	71 %RH
Outside Air Co2:	81 PPM
Unit Discharge Temperature:	75 °F
Space Temperature:	74 °F
Space Relative Humidity:	53 %RH
Thermostat Set Point:	68 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	359 PPM

Comments:

J.C. Solmonese Elementary School report for sampling of testing.