

Indoor Air Quality Test Summary

BUILDING: J.C Solmonese Elementary School

Room Tested: 143

Date:	08/28/20
Time:	1:57 PM
Number Of Occupants:	2
Total Area Of Room:	7000 Cu. ft
CFM From Unit:	1057 CFM
CFM Into Exhaust:	175 CFM
Total Air Exchanges Per Hour:	9.06
Outside Air Temperature:	73 °F
Outside Air Relative Humidity:	72 %RH
Outside Air Co2:	81 PPM
Unit Discharge Temperature:	74 °F
Space Temperature:	76 °F
Space Relative Humidity:	44 %RH
Thermostat Set Point:	72 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	382 PPM

Comments:

J.C. Solmonese Elementary School report for sampling of testing.