

Indoor Air Quality Test Summary

BUILDING: J.C Solmonese Elementary School

Room Tested: 241

Date:	08/28/20
Time:	1:45 PM
Number Of Occupants:	2
Total Area Of Room:	7840 Cu. ft
CFM From Unit:	1570 CFM
CFM Into Exhaust:	302 CFM
Total Air Exchanges Per Hour:	11.63
Outside Air Temperature:	70 °F
Outside Air Relative Humidity:	71 %RH
Outside Air Co2:	82 PPM
Unit Discharge Temperature:	75 °F
Space Temperature:	76 °F
Space Relative Humidity:	56 %RH
Thermostat Set Point:	70 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	388 PPM

Comments:

J.C. Solmonese Elementary School report for sampling of testing.