

## Indoor Air Quality Test Summary

**BUILDING:** L.G. Nourse Elementary School

**Room Tested:** 24

Date:	08/28/20
Time:	1:50 PM
Number Of Occupants:	2
Total Area Of Room:	8640 Cu. ft
CFM From Unit:	961 CFM
CFM Into Exhaust:	397 CFM
Total Air Exchanges Per Hour:	6.67
Outside Air Temperature:	74 °F
Outside Air Relative Humidity:	71 %RH
Outside Air Co2:	82 PPM
Unit Discharge Temperature:	76 °F
Space Temperature:	75 °F
Space Relative Humidity:	55 %RH
Thermostat Set Point:	68 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	362 PPM

Comments:

L.G. Nourse Elementary School report for sampling of testing.