

Indoor Air Quality Test Summary

BUILDING: L.G. Nourse Elementary School

Room Tested: 26

| | |
|--------------------------------|-------------|
| Date: | 08/28/20 |
| Time: | 2:00 PM |
| Number Of Occupants: | 2 |
| Total Area Of Room: | 8640 Cu. ft |
| CFM From Unit: | 1335 CFM |
| CFM Into Exhaust: | 172 CFM |
| Total Air Exchanges Per Hour: | 9.27 |
| Outside Air Temperature: | 74 °F |
| Outside Air Relative Humidity: | 71 %RH |
| Outside Air Co2: | 82 PPM |
| Unit Discharge Temperature: | 76 °F |
| Space Temperature: | 76 °F |
| Space Relative Humidity: | 55 %RH |
| Thermostat Set Point: | 76 °F |
| % Of Outside Air: | 100% |
| Co2 Parts Per Million: | 335 PPM |

Comments:

L.G. Nourse Elementary School report for sampling of testing.