

## Indoor Air Quality Test Summary

**BUILDING:** L.G. Nourse Elementary School

**Room Tested:** 34

Date:	08/28/20
Time:	2:10 PM
Number Of Occupants:	2
Total Area Of Room:	8640 Cu. ft
CFM From Unit:	1024 CFM
CFM Into Exhaust:	295 CFM
Total Air Exchanges Per Hour:	7.11
Outside Air Temperature:	76 °F
Outside Air Relative Humidity:	71 %RH
Outside Air Co2:	81 PPM
Unit Discharge Temperature:	76 °F
Space Temperature:	76 °F
Space Relative Humidity:	56 %RH
Thermostat Set Point:	68 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	365 PPM

Comments:

L.G. Nourse Elementary School report for sampling of testing.