

Indoor Air Quality Test Summary

BUILDING: L.G. Nourse Elementary School

Room Tested: 46

Date:	08/28/20
Time:	2:25 PM
Number Of Occupants:	2
Total Area Of Room:	9000 Cu. ft
CFM From Unit:	1220 CFM
CFM Into Exhaust:	460 CFM
Total Air Exchanges Per Hour:	8.13
Outside Air Temperature:	76 °F
Outside Air Relative Humidity:	71 %RH
Outside Air Co2:	82 PPM
Unit Discharge Temperature:	78 °F
Space Temperature:	77 °F
Space Relative Humidity:	55 %RH
Thermostat Set Point:	72 °F
% Of Outside Air:	100%
Co2 Parts Per Million:	376 PPM

Comments:

L.G. Nourse Elementary School report for sampling of testing.