
WATER QUALITY TESTING

FOR

NORRIDGE SCHOOL DISTRICT 80

NORRIDGE, ILLINOIS

DECEMBER 6, 2017

PROJECT NUMBER: 17-18374



A DIVISION OF GALLAGHER BASSETT SERVICES, INC.

1550 Hubbard Ave., Batavia, IL 60510, 630-879-3006

TABLE OF CONTENTS

INTRODUCTION 1

BACKGROUND INFORMATION 1

METHODOLOGY 2

RESULTS 3

PROFESSIONAL CERTIFICATION 4

Appendix I: IDPH Guidelines

WATER QUALITY TESTING

FOR

NORRIDGE SCHOOL DISTRICT 80

NORRIDGE, ILLINOIS

DECEMBER 6, 2017

PROJECT NUMBER: 17-18374



A DIVISION OF GALLAGHER BASSETT SERVICES, INC.

1550 Hubbard Ave., Batavia, IL 60510, 630-879-3006

INTRODUCTION

Norridge School District 80 implemented a proactive program of water testing at the following schools:

- J Giles Elementary School
- John V. Leigh School

Water sampling was conducted by Mr. Jeffrey Olson of Aires Consulting. Mr. Geoffrey J. Bacci II, P.E. designed the study and developed this report.

This report contains a summary of results. Individual reports are also issued by school building and contain sampling maps and laboratory data.

BACKGROUND INFORMATION

The Lead in Drinking Water Testing Bill (LDWTB) was signed into law by Governor Bruce Rauner effective January 17, 2017. The bill amends six (6) different Illinois Codes and Acts including:

- The Illinois School Code
- Illinois Plumbing License Law.

The LDWTB requires school buildings constructed prior to January 1, 2000 to test drinking water sources for lead and provide written notification of the results. The Bill also directs the Illinois department of Public Health (IDPH) to draft rules by 1/1/2018 which may have additional requirements. The IDPH has issued a guidance document for drinking water testing which is included in Appendix I. The following is a summary of those guidelines:

- All schools housing 5th grade and under built before 1/1/2000 must test drinking sources used for drinking and cooking.
- Results of tests that are 5 parts per billion (ppb) or less can be communicated to parents at minimum by website posting.

- Locations that have results over 5 ppb must be communicated in writing or electronically to affected parents. That communication should also include information on the USEPA website that parents can access for guidance. That website: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

According to the LDWTB the testing and notification requirements apply only to covered sources which are:

- Drinking fountain and drinking sources in buildings for grade 5 and under
- Classroom sinks in grades below 1 (kindergarten and pre-kindergarten).

Aires recommends notification extends to all sources tested.

Lead most frequently gets into drinking water by leaching from plumbing materials and fixtures as water moves through a school's distribution system. Even though the drinking water you receive from your water supplier meets federal and state standards for lead and copper, your facility may have elevated lead levels due to plumbing materials and water use patterns. Leaching can occur for several reasons but the most significant is corrosion which can occur if water is acidic. Acidic water has a pH less than 7.0

Lead in new plumbing and plumbing repairs was banned in 1986. This ban did not entirely eliminate lead as 0.2% lead is still allowed in solder and 8% lead is allowed in piping systems. Pre-1986 plumbing systems have a higher potential to leach lead into drinking water.

Lead is a toxic metal that is harmful to human health. Young children, those 6 years and younger, are at particular risk for lead exposure because they have frequent hand-to-mouth activity and absorb lead more easily than do adults. Children's nervous systems are still undergoing development and thus are more susceptible to the effects of toxic agents. Lead is also harmful to the developing fetuses of pregnant women.

METHODOLOGY

Water testing followed protocol recommended by IDPH and the LDWTB. All water sources have two samples collected. The first collection at each source is a “first draw” sample. Water collection occurs in first draw samples after sources were unused for at least eight (8) hours but not more than 18 hrs. The second sample at that source is collected after 30 seconds of flushing. Each sample is given an identifier which begins with letters that identify the school. The middle letters identify the sample as a drinking fountain (WF), classroom sink (CS) or any other sink (S). Letters identify the sample location. An “A” after the letter indicates a first draw sample and a “B” identifies a flush sample. For example sample JGWF-2A was collected at location 2 at J Giles Elementary School and is a first draw sample at a water fountain. In certain locations where multiple outlets are present a “C” after the number can also denote a first draw sample from one of the outlets (i.e. water fountain with a bottle fill).

Samples were analyzed by Prairie Analytical Systems, Inc. Prairie Analytical is accredited by the National Environmental Laboratory Environmental Conference (NELAC).

The USEPA recommends taking action to reduce lead levels if sample results exceed 20 ppb. That action could include water treatment or fixture replacement.

Public water supplies are required by the Safe Drinking Water Act to take corrective action if 10% or more of their sources contain lead levels greater than 15 ppb.

RESULTS

The following locations are results that exceeded 5 ppb. Locations that exceeded the EPA action level of 20 ppb are shown in **bold print**.

J Giles Elementary:

All results were less than 5 parts per billion (ppb). Results ranged from non-detectable (< 2 ppb) to 2.99 ppb.

Leigh School:

- **LEWF-18A: first draw sample from the drinking fountain in the LL Hall across from Room 147 – 22.0 ppb**

- LEWF-18B: flush sample from the drinking fountain in the LL Hall across from Room 147 – 5.98 ppb
- LEKS-35A: first draw sample from the sink in the Gym Kitchenette – 7.63 ppb

Parents should be notified of results that exceed 5 ppb parents within 7 days per IDPH guidelines. Remaining results should be at minimum posted on the Districts website. All sample results should be e-mailed to IDPH within 7 days.

Drinking fountains that exceed 20 ppb should be taken out of service. Further investigation and corrective action is necessary to identify the lead source and identify corrective action to reduce lead levels.

PROFESSIONAL CERTIFICATION

Aires Consulting, a division of Gallagher Bassett Services, Inc. conducted this study in the interest of Norridge School District 80 **to** assist in meeting environmental obligations and regulations. In this respect, we hope the results of this study are useful. *This study was not intended to include every environmental exposure that may be present at the facility; only those items specifically addressed in the report were evaluated.* If you have any questions concerning this study please let us know.

Respectfully Submitted,



Geoffrey J. Bacci II, P.E.
Director of Operations

Sampling Protocol for Drinking Water in Schools



*A Guidance Document for
Drinking Water Testing*



- ❖ Schools must use an Illinois Environmental Protection Agency (IEPA) accredited laboratory for the testing.
- ❖ Schools must provide the Illinois Department of Public Health (IDPH) with sample results within 7 days of receipt. Results should be emailed to DPH.LeadH2O@illinois.gov.

SB 0550 was signed by Governor Bruce Rauner on January 16, 2017. It requires all schools (Pre-K through 5th grade) to test for lead in water used for drinking and cooking. Schools built after January 1, 2000 are not required to test at this time.

Sampling must be completed by:

- ❖ December 31, 2017 — Schools constructed prior to January 1, 1987
- ❖ December 31, 2018 — Schools constructed between January 2, 1987 and January 1, 2000



Action Steps Prior to Sampling Appendix I

1. Your local water supply can be a great resource. Contact them to request assistance in establishing your sampling plan.
2. Obtain a general floor plan for each school building. Floor plans are available in the schools' asbestos management plan.
3. Identify all fixtures to be sampled on the general floor plan. All plumbing fixtures that are used for cooking or drinking must be sampled. Bathroom and utility sinks do not need to be sampled.
4. Assign a unique alphanumeric identifier to each fixture.
5. Label fixture identifiers on the floor plan. Make sure all samples are labeled with the corresponding alphanumeric identifier for each fixture.
6. Determine which IEPA accredited laboratory you will utilize for the analysis. A list can be found at <http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index>.
7. Contact the laboratory to obtain enough 250 mL sample bottles and Chain of Custody forms to allow you to collect 2 samples from each fixture. The laboratory will also provide sample shipping instructions.



Test Results

How to interpret your test results

1. Test results will be reported in either parts per billion (ppb) or micrograms per liter (ug/l). Both units of measure are appropriate.
2. If any sample exceeds 5 ppb of lead, the notification requirements are triggered.



Reporting and Notification Requirements

- ❖ Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH2O@illinois.gov.
- ❖ If all sample results are less than 5 ppb, schools may use their website (at minimum) to notify parents of the results.
- ❖ If any of the sample results exceed 5 ppb, schools must notify parents in writing or electronically, and include :
 - The location and source exceeding 5 ppb, and
 - The USEPA website for information about lead in drinking water: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Parents should be advised to contact their health care provider with any concerns about their child's health, including blood tests for lead exposure.

Next Steps

Test results will likely generate questions from parents, guardians, and the public about steps the school is taking to address lead in water.

Removing fixtures from use may not be an immediate option. Establishment of a water management plan, including identification of lead-containing plumbing, scheduled flushing, fixture replacement, and monitoring is the best course of action for schools addressing positive lead test results.

Additional guidance for interim (short-term) and permanent lead control measures is provided in the USEPA 3Ts for Reducing Lead in Drinking Water in Schools. This document can be found at:

www.epa.gov/sites/production/files/201509/documents/toolkit_leadschools_guide_3ts_leadschools.pdf



The Illinois Department of Public Health supports the efforts of Illinois Section AWWA to educate schools about lead testing. For additional information see dph.illinois.gov.

Sampling Protocol for Drinking Water in Schools



*A Guidance Document for
Drinking Water Testing*



- ❖ Schools must use an Illinois Environmental Protection Agency (IEPA) accredited laboratory for the testing.
- ❖ Schools must provide the Illinois Department of Public Health (IDPH) with sample results within 7 days of receipt. Results should be emailed to DPH.LeadH2O@illinois.gov.

SB 0550 was signed by Governor Bruce Rauner on January 16, 2017. It requires all schools (Pre-K through 5th grade) to test for lead in water used for drinking and cooking. Schools built after January 1, 2000 are not required to test at this time.

Sampling must be completed by:

- ❖ December 31, 2017 — Schools constructed prior to January 1, 1987
- ❖ December 31, 2018 — Schools constructed between January 2, 1987 and January 1, 2000



Action Steps Prior to Sampling Appendix I

1. Your local water supply can be a great resource. Contact them to request assistance in establishing your sampling plan.
2. Obtain a general floor plan for each school building. Floor plans are available in the schools' asbestos management plan.
3. Identify all fixtures to be sampled on the general floor plan. All plumbing fixtures that are used for cooking or drinking must be sampled. Bathroom and utility sinks do not need to be sampled.
4. Assign a unique alphanumeric identifier to each fixture.
5. Label fixture identifiers on the floor plan. Make sure all samples are labeled with the corresponding alphanumeric identifier for each fixture.
6. Determine which IEPA accredited laboratory you will utilize for the analysis. A list can be found at <http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index>.
7. Contact the laboratory to obtain enough 250 mL sample bottles and Chain of Custody forms to allow you to collect 2 samples from each fixture. The laboratory will also provide sample shipping instructions.



Test Results

How to interpret your test results

1. Test results will be reported in either parts per billion (ppb) or micrograms per liter (ug/l). Both units of measure are appropriate.
2. If any sample exceeds 5 ppb of lead, the notification requirements are triggered.



Reporting and Notification Requirements

- ❖ Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH2O@illinois.gov.
- ❖ If all sample results are less than 5 ppb, schools may use their website (at minimum) to notify parents of the results.
- ❖ If any of the sample results exceed 5 ppb, schools must notify parents in writing or electronically, and include :
 - The location and source exceeding 5 ppb, and
 - The USEPA website for information about lead in drinking water: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Parents should be advised to contact their health care provider with any concerns about their child's health, including blood tests for lead exposure.

Next Steps

Test results will likely generate questions from parents, guardians, and the public about steps the school is taking to address lead in water.

Removing fixtures from use may not be an immediate option. Establishment of a water management plan, including identification of lead-containing plumbing, scheduled flushing, fixture replacement, and monitoring is the best course of action for schools addressing positive lead test results.

Additional guidance for interim (short-term) and permanent lead control measures is provided in the USEPA 3Ts for Reducing Lead in Drinking Water in Schools. This document can be found at:

www.epa.gov/sites/production/files/201509/documents/toolkit_leadschools_guide_3ts_leadschools.pdf



The Illinois Department of Public Health supports the efforts of Illinois Section AWWA to educate schools about lead testing. For additional information see dph.illinois.gov.