

ANALYTICAL REPORT

Job Number: 420-111165-1

SDG Number: Emanuel Axelrod Education Center

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw

Meredith Ruthven

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

11/07/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Job Narrative
420-J111165-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Cusack, Renee	RC

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111165-1	Laundry Room Spigot (497)	Drinking Water	09/24/2016 0509	09/30/2016 1048
420-111165-2	Kitchen Server Sink (Rm 445)	Drinking Water	09/24/2016 0510	09/30/2016 1048
420-111165-3	Kitchen Dishwasher Sink (Rm 445)	Drinking Water	09/24/2016 0510	09/30/2016 1048
420-111165-4	Kitchen Dishwasher Sprayer (Rm 445)	Drinking Water	09/24/2016 0511	09/30/2016 1048
420-111165-5	Custodial Break Room Kitchen Sink	Drinking Water	09/24/2016 0513	09/30/2016 1048
420-111165-6	Custodial Break Room Slop Sink	Drinking Water	09/24/2016 0513	09/30/2016 1048
420-111165-7	Room 443 Bathroom Sink	Drinking Water	09/24/2016 0517	09/30/2016 1048
420-111165-8	Room 442 Bathroom Sink	Drinking Water	09/24/2016 0518	09/30/2016 1048
420-111165-9	Room 442 Classroom Sink	Drinking Water	09/24/2016 0518	09/30/2016 1048
420-111165-10	Room 444 Sink	Drinking Water	09/24/2016 0519	09/30/2016 1048
420-111165-11	Room 452 Bathroom Sink	Drinking Water	09/24/2016 0521	09/30/2016 1048
420-111165-12	Faculty Bathroom Sink (Near 458)	Drinking Water	09/24/2016 0522	09/30/2016 1048
420-111165-13	Classroom 441 Sink	Drinking Water	09/24/2016 0525	09/30/2016 1048
420-111165-14	(Rm 434) Boy's Gang Left Sink	Drinking Water	09/24/2016 0526	09/30/2016 1048
420-111165-15	(Rm 434) Boy's Gang Right Sink	Drinking Water	09/24/2016 0526	09/30/2016 1048
420-111165-16	Water Fountain by 434	Drinking Water	09/24/2016 0527	09/30/2016 1048
420-111165-17	Faculty Bathroom by 434	Drinking Water	09/24/2016 0528	09/30/2016 1048
420-111165-18	Rm 435 Classroom Sink	Drinking Water	09/24/2016 0528	09/30/2016 1048
420-111165-19	Classroom 432 Sink	Drinking Water	09/24/2016 0530	09/30/2016 1048
420-111165-20	Rm 433 Classroom Sink	Drinking Water	09/24/2016 0530	09/30/2016 1048
420-111165-21	Rm 430 Sink	Drinking Water	09/24/2016 0531	09/30/2016 1048
420-111165-22	Rm 431 Classroom Sink	Drinking Water	09/24/2016 0532	09/30/2016 1048
420-111165-23	Rm 429 Sink	Drinking Water	09/24/2016 0532	09/30/2016 1048
420-111165-24	Faculty Bathroom Sink 428	Drinking Water	09/24/2016 0532	09/30/2016 1048
420-111165-25	Girl's Gang Bathroom Left Sink (428)	Drinking Water	09/24/2016 0533	09/30/2016 1048
420-111165-26	Girl's Gang Bathroom Right Sink (428)	Drinking Water	09/24/2016 0534	09/30/2016 1048
420-111165-27	Room 423 Library Sink	Drinking Water	09/24/2016 0534	09/30/2016 1048
420-111165-28	Health 421 Bathroom Sink	Drinking Water	09/24/2016 0535	09/30/2016 1048
420-111165-29	Health 421 Hand Washing Sink	Drinking Water	09/24/2016 0536	09/30/2016 1048
420-111165-30	Room 426 Sink	Drinking Water	09/24/2016 0536	09/30/2016 1048
420-111165-31	Health 419 Office Left Sink	Drinking Water	09/24/2016 0537	09/30/2016 1048
420-111165-32	Health 419 Office Right Sink	Drinking Water	09/24/2016 0537	09/30/2016 1048
420-111165-33	Room 425 Sink	Drinking Water	09/24/2016 0539	09/30/2016 1048
420-111165-34	Health 419 Bathroom Sink	Drinking Water	09/24/2016 0538	09/30/2016 1048
420-111165-35	RCCE 417 Kitchen Sink	Drinking Water	09/24/2016 0540	09/30/2016 1048
420-111165-36	417 Women's Bathroom	Drinking Water	09/24/2016 0541	09/30/2016 1048
420-111165-37	417 Men's Bathroom	Drinking Water	09/24/2016 0542	09/30/2016 1048

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111165-38	Water Fountain Across from RCCE Office	Drinking Water	09/24/2016 0544	09/30/2016 1048
420-111165-39	Room 410	Drinking Water	09/24/2016 0545	09/30/2016 1048
420-111165-40	Room 410 Bathroom Sink	Drinking Water	09/24/2016 0546	09/30/2016 1048
420-111165-41	Bathroom by 411 Left Sink	Drinking Water	09/24/2016 0547	09/30/2016 1048
420-111165-42	Bathroom by 411 Right Sink	Drinking Water	09/24/2016 0547	09/30/2016 1048
420-111165-43	Water Fountain on Right by Stage	Drinking Water	09/24/2016 0548	09/30/2016 1048
420-111165-44	Water Fountain on Left by Stage	Drinking Water	09/24/2016 0549	09/30/2016 1048
420-111165-45	Gang Bathroom by Gym (401) Left Sink	Drinking Water	09/24/2016 0549	09/30/2016 1048
420-111165-46	Gang Bathroom by Gym (401) Right Sink	Drinking Water	09/24/2016 0549	09/30/2016 1048
420-111165-47	Room 408 Drinking Fountain	Drinking Water	09/24/2016 0551	09/30/2016 1048
420-111165-48	Room 408 Sink	Drinking Water	09/24/2016 0551	09/30/2016 1048
420-111165-49	Room 406 Classroom Sink	Drinking Water	09/24/2016 0553	09/30/2016 1048
420-111165-50	Custodial Closet Next to 406	Drinking Water	09/24/2016 0554	09/30/2016 1048
420-111165-51	Faculty Bathroom 405 Sink	Drinking Water	09/24/2016 0555	09/30/2016 1048
420-111165-52	Room 404 Sink	Drinking Water	09/24/2016 0555	09/30/2016 1048
420-111165-53	Room 402 Bathroom Sink	Drinking Water	09/24/2016 0556	09/30/2016 1048
420-111165-54	Room 402 Classroom Sink	Drinking Water	09/24/2016 0557	09/30/2016 1048
420-111165-55	Room 414 Classroom Sink	Drinking Water	09/24/2016 0559	09/30/2016 1048
420-111165-56	Room 414 Bathroom Sink	Drinking Water	09/24/2016 0559	09/30/2016 1048
420-111165-57	Room 416 Bathroom Sink	Drinking Water	09/24/2016 0600	09/30/2016 1048
420-111165-58	Room 416 Classroom Sink	Drinking Water	09/24/2016 0600	09/30/2016 1048
420-111165-59	Faculty 416A Bathroom Sink	Drinking Water	09/24/2016 0601	09/30/2016 1048
420-111165-60	Faculty 418A Bathroom Sink	Drinking Water	09/24/2016 0602	09/30/2016 1048
420-111165-61	Room 418 Sink	Drinking Water	09/24/2016 0603	09/30/2016 1048
420-111165-62	Room 418 Bathroom Sink	Drinking Water	09/24/2016 0603	09/30/2016 1048
420-111165-63	Room 420 Bathroom Sink	Drinking Water	09/24/2016 0604	09/30/2016 1048
420-111165-64	Room 420 Sink	Drinking Water	09/24/2016 0604	09/30/2016 1048
420-111165-65	Room 422 Bathroom in Classroom	Drinking Water	09/24/2016 0605	09/30/2016 1048
420-111165-66	Room 422 Bathroom Right Inside Classroom Door	Drinking Water	09/24/2016 0606	09/30/2016 1048
420-111165-67	Room 422 Sink	Drinking Water	09/24/2016 0606	09/30/2016 1048
420-111165-68	Room 424 Sink	Drinking Water	09/24/2016 0607	09/30/2016 1048
420-111165-69	Room 476 Bathroom Sink	Drinking Water	09/24/2016 0609	09/30/2016 1048
420-111165-70	Room 475 Sink	Drinking Water	09/24/2016 0610	09/30/2016 1048
420-111165-71	Room 465 Sink	Drinking Water	09/24/2016 0611	09/30/2016 1048
420-111165-72	Water Fountain Across from 464	Drinking Water	09/24/2016 0612	09/30/2016 1048
420-111165-73	Resnick Boy's Bathroom Left Sink	Drinking Water	09/24/2016 0612	09/30/2016 1048

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111165-74	Resnick Boy's Bathroom Right Sink	Drinking Water	09/24/2016 0613	09/30/2016 1048
420-111165-75	Resnick Girl's Bathroom Left Sink	Drinking Water	09/24/2016 0613	09/30/2016 1048
420-111165-76	Resnick Gym Water Fountain (460)	Drinking Water	09/24/2016 0614	09/30/2016 1048
420-111165-77	Resnick Girl's Bathroom Right Sink	Drinking Water	09/24/2016 0614	09/30/2016 1048
420-111165-78	Bathroom Sink Next to 498	Drinking Water	09/24/2016 0640	09/30/2016 1048
420-111165-79	Outside Spigot by 455	Drinking Water	09/24/2016 0637	09/30/2016 1048
420-111165-80	Boiler Room Slop Sink Under Admin.	Drinking Water	09/24/2016 0642	09/30/2016 1048

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Laundry Room Spigot (497)
Lab Sample ID: 420-111165-1

Date Sampled: 09/24/2016 0509
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1644	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Kitchen Server Sink (Rm 445)
Lab Sample ID: 420-111165-2

Date Sampled: 09/24/2016 0510
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1643	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Kitchen Dishwasher Sink (Rm 445)
Lab Sample ID: 420-111165-3

Date Sampled: 09/24/2016 0510
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1642	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Kitchen Dishwasher Sprayer (Rm 445)
Lab Sample ID: 420-111165-4

Date Sampled: 09/24/2016 0511
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1642	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Custodial Break Room Kitchen Sink
Lab Sample ID: 420-111165-5

Date Sampled: 09/24/2016 0513
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1641	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Custodial Break Room Slop Sink
Lab Sample ID: 420-111165-6

Date Sampled: 09/24/2016 0513
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1640	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 443 Bathroom Sink
Lab Sample ID: 420-111165-7

Date Sampled: 09/24/2016 0517
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1639	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.55	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 442 Bathroom Sink
Lab Sample ID: 420-111165-8

Date Sampled: 09/24/2016 0518
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1638	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	2.37	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 442 Classroom Sink
Lab Sample ID: 420-111165-9

Date Sampled: 09/24/2016 0518
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1638	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.16	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 444 Sink
Lab Sample ID: 420-111165-10

Date Sampled: 09/24/2016 0519
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1637		
Prep Method: 200			Date Prepared: 10/29/2016 1300		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 452 Bathroom Sink
Lab Sample ID: 420-111165-11

Date Sampled: 09/24/2016 0521
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1632	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	3.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty Bathroom Sink (Near 458)
Lab Sample ID: 420-111165-12

Date Sampled: 09/24/2016 0522
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1631	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.11	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Classroom 441 Sink
Lab Sample ID: 420-111165-13

Date Sampled: 09/24/2016 0525
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1630	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: (Rm 434) Boy's Gang Left Sink
Lab Sample ID: 420-111165-14

Date Sampled: 09/24/2016 0526
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1630	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: (Rm 434) Boy's Gang Right Sink
Lab Sample ID: 420-111165-15

Date Sampled: 09/24/2016 0526
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1629	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Water Fountain by 434
Lab Sample ID: 420-111165-16

Date Sampled: 09/24/2016 0527
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1628	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty Bathroom by 434
Lab Sample ID: 420-111165-17

Date Sampled: 09/24/2016 0528
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1627	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Rm 435 Classroom Sink
Lab Sample ID: 420-111165-18

Date Sampled: 09/24/2016 0528
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1625	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Classroom 432 Sink
Lab Sample ID: 420-111165-19

Date Sampled: 09/24/2016 0530
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1624	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.25	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Rm 433 Classroom Sink
Lab Sample ID: 420-111165-20

Date Sampled: 09/24/2016 0530
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1623	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	3.31	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Rm 430 Sink
Lab Sample ID: 420-111165-21

Date Sampled: 09/24/2016 0531
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1622	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Rm 431 Classroom Sink
Lab Sample ID: 420-111165-22

Date Sampled: 09/24/2016 0532
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1622	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	4.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Rm 429 Sink
Lab Sample ID: 420-111165-23

Date Sampled: 09/24/2016 0532
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1621	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty Bathroom Sink 428
Lab Sample ID: 420-111165-24

Date Sampled: 09/24/2016 0532
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1620		
Prep Method: 200			Date Prepared: 10/29/2016 1300		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Girl's Gang Bathroom Left Sink (428)
Lab Sample ID: 420-111165-25

Date Sampled: 09/24/2016 0533
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1619	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Girl's Gang Bathroom Right Sink (428)
Lab Sample ID: 420-111165-26

Date Sampled: 09/24/2016 0534
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1618	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 423 Library Sink
Lab Sample ID: 420-111165-27

Date Sampled: 09/24/2016 0534
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1618	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Health 421 Bathroom Sink
Lab Sample ID: 420-111165-28

Date Sampled: 09/24/2016 0535
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1615	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.40	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Health 421 Hand Washing Sink
Lab Sample ID: 420-111165-29

Date Sampled: 09/24/2016 0536
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1614	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 426 Sink
Lab Sample ID: 420-111165-30

Date Sampled: 09/24/2016 0536
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1614		
Prep Method: 200			Date Prepared: 10/29/2016 1300		
Pb	3.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Health 419 Office Left Sink
Lab Sample ID: 420-111165-31

Date Sampled: 09/24/2016 0537
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1610	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Health 419 Office Right Sink
Lab Sample ID: 420-111165-32

Date Sampled: 09/24/2016 0537
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1610	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 425 Sink
Lab Sample ID: 420-111165-33

Date Sampled: 09/24/2016 0539
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1609	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Health 419 Bathroom Sink
Lab Sample ID: 420-111165-34

Date Sampled: 09/24/2016 0538
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1608	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: RCCE 417 Kitchen Sink
Lab Sample ID: 420-111165-35

Date Sampled: 09/24/2016 0540
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1606	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.55	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: 417 Women's Bathroom
Lab Sample ID: 420-111165-36

Date Sampled: 09/24/2016 0541
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1605	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: 417 Men's Bathroom
Lab Sample ID: 420-111165-37

Date Sampled: 09/24/2016 0542
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1604	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	3.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Water Fountain Across from RCCE Office
Lab Sample ID: 420-111165-38

Date Sampled: 09/24/2016 0544
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1603	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	12.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 410
Lab Sample ID: 420-111165-39

Date Sampled: 09/24/2016 0545
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1602	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	3.98	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 410 Bathroom Sink
Lab Sample ID: 420-111165-40

Date Sampled: 09/24/2016 0546
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1602	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Bathroom by 411 Left Sink
Lab Sample ID: 420-111165-41

Date Sampled: 09/24/2016 0547
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1903	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Bathroom by 411 Right Sink
Lab Sample ID: 420-111165-42

Date Sampled: 09/24/2016 0547
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1904	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.72	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Water Fountain on Right by Stage
Lab Sample ID: 420-111165-43

Date Sampled: 09/24/2016 0548
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1905	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Water Fountain on Left by Stage
Lab Sample ID: 420-111165-44

Date Sampled: 09/24/2016 0549
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1905	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Gang Bathroom by Gym (401) Left Sink
Lab Sample ID: 420-111165-45

Date Sampled: 09/24/2016 0549
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1906	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Gang Bathroom by Gym (401) Right Sink
Lab Sample ID: 420-111165-46

Date Sampled: 09/24/2016 0549
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1907	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.44	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 408 Drinking Fountain
Lab Sample ID: 420-111165-47

Date Sampled: 09/24/2016 0551
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1908	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	64.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 408 Sink
Lab Sample ID: 420-111165-48

Date Sampled: 09/24/2016 0551
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1909		
Prep Method: 200			Date Prepared: 10/29/2016 1300		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 406 Classroom Sink
Lab Sample ID: 420-111165-49

Date Sampled: 09/24/2016 0553
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1909	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	1.37	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Custodial Closet Next to 406
Lab Sample ID: 420-111165-50

Date Sampled: 09/24/2016 0554
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1910	
Prep Method: 200			Date Prepared:	10/29/2016 1300	
Pb	8.50	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty Bathroom 405 Sink
Lab Sample ID: 420-111165-51

Date Sampled: 09/24/2016 0555
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1913	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.19	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 404 Sink
Lab Sample ID: 420-111165-52

Date Sampled: 09/24/2016 0555
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1916	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	2.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 402 Bathroom Sink
Lab Sample ID: 420-111165-53

Date Sampled: 09/24/2016 0556
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1917	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	4.46	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 402 Classroom Sink
Lab Sample ID: 420-111165-54

Date Sampled: 09/24/2016 0557
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1917	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 414 Classroom Sink
Lab Sample ID: 420-111165-55

Date Sampled: 09/24/2016 0559
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1918	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 414 Bathroom Sink
Lab Sample ID: 420-111165-56

Date Sampled: 09/24/2016 0559
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1919	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 416 Bathroom Sink
Lab Sample ID: 420-111165-57

Date Sampled: 09/24/2016 0600
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1920		
Prep Method: 200			Date Prepared: 10/29/2016 1330		
Pb	1.73	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 416 Classroom Sink
Lab Sample ID: 420-111165-58

Date Sampled: 09/24/2016 0600
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1922		
Prep Method: 200			Date Prepared: 10/29/2016 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty 416A Bathroom Sink
Lab Sample ID: 420-111165-59

Date Sampled: 09/24/2016 0601
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1923	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	2.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Faculty 418A Bathroom Sink
Lab Sample ID: 420-111165-60

Date Sampled: 09/24/2016 0602
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1924	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 418 Sink
Lab Sample ID: 420-111165-61

Date Sampled: 09/24/2016 0603
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1925	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.19	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 418 Bathroom Sink
Lab Sample ID: 420-111165-62

Date Sampled: 09/24/2016 0603
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1925	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 420 Bathroom Sink
Lab Sample ID: 420-111165-63

Date Sampled: 09/24/2016 0604
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1926		
Prep Method: 200			Date Prepared: 10/29/2016 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 420 Sink
Lab Sample ID: 420-111165-64

Date Sampled: 09/24/2016 0604
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1927	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 422 Bathroom in Classroom
Lab Sample ID: 420-111165-65

Date Sampled: 09/24/2016 0605
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1928	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.01	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 422 Bathroom Right Inside Classroom
Lab Sample ID: 420-111165-66

Date Sampled: 09/24/2016 0606
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1928		
Prep Method: 200			Date Prepared: 10/29/2016 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 422 Sink
Lab Sample ID: 420-111165-67

Date Sampled: 09/24/2016 0606
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1929	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 424 Sink
Lab Sample ID: 420-111165-68

Date Sampled: 09/24/2016 0607
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1932	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	2.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 476 Bathroom Sink
Lab Sample ID: 420-111165-69

Date Sampled: 09/24/2016 0609
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1933	
Prep Method: 200			Date Prepared:	10/29/2016 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 475 Sink
Lab Sample ID: 420-111165-70

Date Sampled: 09/24/2016 0610
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1933		
Prep Method: 200			Date Prepared: 10/29/2016 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Room 465 Sink
Lab Sample ID: 420-111165-71

Date Sampled: 09/24/2016 0611
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1934	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Water Fountain Across from 464
Lab Sample ID: 420-111165-72

Date Sampled: 09/24/2016 0612
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1937		
Prep Method: 200			Date Prepared: 10/29/2016 1400		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Resnick Boy's Bathroom Left Sink
Lab Sample ID: 420-111165-73

Date Sampled: 09/24/2016 0612
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1938	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Resnick Boy's Bathroom Right Sink
Lab Sample ID: 420-111165-74

Date Sampled: 09/24/2016 0613
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/30/2016 1939		
Prep Method: 200			Date Prepared: 10/29/2016 1400		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Resnick Girl's Bathroom Left Sink
Lab Sample ID: 420-111165-75

Date Sampled: 09/24/2016 0613
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1941	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Resnick Gym Water Fountain (460)
Lab Sample ID: 420-111165-76

Date Sampled: 09/24/2016 0614
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1942	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Resnick Girl's Bathroom Right Sink
Lab Sample ID: 420-111165-77

Date Sampled: 09/24/2016 0614
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1943	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Bathroom Sink Next to 498
Lab Sample ID: 420-111165-78

Date Sampled: 09/24/2016 0640
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1944	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	2.20	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Outside Spigot by 455
Lab Sample ID: 420-111165-79

Date Sampled: 09/24/2016 0637
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1944	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	8.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-111165-1
Sdg Number: Emanuel Axelrod Education Center

Client Sample ID: Boiler Room Slop Sink Under Admin.
Lab Sample ID: 420-111165-80

Date Sampled: 09/24/2016 0642
Date Received: 09/30/2016 1048
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/30/2016 1945	
Prep Method: 200			Date Prepared:	10/29/2016 1400	
Pb	8.59	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Emanuel Axelrod Education Center

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Emanuel Axelrod Education Center

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Emanuel Axelrod Education Center

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



CHAIN OF CUSTODY

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
111165

1097

PROJECT REFERENCE Orange-Ulster BOCES/Emanuel Axelrod Education Center		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES							PAGE 1 of 1						
ENVIROTEST PROJECT MANAGER Debra Bayer		TOWN		SOLID OR SEMISOLID		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		TURNAROUND TIME	
CLIENT (SITE) / PM Jack DeGraw		CLIENT PHONE 845-781-4887		AQUEOUS (WATER)		Liter Amber HCl		40ml Vials HCl		Other		Other		Other		NORMAL		QUICK	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		COMPOSITE (C) OR GRAB (G) / INDICATE		Other Specify		Other		Other		Other		Other		VERBAL			
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		SAMPLE IDENTIFICATION		DATE		DATE		DATE		DATE		DATE		DATE		DATE		DATE	
COMPANY CONTRACTING THIS WORK (If applicable)		Laundry Room spigot (497)		9/24/2016 0509		9/30/16		1048		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Kitchen server sink (rm 445)		9/24/2016 0510		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Kitchen dishwasher sink (rm 445)		9/24/2016 0510		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Kitchen dishwasher sprayer (rm 445)		9/24/2016 0511		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		custodial break room kitchen sink		9/24/2016 0513		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		custodial break room slop sink		9/24/2016 0513		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Room 443 bathroom sink		9/24/2016 0517		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Room 442 bathroom sink		9/24/2016 0518		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Room 442 classroom sink		9/24/2016 0518		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Room 444 sink		9/24/2016 0519		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Room 452 bathroom sink		9/24/2016 0521		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		Faculty bathroom sink (near 458)		9/24/2016 0522		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
		classroom 441 sink		9/24/2016 0535		9/24/16		1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
RELINQUISHED BY: (SIGNATURE) <i>Christy Fischer</i>		COMPANY oubooces		DATE 9/30/16		TIME 1048		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
SAMPLED BY: (SIGNATURE) <i>Naureen O'Doherty</i>		COMPANY oubooces		DATE 9/24/16		TIME 1000		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
RELINQUISHED BY: (SIGNATURE) <i>Naureen O'Doherty</i>		COMPANY oubooces		DATE 9/24/16		TIME 1048		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	

RECEIVED FOR LABORATORY BY: (SIGNATURE) *A. Elmendorf ETC*

DATE **9/30/16** TIME **1048** CUSTODY INTACT YES/NO

COOLER TEMP (C) **20.2°C**

LABORATORY REMARKS: ICE (Y/N) pH **CL2** Reviewed by: _____

IR #3



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

11165

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Orange-Ulster BOCES/Emmanuel Axelrod Education Center		PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES							PAGE 1 of 1		
ENVIROTEST PROJECT MANAGER Debra Bayer		TOWN	SOLID OR SEMISOLID D (Drinking Water) or W (Waste Water) Indicate	Other	Other	Terra Core	250ml Plastic	250ml Plastic Sulfuric Acid	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	40ml Vials HCl	1	TURNAROUND TIME
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		CLIENT FAX	Other	Other	Other	Other	Other	Other	Other	Other	Other
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		NUMBER OF CONTAINERS SUBMITTED							QUICK	VERBAL	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPANY CONTRACTING FIRM (WORK ORDER #)		COMPOSITE (C) OR GRAB (G) INDICATE							# OF COOLERS		
SAMPLE DATE		SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED							REMARKS		
14	9/24/2016	0526	(Rm 434) Boy's gang left sink	G	D							1	Lead (DW 200.8)
15	9/24/2016	0526	(Rm 434) Boy's gang right sink	G	D							1	Lead (DW 200.8)
16	9/24/2016	0527	Water fountain by 434	G	D							1	Lead (DW 200.8)
17	9/24/2016	0528	Faculty bathroom by 434	G	D							1	Lead (DW 200.8)
18	9/24/2016	0528	Rm 435 classroom sink	G	D							1	Lead (DW 200.8)
19	9/24/2016	0530	Classroom 432 sink	G	D							1	Lead (DW 200.8)
20	9/24/2016	0530	Rm 433 classroom sink	G	D							1	Lead (DW 200.8)
21	9/24/2016	0531	Rm 430 sink	G	D							1	Lead (DW 200.8)
22	9/24/2016	0532	Rm 431 classroom sink	G	D							1	Lead (DW 200.8)
23	9/24/2016	0532	Rm 429 sink	G	D							1	Lead (DW 200.8)
24	9/24/2016	0532	Faculty bathroom sink 428	G	D							1	Lead (DW 200.8)
25	9/24/2016	0533	Girl's gang bathroom left sink (428)	G	D							1	Lead (DW 200.8)
26	9/24/2016	0534	Girl's gang bathroom right sink (428)	G	D							1	Lead (DW 200.8)

RECEIVED BY (SIGNATURE) <i>John P. ...</i>	DATE 9/30/16	TIME 1048	COMPANY oubooces
SAMPLED BY (SIGNATURE) <i>Trained P. Doherty</i>	DATE 9/29/16	TIME 1000	COMPANY oubooces
RELINQUISHED BY (SIGNATURE)	DATE	TIME	COMPANY

RECEIVED FOR LABORATORY BY (SIGNATURE) <i>A. Elmendorf</i>	DATE 9/30/16	TIME 1048	CUSTODY INTACT YES NO	COOLER TEMP (C) 20.2°C	LABORATORY REMARKS ICE (Y/N) pH CL2	Reviewed by
---	-----------------	--------------	-----------------------------	---------------------------	--	-------------

IR # 3



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

11165

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name

EnviroTest Laboratories

Address & Phone

PROJECT REFERENCE Orange-Ulster BOCES/Emmanuel Axelrod Education Center		PROJECT NO	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES		PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer		P/O NUMBER	TOWN	Other Specify	40ml Vials HCl	250ml Plastic Nitric Acid	TURNAROUND TIME
CLIENT(SITE) NAME Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX	AQUEOUS (WATER)	Liter Amber HCl	250ml Plastic Sulfuric Acid	NORMAL
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		COMPOSITE (C) OR GRAB (G) INDICATE	Liter Amber HCl	250ml Plastic Nitric Acid	QUICK
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924				SOLID OR SEMISOLID	250ml Plastic Sulfuric Acid	250ml Plastic Nitric Acid	VERBAL
COMPANY CONTACTING THIS WORK (if applicable)					250ml Plastic Sulfuric Acid	250ml Plastic Nitric Acid	
SAMPLE IDENTIFICATION					40ml Vials HCl	40ml Vials HCl	
DATE	TIME				NUMBER OF CONTAINERS SUBMITTED		REMARKS
9/24/2016	0534	Room 423 Library sink		G	1	1	Lead (DW 200.8)
9/24/2016	0535	Health 421 Bathroom sink		G	1	1	Lead (DW 200.8)
9/24/2016	0536	Health 421 Hand washing sink		G	1	1	Lead (DW 200.8)
9/24/2016	0536	Room 426 sink		G	1	1	Lead (DW 200.8)
9/24/2016	0537	Health 419 office left sink		G	1	1	Lead (DW 200.8)
9/24/2016	0537	Health 419 office right sink		G	1	1	Lead (DW 200.8)
9/24/2016	0539	Room 425 sink		G	1	1	Lead (DW 200.8)
9/24/2016	0538	Health 419 Bathroom sink		G	1	1	Lead (DW 200.8)
9/24/2016	0540	RCCE 417 Kitchen sink		G	1	1	Lead (DW 200.8)
9/24/2016	0541	417 Woman's bathroom		G	1	1	Lead (DW 200.8)
9/24/2016	0542	417 Men's bathroom		G	1	1	Lead (DW 200.8)
9/24/2016	0544	water fountain across from RCCE office		G	1	1	Lead (DW 200.8)
9/24/2016	0545	Room 410		G	1	1	Lead (DW 200.8)
RELINQUISHED BY (SIGNATURE)	DATE	COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMPANY DATE	TIME
<i>[Signature]</i>	9/20/16	OUBOCES	9/24/16	1048	<i>[Signature]</i>		
SAMPLED BY (SIGNATURE)	DATE	COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMPANY DATE	TIME
<i>Trawnee O'Doherty</i>	9/20/16	OUBOCES	9/24/16	1000	<i>[Signature]</i>		
RELINQUISHED BY (SIGNATURE)	DATE	COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMPANY DATE	TIME
<i>[Signature]</i>	9/20/16	OUBOCES	9/24/16	1048	<i>[Signature]</i>		

LABORATORY REMARKS: ICE (Y/N) PH CL2 _____ Reviewed by _____

COOLER Temp (C): 20.2°C

IR #3

111165

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

687

PROJECT REFERENCE Orange-Ulster BOCES/Manuel Axelrod Education Center		PROJECT NO.		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES							PAGE 1 of 1								
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER		TOWN		OTHER SPECIFY		40ml Vials HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		CLIENT FAX		SOLID OR SEMISOLID		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org				LIQUID (Drinking Water) or WASTE WATER (Indicate)		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		QUICK	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924						AQUEOUS (WATER)		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		VERBAL	
COMPANY CONTRACTING THIS WORK (If Non-Boiler)						COMPOSITE (C) OR GRAB (G) INDICATE		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		# OF COOLERS	
SAMPLE IDENTIFICATION						OTHER SPECIFY		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		REMARKS	
DATE	TIME							Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0606	Room 422 bathroom right inside classroom door				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0606	Room 422 sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0607	Room 424 sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0607	Room 476 bathroom sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0610	Room 475 sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0611	Room 465 sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0612	Water fountain across from 464				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0612	Resnick Boy's bathroom left sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0613	Resnick Boy's bathroom right sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0613	Resnick Girl's bathroom left sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0614	Resnick GYM water fountain (460)				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0614	Resnick Girl's bathroom right sink				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
9/24/2016	0640	Bathroom sink next to 498				G		Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE) <i>Cheryl</i>		COMPANY oubooces		DATE 9/24/16		TIME 1048		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		TIME	
SAMPLED BY: (SIGNATURE) <i>Naureen B. Dekey</i>		COMPANY oubooces		DATE 9/24/16		TIME 1000		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		TIME	
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>A. Mendez</i>		COMPANY ETL		DATE 9/24/16		TIME 1048		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		COMPANY DATE		RECEIVED BY: (SIGNATURE)		TIME	

LABORATORY REMARKS: ICE (Y/N) PH _____ CL2 _____ Reviewed by _____

IR #3

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-111165-1
SDG Number: Emanuel Axelrod Education Center

Login Number: 111165

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.2 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling. AE 10/3/16
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	