

CAROLINE CALDERONE BAISLEY
DIRECTOR OF HEALTH



10/12 FWA DAN WATSON

MICHAEL LONG, Director
DIVISION OF ENVIRONMENTAL SERVICES
DOUGLAS SERAFIN, Laboratory
DEBORAH TRAVERS, DIRECTOR
DIVISION OF FAMILY HEALTH
ROBIN CLARK-SMITH, Director
SPECIAL CLINICAL SERVICES

DEPARTMENT OF HEALTH

Dr. Toni Jones
Parkway School
Havemeyer Bldg.
290 Greenwich Ave.
Greenwich, CT 06830-6521

RECEIVED

OCT 12 2020

BOE- FACILITIES

October 08, 2020

Dear Dr. Toni Jones,

This letter is to advise you that based upon the results of the most recent water tests collected on 8/17/2020 from your public well that your water is in compliance and meets the standards set by the Town of Greenwich and the State of Connecticut. Please contact this Department at 203-987-1001 if you have any questions.

Test Performed	Acceptable Results	Your Results
Total Coliform	Absent	Absent
E-Coli	Absent	Absent
pH	Between 6.4 – 10.0	6.92
Color Units	Less than 15 (Not to exceed 30)	5
Turbidity	Less than 5 (Not to exceed 10)	0.39
Odor	Less than 2	0
Nitrate (mg/l)	Less than 10.0 mg/l	5.3
Nitrite (mg/l)	Less than 1.0 mg/l	0.024
Sodium (mg/l)	Recommended below 100 mg/l	36.8

Division of Environmental Services