



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 21-04 McIntosh School Window Replacement Project

DATE: November 6, 2020

RE: **ADDENDUM NO. 2**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 2nd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing



ADDENDUM TWO

Project No.: **21-04**

Date: **November 6, 2020**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **WINDOW REPLACEMENT PROJECT AT
MCINTOSH ELEMENTARY SCHOOL FOR
ROCKFORD PUBLIC SCHOOLS
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, THURSDAY, NOVEMBER 12, 2020**


From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Scott R. Johnson, AIA, LEED AP

This Addendum consists of:
Pages 1 thru 2.

NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

CHANGES to the DRAWINGS

1. DRAWING A106

- 1.1.** Window W16 – The louver called for in this window under the original bid documents is required. The boiler system uses this as combustion air. Therefore, the Contractor shall provide and install the new louver specified on the drawing and reconnect it up to the existing ductwork.
- 1.2.** Window W15 – As changed per Addendum One, the louver in this window is not required.

END ADDENDUM NUMBER 2