

October, 2020

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The two larger ductless split A/C units for the data room at Amity High School were installed by the district building maintainers.
- The bleachers for field three have been installed.
- Preventive maintenance work on snow removal equipment was completed by our building maintainer (oil changes, spark plugs, carb cleaning etc.).
- Many classrooms were rearranged by both custodial and maintenance staffs to allow the maximum number of desks at proper distancing protocols. This involved not only moving out excess furniture, but in certain instances needing countertops and cubicle style desks taken apart and removed and electrical lines and outlets removed and capped off.
- UI/FCE successfully completed a test of the micro grid on 10/24/2020.

Projects in process:

- The scoreboard for field three is in progress.
- Winter preventive maintenance work on the boilers has been started by F+F Mechanical.
- Our building maintainer is working with the technology students and teacher to guide them in building custom partitions for their computer workstations.
- Amity High School dishwasher is being repaired.
- Looking at the District's storage needs and options for the modular buildings at both middle schools.
- UI found a bad metering transformer on one of the power poles at Amity High School, which was causing a fuse to pop and losing power to the field house.
- An acoustical study is being done in both middle schools to decide the best product and design to help the noise problems in the gymnasiums and cafeterias.

Outstanding issues to be addressed:

- Demolition of the modular building at Amity Middle School in Orange.