

School Name: **Stonebridge Elementary (SB)**  
 Date: **11/2/2018, 12/4/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result 11/2/2018 (ppb)	Lead Result 12/4/2018 (ppb)	Lead Result 30 Sec Flush 12/4/2018 (ppb)	Lead Result 3 Min Flush 12/4/2018 (ppb)
First	A103	Cafeteria	1	WC	ND	-	-	-
First	A103	Cafeteria	2	BF	ND	-	-	-
First	-	Dish Room	3	S	5.2	-	-	-
First	-	Dish Room	4	Spray	2.8	-	-	-
First	-	Nurse	5	S	7.7	-	-	-
First	-	Nurse Restroom	6	S	17.4	-	-	-
First	-	Hallway	7	WC	ND	-	-	-
First	-	Hallway	8	BF	ND	-	-	-
First	A124	Special Ed	9	S	12.1	-	-	-
First	A119	Special Ed	10	S	21.2	3.6	0.19	0.19
First	A119	Special Ed Bathroom	11	S	10.6	-	-	-
First	A112	Classroom - Northeast Corner	12	S	79.7	6.7	1.3	0.3
First	A112	Classroom - East Middle	13	S	171	7.8	0.63	0.3
First	A112	Classroom- Southeast	14	S	121	41	1.5	0.57
First	A112	Classroom- Southeast	15	S	42.9	75.7	1.9	0.41
First	A112	Classroom- South Middle	16	S	94.1	109	1.6	0.38
First	A112	Classroom- Southwest	17	S	153	30.5	1.2	0.37
First	A113	Classroom	18	S	9	-	-	-
First	A114	Classroom-Southeast	19	S	12.4	-	-	-
First	A114	Classroom-South Middle	20	S	25.5	15.5	1.2	0.21
First	A114	Classroom-Southwest	21	S	22.7	29.2	0.15	0.13
First	A114	Classroom-West	22	S	9.2	-	-	-
First	-	Hallway	23	WC	ND	-	-	-
First	B126	Classroom	24	S	33.8	15.8	0.74	0.21
First	B127	Classroom	25	DF	16.8	-	-	-
First	B128	Classroom	26	DF	11.5	-	-	-
First	B128	Classroom	27	S	10.7	-	-	-
First	B129	Classroom	28	S	7.7	-	-	-
First	B101	Classroom	29	DF	4	-	-	-
First	B101	Classroom	30	S	3.8	-	-	-
First	B102	Classroom	31	DF	6.9	-	-	-
First	B102	Classroom	32	S	8.7	-	-	-
First	B103	Classroom	33	DF	10.5	-	-	-
First	B103	Classroom	34	S	9.4	-	-	-
First	B104	Classroom	35	S	6.4	-	-	-
First	B105	Classroom	36	S	30.7	3.2	0.71	0.74
First	B106	Classroom	37	DF	7.8	-	-	-
First	B106	Classroom	38	S	7	-	-	-
First	B108	Classroom	39	DF	11.1	-	-	-
First	B108	Classroom	40	S	12.2	-	-	-
First	B110	Classroom	41	DF	7.4	-	-	-
First	B110	Classroom	42	S	6.4	-	-	-
First	B111	Classroom	43	DF	16.7	-	-	-
First	B112	Classroom	44	DF	5.8	-	-	-
First	B112	Classroom	45	S	4.2	-	-	-
First	B113	Classroom	46	DF	7.7	-	-	-
First	B113	Classroom	47	S	4.6	-	-	-
First	B118	Classroom - Storage	48	S	48.5	3.8	1.4	1.1
First	B118	Classroom	49	S	15.8	-	-	-
First	B120	Classroom	50	DF	20.4	12.5	9.5	5.5
First	B120	Classroom	51	S	20.6	8.8	14.9	0.66
First	B121	Classroom	52	S	9.8	-	-	-
First	B122	Classroom-Storage	53	S	16	-	-	-
First	B135	Classroom	54	DF	9.8	-	-	-
First	B135	Classroom	55	S	7.9	-	-	-
First	B136	Classroom	56	S	8	-	-	-
First	B137	Classroom	57	DF	8.8	-	-	-
First	B137	Classroom	58	S	30.8	3.6	1.3	0.45
First	B138	Classroom	59	DF	13.4	-	-	-
First	B138	Classroom	60	S	20.1	4.6	4.8	0.48
First	-	Kitchen	61	Spray	15	-	-	-
First	-	Kitchen - South	62	S	2.7	-	-	-
First	-	Kitchen - Northwest	63	S	4.1	-	-	-
First	-	Kitchen -North	64	S	5	-	-	-
First	A127	Teacher Lounge	65	S	-	1.7	-	-

# Stonebridge Elementary

## Lead in Drinking Water

### Project #19054

