

School Name: **Brookview Elementary (BV)**
 Date: **5/4/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First Floor	410	Kitchen - East Side of Counter	1	S	ND
First Floor	410	Kitchen - West Side of Counter	2	S	ND
First Floor	410	Kitchen - North Side of Counter	3	S	ND
First Floor	410	Kitchen - Kettle	4	K	ND
First Floor	410	Kitchen - North	5	S	ND
First Floor	410	Dishroom - Spray	6	S	ND
First Floor	410	Dishroom - East	7	S	2.1
First Floor	410	Dishroom - West	8	S	2.9
First Floor	420	Cafeteria - East	9	WC	ND
First Floor	420	Cafeteria - West	10	WC	ND
First Floor	420	Cafeteria - Bottle	11	BF	ND
First Floor	125	Staff Lounge	12	S	ND
First Floor	N/A	Hallway Near Gym - West	13	WC	ND
First Floor	N/A	Hallway Near Gym - East	14	WC	ND
First Floor	N/A	Hallway Near Gym - Bottle	15	BF	ND
First Floor	502	Classroom	16	DF	2.1
First Floor	502	Classroom	17	S	ND
First Floor	504	Classroom	18	DF	ND
First Floor	504	Classroom	19	S	ND
First Floor	506	Classroom	20	DF	ND
First Floor	506	Classroom	21	S	ND
First Floor	508	Classroom	22	DF	ND
First Floor	508	Classroom	23	S	ND
First Floor	507	Classroom	24	DF	ND
First Floor	507	Classroom	25	S	ND
First Floor	505	Classroom	26	DF	ND
First Floor	505	Classroom	27	S	ND
First Floor	503	Classroom	28	DF	ND
First Floor	503	Classroom	29	S	ND
First Floor	501	Classroom	30	DF	ND
First Floor	501	Classroom	31	S	ND
First Floor	N/A	500 Hallway - West	32	WC	ND
First Floor	N/A	500 Hallway - East	33	WC	ND
First Floor	N/A	500 Hallway - Bottle	34	BF	ND
First Floor	112	Art Room - North	35	S	ND
First Floor	112	Art Room - Northeast	36	S	ND
First Floor	112	Art Room - Southeast	37	S	ND
First Floor	112	Art Room - South	38	S	ND
First Floor	108	Health Office	39	S	ND
First Floor	N/A	300 Hallway - West	40	WC	ND
First Floor	N/A	300 Hallway - East	41	WC	ND
First Floor	N/A	300 Hallway - Bottle	42	BF	ND
First Floor	301	Classroom	43	DF	2.3
First Floor	301	Classroom	44	S	1.4
First Floor	303	Classroom	45	DF	ND
First Floor	303	Classroom	46	S	ND
First Floor	305	Classroom	47	DF	ND
First Floor	305	Classroom	48	S	ND
First Floor	306	Classroom	49	DF	2.1
First Floor	306	Classroom	50	S	ND
First Floor	304	Classroom	51	DF	2.2
First Floor	304	Classroom	52	S	ND
First Floor	302	Classroom	53	DF	2.4
First Floor	302	Classroom	54	S	1.9

School Name: **Brookview Elementary (BV)**
 Date: **5/4/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First Floor	130	Classroom	55	S	ND
First Floor	N/A	200 Hallway - East	56	WC	ND
First Floor	N/A	200 Hallway - West	57	WC	ND
First Floor	N/A	200 Hallway - Bottle	58	BF	ND
First Floor	201	Classroom	59	DF	2.1
First Floor	201	Classroom	60	S	ND
First Floor	203	Classroom	61	DF	ND
First Floor	203	Classroom	62	S	ND
First Floor	205	Classroom	63	DF	2.1
First Floor	205	Classroom	64	S	ND
First Floor	206	Classroom	65	DF	ND
First Floor	206	Classroom	66	S	ND
First Floor	204	Classroom	67	DF	ND
First Floor	204	Classroom	68	S	ND
First Floor	210	Classroom	69	S	3.1
First Floor	121	Classroom	70	S	ND
First Floor	117	Classroom	71	S	ND
First Floor	118	Classroom	72	S	2.3
First Floor	202	Classroom	73	DF	2
First Floor	202	Classroom	74	S	ND

