

School Name: **Stonebridge Elementary (SB)**Date: **11/2/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	A103	Cafeteria	1	WC	ND
First	A103	Cafeteria	2	BF	ND
First	-	Dish Room	3	S	5.2
First	-	Dish Room	4	Spray	2.8
First	-	Nurse	5	S	7.7
First	-	Nurse Restroom	6	S	17.4
First	-	Hallway	7	WC	ND
First	-	Hallway	8	BF	ND
First	A124	Special Ed	9	S	12.1
First	A119	Special Ed	10	S	21.2
First	A119	Special Ed Bathroom	11	S	10.6
First	A112	Classroom - Northeast Corner	12	S	79.7
First	A112	Classroom - East Middle	13	S	171
First	A112	Classroom- Southeast	14	S	121
First	A112	Classroom- Southeast	15	S	42.9
First	A112	Classroom- South Middle	16	S	94.1
First	A112	Classroom- Southwest	17	S	153
First	A113	Classroom	18	S	9
First	A114	Classroom-Southeast	19	S	12.4
First	A114	Classroom-South Middle	20	S	25.5
First	A114	Classroom-Southwest	21	S	22.7
First	A114	Classroom-West	22	S	9.2
First	-	Hallway	23	WC	ND
First	B126	Classroom	24	S	33.8
First	B127	Classroom	25	DF	16.8
First	B128	Classroom	26	DF	11.5
First	B128	Classroom	27	S	10.7
First	B129	Classroom	28	S	7.7
First	B101	Classroom	29	DF	4
First	B101	Classroom	30	S	3.8
First	B102	Classroom	31	DF	6.9
First	B102	Classroom	32	S	8.7
First	B103	Classroom	33	DF	10.5
First	B103	Classroom	34	S	9.4
First	B104	Classroom	35	S	6.4
First	B105	Classroom	36	S	30.7
First	B106	Classroom	37	DF	7.8
First	B106	Classroom	38	S	7
First	B108	Classroom	39	DF	11.1
First	B108	Classroom	40	S	12.2
First	B110	Classroom	41	DF	7.4
First	B110	Classroom	42	S	6.4
First	B111	Classroom	43	DF	16.7
First	B112	Classroom	44	DF	5.8
First	B112	Classroom	45	S	4.2

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	B113	Classroom	46	DF	7.7
First	B113	Classroom	47	S	4.6
First	B118	Classroom - Storage	48	S	48.5
First	B118	Classroom	49	S	15.8
First	B120	Classroom	50	DF	20.4
First	B120	Classroom	51	S	20.6
First	B121	Classroom	52	S	9.8
First	B122	Classroom-Storage	53	S	16
First	B135	Classroom	54	DF	9.8
First	B135	Classroom	55	S	7.9
First	B136	Classroom	56	S	8
First	B137	Classroom	57	DF	8.8
First	B137	Classroom	58	S	30.8
First	B138	Classroom	59	DF	13.4
First	B138	Classroom	60	S	20.1
First	-	Kitchen	61	Spray	15
First	-	Kitchen - South	62	S	2.7
First	-	Kitchen - Northwest	63	S	4.1
First	-	Kitchen -North	64	S	5

Stonebridge Elementary Lead in Drinking Water Project #19054

First Draw Sampling (Nov 2018)

- ◆ Lead < 2 ppb
- ◆ 2 ppb <=Lead<=20 ppb
- ◆ Lead > 20 ppb

Fixtures not working

