

School Name: Stillwater Area High School (SAHS)

Date: 11/2/2018

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	-	Kitchen - West Wall	1	S	3.4
First	-	Kitchen - West Wall	2	Spray	4.7
First	-	Kitchen	3	K	9.3
First	-	Kitchen - Southeast Wall	4	S	1.6
First	-	Kitchen - Southeast Wall	5	Spray	ND
First	-	Kitchen - Southeast (3 Basin)	6	S	4.2
First	-	Kitchen - Southeast (3 Basin)	7	S	5.2
First	-	Kitchen - Southeast (3 Basin)	8	Spray	ND
First	-	Kitchen - Northeast	9	Spray	ND
First	-	Kitchen - Northeast	10	Spray	2.6
First	-	Kitchen - Northeast	11	Spray	ND
First	-	Hall by Gym Entrance	12	BF	ND
First	-	Hall by Gym Entrance	13	WC	ND
First	-	Hall by Gym Entrance	14	WC	ND
First	-	Hall by Cafeteria Bathrooms	15	WC	ND
First	-	Hall by Cafeteria Bathrooms	16	WC	ND
First	-	Pony Market - Center	17	S	ND
First	-	Pony Market (3 Basin)	18	S	1.7
First	-	Pony Market (3 Basin)	19	S	ND
First	-	Pony Market (3 Basin)	20	Spray	1.5
First	-	Hall by Room E116	21	WC	ND
First	-	Hall by Room E116	22	WC	ND
First	E100	White Pony Center	23	S	1.8
First	-	Hall by Room E102	24	BF	ND
First	-	Hall by Room E102	25	WC	ND
First	-	Hall by Room E102	26	WC	ND
First	E101	Guidance Room	27	S	2.6
First	E121	Classroom	28	S	3
First	-	Hally by Room E130	29	BF	ND
First	-	Hall by Room E130	30	WC	ND
First	-	Hall by Room E130	31	WC	ND
First	D129	Classroom	32	S	8.8
First	D127	Classroom	33	S	ND
First	D125	Classroom - East	34	S	2.7
First	D125	Classroom -West	35	S	2.3
First	D109	Classroom	36	S	ND
First	D124	Classroom	37	S	1.8
First	D100	Main Office	38	S	1.7
First	D101	Copy Room	39	S	7.2
First	D103	Nurse	40	S	6
First	D103	Nurse - Bathroom	41	S	6.1
First	D103	Nurse	42	Refrigerator	1.3
First	D136	Gray Pony Center	43	S	1.1
First	-	Hall by Womens Bath - Near C120	44	BF	ND
First	-	Hall by Womens Bath - Near C120	45	WC	ND
First	-	Hall by Womens Bath - Near C120	46	WC	ND
First	-	Hall by Mens Bath - Near C120	47	BF	ND
First	-	Hall by Mens Bath - Near C120	48	WC	ND
First	-	Hall by Mens Bath - Near C120	49	WC	ND
First	-	Hall by Room C118	50	BF	ND
First	-	Hall by Room C118	51	WC	ND
First	-	Hall by Room C118	52	WC	1.6
First	C100	Black Pony Center	53	S	2.5
First	-	Hall by Room C102	54	WC	ND

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	-	Hall by Room C102	55	WC	ND
First	B108	Music	56	S	1.6
First	B113	Music	57	S	7
First	B115	Music	58	BF	1.2
First	B115	Music	59	WC	1.3
First	B117	Music	60	S	4.2
First	B120	Tech Ed	61	WC	1.5
First	-	Auditorium Hall - East	62	WC	ND
First	-	Auditorium Hall - East	63	WC	ND
First	-	Auditorium Hall - West	64	WC	1.5
First	-	Auditorium Hall - West	65	WC	ND
First	-	Kitchen Breakroom	66	S	5.6
First	G113	Classroom	67	S	ND
First	G115	Classroom	68	S	2
First	G117	Athletic Trainer	69	Tubs	ND
First	G117	Athletic Trainer	70	S	1.1
First	G117	Athletic Trainer	71	Spray	1.2
First	G117	Athletic Trainer	72	Ice	ND
Second	-	Hall by Room C202	73	WC	ND
Second	-	Hall by Room C214	74	WC	1.6
Second	C213	Classroom	75	S	3.5
Second	C213	Classroom	76	BF	ND
Second	-	Hall by Room C230	77	WC	ND
Second	-	Hall by Room C230	78	BF	ND
Second	-	Hall by Room C230	79	WC	ND
Second	-	Hall by MRR	80	BF	ND
Second	-	Hall by MRR	81	WC	ND
Second	D200	Red Pony Center	82	S	5.2
Second	D214	Media Center	83	S	22
Second	-	Hall by Room E215	84	WC	1.1
Second	E213	Classroom	85	S	4.7
Second	E213	Classroom	86	BF	ND
Second	-	Hall by Room E230	87	WC	ND
Second	-	Hall by Room E230	88	BF	ND
Second	-	Hall by Room E230	89	WC	ND
First	F100	Custodial Breakroom	90	S	1.4
First	G105	Locker Room	91	WC	4.2
First	G107	Locker Room	92	WC	6
First	-	Hall by Gym 2	93	WC	ND
First	-	Hall by Gym 2	94	BF	ND
First	-	Hall by Gym 2	95	WC	ND
First	G109	Locker Room	96	WC	2.9
First	G111	Locker Room	97	WC	4.1
First	-	Hall by Gym 4	98	WC	ND
First	-	Hall by Gym 4	99	BF	ND
First	-	Hall by Gym 4	100	WC	ND
First	G119	Gymnastics	101	BF	ND
First	G119	Gymnastics	102	WC	ND
First	G119	Gymnastics	103	WC	ND
First	G120	PAC 6	104	BF	ND
First	G120	PAC 6	105	WC	ND
First	G120	PAC 6	106	WC	ND
First	G120	PAC 7	107	BF	ND
First	G120	PAC 7	108	WC	ND
First	G120	PAC 7	109	WC	ND
First	-	PAC Hall by Womens Bath	110	BF	ND
First	-	PAC Hall by Womens Bath	111	WC	ND

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	-	PAC Hall by Womens Bath	112	WC	ND
First	-	PAC Hall by Mens Bath	113	BF	ND
First	-	PAC Hall by Mens Bath	114	WC	ND
First	-	PAC Hall by Mens Bath	115	WC	ND
First	-	Concessions	116	S	ND
First	-	Concessions	117	Spray	ND
First	-	Back Concessions	118	S	ND
First	-	Back Concessions	119	S	ND
Second	-	PAC Track	120	BF	ND
Second	-	PAC Track	121	WC	ND
Second	-	PAC Track	122	WC	ND
Second	G203	Weight Room	123	BF	ND
Second	G203	Weight Room	124	WC	ND
Second	G203	Weight Room	125	WC	ND
Second	G201	Cardio Room	126	BF	ND
Second	G201	Cardio Room	127	WC	ND
Second	G201	Cardio Room	128	WC	ND

Stillwater Area High School


First Floor

Lead in Drinking Water

Project #19054

First Draw Sampling (Nov 2018)

- ◆ Lead < 2 ppb
- ◆ 2 ppb <= Lead <= 20 ppb
- ◆ Lead > 20 ppb




Science lab stations and art room sink faucets were not tested; District posted signage on such fixtures stating "water not for drinking"

Stillwater Area High School
 Second Floor
 Lead in Drinking Water
 Project #19054


First Draw Sampling (Nov 2018)

- ◆ Lead < 2 ppb
- ◆ 2 ppb <=Lead<=20 ppb
- ◆ Lead > 20 ppb



Science lab stations and art room sink faucets were not tested; District posted signage on such fixtures stating "water not for drinking"

Stillwater Area High School
Second Floor: Pony Activity Center
Lead in Drinking Water
Project #19054



Science lab stations and art room sink faucets were not tested; District posted signage on such fixtures stating "water not for drinking"