

School Name: **Early Childhood Family Center (ECFC)**Date: **11/2/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	165	Therapy 9	1	S	2.3
First	166	Therapy 8	2	S	3
First	167	Therapy 7	3	S	56.7
First	168	Therapy 6	4	S	1.6
First	169	Therapy 5	5	S	1.7
First	171	Kitchenette	6	S	1.4
First	148	Classroom -Upper Sink	7	S	1.3
First	148	Classroom -Lower Sink	8	S	ND
First	147	Classroom-Upper Sink	9	S	1.4
First	147	Classroom-Lower Sink	10	S	1.6
First	142	Classroom-Upper Sink	11	S	1.1
First	142	Classroom-Lower Sink	12	S	1.7
First	153	Classroom-Upper Sink	13	S	1.3
First	153	Classroom-Lower Sink	14	S	ND
First	160	Classroom-Upper Sink	15	S	ND
First	160	Classroom-Lower Sink	16	S	1.3
First	162	Classroom-Upper Sink	17	S	1
First	162	Classroom-Lower Sink	18	S	1.4
First	180	Classroom-Upper Sink	19	S	ND
First	180	Classroom-Lower Sink	20	S	1.2
First	185	Classroom-Upper Sink	21	S	1.3
First	185	Classroom-Lower Sink	22	S	ND
First	186	Classroom-Upper Sink	23	S	ND
First	186	Classroom-Lower Sink	24	S	ND
First	191	Classroom-Upper Sink	25	S	4
First	191	Classroom-Lower Sink	26	S	2.2
First	192	Classroom	27	S	3.3
First	193	Classroom	28	S	1.9
First	240	Nurse	29	S	1.7
First	238	Lactation	30	S	ND
First	236	Break Room	31	S	ND
First	236	Break Room-East	32	WC	ND
First	236	Break Room-West	33	WC	ND
First	-	Hallway	34	BF	ND
First	-	Hallway-Upper Water Cooler	35	WC	ND
First	-	Hallway-Lower Water Cooler	36	WC	ND
First	-	Hallway	37	BF	ND
First	-	Hallway-Upper Water Cooler	38	WC	ND
First	-	Hallway-Lower Water Cooler	39	WC	ND
First	120	Classroom	40	S	1.2
First	-	Hallway	41	BF	ND
First	-	Hallway-Upper Water Cooler	42	WC	ND
First	-	Hallway-Lower Water Cooler	43	WC	ND

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	121	Classroom -Upper Sink	44	S	ND
First	121	Classroom -Lower Sink	45	S	ND
First	125	Classroom -Upper Sink	46	S	ND
First	125	Classroom -Lower Sink	47	S	ND
First	126	Classroom -Upper Sink	48	S	ND
First	126	Classroom -Lower Sink	49	S	ND
First	128	Classroom -Upper Sink	50	S	1.2
First	128	Classroom -Lower Sink	51	S	ND
First	129	Classroom -Upper Sink	52	S	1.6
First	129	Classroom -Lower Sink	53	S	ND
First	131	Classroom -Upper Sink	54	S	ND
First	131	Classroom -Lower Sink	55	S	1
First	140	Parent Classroom	56	S	2.7
First	141	Parent Classroom	57	S	1.3

Early Childhood Family Center
 Lead in Drinking Water
 Project #19054



First Draw Sampling (Nov 2018)

- ◆ Lead < 2 ppb
- ◆ 2 ppb <=Lead<= 20 ppb
- ◆ Lead > 20 ppb

