

School Name: **Central Services Building (CSB)**

Date: **11/2/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	-	Break Area	1	S	11.1
First	127	Suites	2	S	6.4
First	132	Lounge	3	S	2.4
First	-	Hall	4	WC	5.3

Central Services Building
 Lead in Drinking Water
 Project #19054

First Draw Sampling (Nov 2018)

- ◆ Lead < 2 ppb
- ◆ 2 ppb <= Lead <=20 ppb
- ◆ Lead > 20 ppb

