

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Gorham Elementary School	10/9/2020	63	55	8	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
170.3-135	Room 105	Sink	15.4
170.3-141	Kitchen Area Large Triple Bay	Sink	18.9
170.3-151L	Room 215	Sink	17.2
170.3-151R	Room 215	Sink	51.6
170.3-157	Room 140 Blake Wing	Sink	59.7
170.3-162	Room 132 Home Living Center FLES	Sink	35.6
170.3-180	Room 138 Blank Wing	Sink	17.6
170.3-182	Room 118 FLES	Sink	15.2



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Report Number: 20-10-02432
 Received Date: 10/15/2020
 Reported Date: 11/06/2020
 Sampled By: Andrew Theal
 Tech Certification #:

Project/Test Address: 20-20L-170.3; Gorham Elementary; 2705 State Route 245; Stawley, NY 14561

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02432-001	170.3-132	10/09/2020	RM 101B NURSES OFFICE	1.24	11/04/2020	
20-10-02432-002	170.3-133A	10/09/2020	CORRIDOR B/T 101B AND 102	<1.00	11/04/2020	
20-10-02432-003	170.3-133B	10/09/2020	CORRIDOR B/T 101B AND 103	<1.00	11/04/2020	
20-10-02432-004	170.3-134	10/09/2020	RM 103	2.39	11/04/2020	
20-10-02432-005	170.3-135	10/09/2020	RM 105	15.4	11/04/2020	
20-10-02432-006	170.3-137A	10/09/2020	CORRIDOR B/T GIRLS AND BOYS LOCKER RM	<1.00	11/04/2020	
20-10-02432-007	170.3-137B	10/09/2020	CORRIDOR B/T GIRLS AND BOYS LOCKER RM	<1.00	11/04/2020	
20-10-02432-008	170.3-138	10/09/2020	RM 111	2.20	11/04/2020	
20-10-02432-009	170.3-139	10/09/2020	RM 127 CONFERENCE ROOM	3.95	11/04/2020	
20-10-02432-010	170.3-140	10/09/2020	KITCHEN AREA PREP SINK	12.6	11/04/2020	
20-10-02432-011	170.3-141	10/09/2020	KITCHEN AREA LARGE TRIPLE BAY	18.9	11/04/2020	
20-10-02432-012	170.3-142A	10/09/2020	CORRIDOR OUTSIDE RM 120	<1.00	11/04/2020	
20-10-02432-013	170.3-142B	10/09/2020	CORRIDOR OUTSIDE RM 120	<1.00	11/04/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 20-20L-170.3; Gorham Elementary; 2705 State Route
 245; Stawley, NY 14561

Report Number: 20-10-02432

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02432-014	170.3-142C	10/09/2020	CORRIDOR OUTSIDE RM 120	<1.00	11/04/2020	
20-10-02432-015	170.3-143L	10/09/2020	MULTI-PURPOSE RM	1.88	11/04/2020	
20-10-02432-016	170.3-143R	10/09/2020	MULTI-PURPOSE RM	3.41	11/04/2020	
20-10-02432-017	170.3-144A	10/09/2020	OUTSIDE LIBRARY 2ND FLOOR	<1.00	11/04/2020	
20-10-02432-018	170.3-144B	10/09/2020	OUTSIDE LIBRARY 2ND FLOOR	<1.00	11/04/2020	
20-10-02432-019	170.3-145	10/09/2020	RM 204	2.16	11/04/2020	
20-10-02432-020	170.3-146	10/09/2020	RM 206	6.92	11/04/2020	
20-10-02432-021	170.3-147	10/09/2020	RM 207	2.97	11/04/2020	
20-10-02432-022	170.3-148	10/09/2020	RM 210	1.86	11/04/2020	
20-10-02432-023	170.3-149	10/09/2020	RM 212	1.23	11/04/2020	
20-10-02432-024	170.3-150	10/09/2020	RM 214	2.16	11/04/2020	
20-10-02432-025	170.3-151L	10/09/2020	RM 215	17.2	11/04/2020	
20-10-02432-026	170.3-151R	10/09/2020	RM 215	51.6	11/04/2020	
20-10-02432-027	170.3-152	10/09/2020	RM 216	3.27	11/04/2020	
20-10-02432-028	170.3-153L	10/09/2020	CORRIDOR B/T RM 216 AND 217	<1.00	11/04/2020	
20-10-02432-029	170.3-153R	10/09/2020	CORRIDOR B/T RM 216 AND 217	<1.00	11/04/2020	
20-10-02432-030	170.3-154	10/09/2020	RM 217	1.75	11/04/2020	
20-10-02432-031	170.3-155	10/09/2020	RM 218	1.50	11/04/2020	
20-10-02432-032	170.3-156	10/09/2020	RM 142 BLAKE WING	1.74	11/04/2020	
20-10-02432-033	170.3-157	10/09/2020	RM 140 BLAKE WING	69.7	10/30/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-02432

Project/Test Address: 20-20L-170.3; Gorham Elementary; 2705 State Route
245; Stawley, NY 14561

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02432-034	170.3-158	10/09/2020	RM 138 BLAKE WING	2.32	11/04/2020	
20-10-02432-035	170.3-159	10/09/2020	RM 135 BLAKE WING	1.72	11/04/2020	
20-10-02432-036	170.3-160	10/09/2020	RM 133 BLANK WING	1.59	11/04/2020	
20-10-02432-037	170.3-161	10/09/2020	RM 115 FACULTY LOUNGE	1.69	11/04/2020	
20-10-02432-038	170.3-162	10/09/2020	RM 132 HOME LIVING CENTER FLES	85.6	11/05/2020	
20-10-02432-039	170.3-163	10/09/2020	CORRIDOR OUTSIDE GYM FLES	1.39	11/05/2020	
20-10-02432-040	170.3-164	10/09/2020	RM 118 FLES	4.85	11/05/2020	
20-10-02432-041	170.3-165	10/09/2020	RM 119 FLES	7.04	11/05/2020	
20-10-02432-042	170.3-166	10/09/2020	RM 122 FLES	4.63	11/05/2020	
20-10-02432-043	170.3-167	10/09/2020	CORRIDOR B/T BRMS 11 AND 113 FLES	1.12	11/05/2020	
20-10-02432-044	170.3-168	10/09/2020	RM 110 FLES	5.31	11/05/2020	
20-10-02432-045	170.3-169	10/09/2020	RM 108 FLES	2.37	11/05/2020	
20-10-02432-046	170.3-170	10/09/2020	RM 106 FLES	2.18	11/05/2020	
20-10-02432-047	170.3-171	10/09/2020	RM 104 FLES	2.53	11/05/2020	
20-10-02432-048	170.3-173	10/09/2020	MAIN OFFICE BATHROOM	1.31	11/05/2020	
20-10-02432-049	170.3-174	10/09/2020	RM 101B NURSES OFFICE BATHROOM	3.16	11/05/2020	
20-10-02432-050	170.3-175	10/09/2020	RM 108 ART ROOM	7.36	11/05/2020	
20-10-02432-051	170.3-176	10/09/2020	RM 111	1.94	11/05/2020	
20-10-02432-052	170.3-177	10/09/2020	RM 133 BLAKE WING	1.14	11/05/2020	
20-10-02432-053	170.3-178	10/09/2020	RM 135 BLAKE WING	1.36	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 20-20L-170.3; Gorham Elementary; 2705 State Route
 245; Stawley, NY 14561

Report Number: 20-10-02432

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02432-054	170.3-179	10/09/2020	RM 138 BLAKE WING	2.48	11/05/2020	
20-10-02432-055	170.3-180	10/09/2020	RM 140 BLAKE WING	17.6	11/05/2020	
20-10-02432-056	170.3-181	10/09/2020	RM 142 BLAKE WING	1.35	11/05/2020	
20-10-02432-057	170.3-182	10/09/2020	RM 118 FLES	15.2	11/05/2020	
20-10-02432-058	170.3-184	10/09/2020	RM 106 FLES	8.19	11/05/2020	
20-10-02432-059	170.3-185	10/09/2020	RM 110 FLES	2.48	11/05/2020	
20-10-02432-060	170.3-186	10/09/2020	RM 122 FLES	3.36	11/05/2020	
20-10-02432-061	170.3-187	10/09/2020	RM 108 FLES	4.47	11/05/2020	
20-10-02432-062	170.3-188	10/09/2020	KITCHEN STAFF BATHROOM 124D GE	1.05	11/05/2020	
20-10-02432-063	170.3-189	10/09/2020	KITCHEN STAFF HAND SINK GE	3.00	11/05/2020	

Method: SM 3113B-2010
 Analyst: Jennalee Hertzler
 Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Middle/High School	10/9/2020	100	95	5	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
170.1-66	Room 137	Sink	26.1
170.1-88	Room 429 Home and Careers	Sink	49.9
170.1-91	Room 236 HS Kitchen Prep Sink	Sink	92.7
170.1-97	B/T Storage Room 302 and 304	Sink	52.0
170.1-103	Room 316 Library Office	Sink	18.2



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 20-10-02437

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 10/15/2020
 Reported Date: 11/09/2020
 Sampled By: Andrew Theal
 Tech Certification #:

Project/Test Address: 2020L-170.1; Marcus Whitman Middle/High School; 4100 Baldwin Rd;
 Rushville, NY 14544

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-001	170.1-32A	10/09/2020	CORRIDOR OUTSIDE ROOM 114 GYM	<1.00	11/05/2020	
20-10-02437-002	170.1-32B	10/09/2020	CORRIDOR OUTSIDE RM 114 GYM	<1.00	11/05/2020	
20-10-02437-003	170.1-33	10/09/2020	CORRIDOR B/T RM 107 AND 109	<1.00	11/05/2020	
20-10-02437-004	170.1-34	10/09/2020	RM 105 TEACHER LOUNGE	<1.00	11/05/2020	
20-10-02437-005	170.1-35	10/09/2020	RM 104 KITCHEN DISHWASHING SINK	1.75	11/05/2020	
20-10-02437-006	170.1-36	10/09/2020	RM 103 HOME AND CAREERS	7.75	11/05/2020	
20-10-02437-007	170.1-37A	10/09/2020	CORRIDOR OUTSIDE RM 205	<1.00	11/05/2020	
20-10-02437-008	170.1-37B	10/09/2020	CORRIDOR OUTSIDE RM 205	<1.00	11/05/2020	
20-10-02437-009	170.1-38	10/09/2020	CORRIDOR OUTSIDE RM 313	<1.00	11/05/2020	
20-10-02437-010	170.1-39A	10/09/2020	CORRIDOR OUTSIDE RM 135	<1.00	11/05/2020	
20-10-02437-011	170.1-39B	10/09/2020	CORRIDOR OUTSIDE RM 135	<1.00	11/05/2020	
20-10-02437-012	170.4-46	10/09/2020	RM 134	1.15	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.1; Marcus WHitman Middle/High School;
 4100 Baldwin Rd; Rushville, NY 14544

Report Number: 20-10-02437

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-013	170.1-48	10/09/2020	RM 201	<1.00	11/05/2020	
20-10-02437-014	170.1-50	10/09/2020	RM 203	<1.00	11/05/2020	
20-10-02437-015	170.1-51	10/09/2020	RM 204	5.44	11/05/2020	
20-10-02437-016	170.1-52	10/09/2020	RM 313	<1.00	11/05/2020	
20-10-02437-017	170.1-53	10/09/2020	RM 315	<1.00	11/05/2020	
20-10-02437-018	170.1-54	10/09/2020	RM 317	1.82	11/05/2020	
20-10-02437-019	170.1-55	10/09/2020	RM 319	<1.00	11/05/2020	
20-10-02437-020	170.1-56	10/09/2020	RM 308	2.00	11/05/2020	
20-10-02437-021	170.1-57	10/09/2020	RM 306	<1.00	11/05/2020	
20-10-02437-022	170.1-58	10/09/2020	RM 310	1.72	11/05/2020	
20-10-02437-023	170.1-59	10/09/2020	RM 106	<1.00	11/05/2020	
20-10-02437-024	170.1-60	10/09/2020	RM 108	<1.00	11/05/2020	
20-10-02437-025	170.1-61	10/09/2020	RM 110	3.27	11/05/2020	
20-10-02437-026	170.1-62	10/09/2020	RM 128	5.05	11/05/2020	
20-10-02437-027	170.1-63	10/09/2020	RM 130	<1.00	11/05/2020	
20-10-02437-028	170.1-64	10/09/2020	RM 134	3.00	11/05/2020	
20-10-02437-029	170.1-65	10/09/2020	RM 132	1.17	11/05/2020	
20-10-02437-030	170.1-66	10/09/2020	RM 137	26.1	11/05/2020	
20-10-02437-031	170.1-67	10/09/2020	RM 201	<1.00	11/05/2020	
20-10-02437-032	170.1-68	10/09/2020	RM 202	3.08	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.1; Marcus WHitman Middle/High School;
 4100 Baldwin Rd; Rushville, NY 14544

Report Number: 20-10-02437

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-033	170.1-69	10/09/2020	RM 203	<1.00	11/05/2020	
20-10-02437-034	170.1-70	10/09/2020	RM 204	4.28	11/05/2020	
20-10-02437-035	170.1-71	10/09/2020	RM 206	<1.00	11/05/2020	
20-10-02437-036	170.1-72	10/09/2020	RM 313	<1.00	11/05/2020	
20-10-02437-037	170.1-73	10/09/2020	RM 315	<1.00	11/05/2020	
20-10-02437-038	170.1-74	10/09/2020	RM 317	2.64	11/05/2020	
20-10-02437-039	170.1-75	10/09/2020	RM 319	<1.00	11/05/2020	
20-10-02437-040	170.1-76	10/09/2020	RM 308	<1.00	11/05/2020	
20-10-02437-041	170.1-77	10/09/2020	RM 306	<1.00	11/05/2020	
20-10-02437-042	170.1-78	10/09/2020	RM 310	<1.00	11/05/2020	
20-10-02437-043	170.1-79A	10/09/2020	CORRIDOR CORNER AT DISTRICT OFFICE	<1.00	11/05/2020	
20-10-02437-044	170.1-79B	10/09/2020	CORRIDOR CORNER AT DISTRICT OFFICE	<1.00	11/05/2020	
20-10-02437-045	170.1-80	10/09/2020	LAUNDRY ROOM	2.62	11/05/2020	
20-10-02437-046	170.1-81	10/09/2020	CORRIDOR OUTSIDE BOYS LOCKER ROOM	3.66	11/05/2020	
20-10-02437-047	170.1-82	10/09/2020	CORRIDOR BETWEEN LOBBY BATHROOMS	5.81	11/05/2020	
20-10-02437-048	170.1-83	10/09/2020	CORRIDOR OUTSIDE GIRLS LOCKER RM	1.45	11/05/2020	
20-10-02437-049	170.1-84	10/09/2020	HS OFFICE LOBBY AREA NEXT TO BRMS	11.7	11/05/2020	
20-10-02437-050	170.1-85	10/09/2020	RM 335 TEACHERS LOUNGE	6.06	11/05/2020	
20-10-02437-051	170.1-86A	10/09/2020	CORRIDOR B/T 323/324 BRMS BY TECH OFFICE	<1.00	11/05/2020	
20-10-02437-052	170.1-86B	10/09/2020	CORRIDOR B/T 323/324 BRMS BY TECH OFFICE	<1.00	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.1; Marcus WHitman Middle/High School;
 4100 Baldwin Rd; Rushville, NY 14544

Report Number: 20-10-02437

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-053	170.1-87A	10/09/2020	CORRIDOR B/T BRMS 400 WING	<1.00	11/05/2020	
20-10-02437-054	170.1-87B	10/09/2020	CORRIDOR B/T BRMS 400 WING	<1.00	11/05/2020	
20-10-02437-055	170.1-88	10/09/2020	RM 429 HOME AND CAREERS	49.9	11/05/2020	
20-10-02437-056	170.1-89	10/09/2020	RM 445 HS OFFICE	1.99	11/05/2020	
20-10-02437-057	170.1-90	10/09/2020	RM 231 HS CAFETERIA	3.11	11/05/2020	
20-10-02437-058	170.1-91	10/09/2020	RM 236 HS KITCHEN PREP SINK	92.7	11/05/2020	
20-10-02437-059	170.1-92	10/09/2020	DISTRICT OFFICE BREAK ROOM	1.08	11/05/2020	
20-10-02437-060	170.1-93	10/09/2020	NURSE OFFICE AREA	7.76	11/05/2020	
20-10-02437-061	170.1-94	10/09/2020	NURSES STORAGE ROOM AREA	7.06	11/05/2020	
20-10-02437-062	170.1-95	10/09/2020	GIRLS PE OFFICE BATHROOM	4.49	11/05/2020	
20-10-02437-063	170.1-97	10/09/2020	B/T STORAGE ROOM 302 AND 304	52.0	11/05/2020	
20-10-02437-064	170.1-101	10/09/2020	RM 210	122	11/05/2020	
20-10-02437-065	170.1-103	10/09/2020	RM 316 LIBRARY OFFICE	18.2	11/05/2020	
20-10-02437-066	170.1-104	10/09/2020	RM 446 HS BOE RM	2.42	11/05/2020	
20-10-02437-067	170.1-105	10/09/2020	RM 512 B/5 RM 511 AND 513	2.62	11/05/2020	
20-10-02437-068	170.1-106	10/09/2020	RM 600 MS TEACHER'S LOUNGE	3.74	11/05/2020	
20-10-02437-069	170.1-107	10/09/2020	CORRIDOR B/T BRMS 600 WING	<1.00	11/05/2020	
20-10-02437-070	170.1-108A	10/09/2020	CORRIDOR OUTSIDE RM 706 MS CAFETERIA	<1.00	11/05/2020	
20-10-02437-071	170.1-108B	10/09/2020	CORRIDOR OUTSIDE RM 706 MS CAFETERIA	<1.00	11/05/2020	
20-10-02437-072	170.1-108C	10/09/2020	CORRIDOR OUTSIDE RM 706 MS CAFETERIA	<1.00	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.1; Marcus WHitman Middle/High School;
 4100 Baldwin Rd; Rushville, NY 14544

Report Number: 20-10-02437

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-073	170.1-109	10/09/2020	MS KITCHEN PREP SINK	<1.00	11/05/2020	
20-10-02437-074	170.1-110	10/09/2020	CORRIDOR B/T BRMS 607 A AND B	1.61	11/05/2020	
20-10-02437-075	170.1-111	10/09/2020	MS OFFICE BREAK AREA	<1.00	11/05/2020	
20-10-02437-076	170.1-112A	10/09/2020	CORRIDOR OUTSIDE RM 021	<1.00	11/05/2020	
20-10-02437-077	170.1-112B	10/09/2020	CORRIDOR OUTSIDE RM 021	<1.00	11/05/2020	
20-10-02437-078	170.1-112C	10/09/2020	CORRIDOR OUTSIDE RM 021	<1.00	11/05/2020	
20-10-02437-079	170.1-113.1	10/09/2020	RM 021 HOME AND CAREERS	1.56	11/05/2020	
20-10-02437-080	170.1-113.2	10/09/2020	RM 021 HOME AND CAREERS	5.49	11/05/2020	
20-10-02437-081	170.1-113.3	10/09/2020	RM 021 HOME AND CAREERS	2.80	11/05/2020	
20-10-02437-082	170.1-113.4	10/09/2020	RM 021 HOME AND CAREERS	6.54	11/05/2020	
20-10-02437-083	170.1-114L	10/09/2020	CORRIDOR B/T BRMS MS BASEMENT	9.86	11/05/2020	
20-10-02437-084	170.1-114R	10/09/2020	CORRIDOR B/T BRMS MS BASEMENT	12.0	11/05/2020	
20-10-02437-085	170.1-115	10/09/2020	GHTFOOTE LOUNGE NEXT TO MS OFFICE	<1.00	11/05/2020	
20-10-02437-086	170.1-116	10/09/2020	RM 604 ECO	7.58	11/05/2020	
20-10-02437-087	170.1-117	10/09/2020	RM 606 ECO	5.98	11/05/2020	
20-10-02437-088	170.1-118	10/09/2020	RM 721	3.38	11/05/2020	
20-10-02437-089	170.1-119	10/09/2020	RM 719	<1.00	11/05/2020	
20-10-02437-090	170.1-120	10/09/2020	RM 718	1.62	11/05/2020	
20-10-02437-091	170.1-121	10/09/2020	RM 717	6.32	11/05/2020	
20-10-02437-092	170.1-122	10/09/2020	RM 715 LIBRARY OFFICE	<1.00	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.1; Marcus WHitman Middle/High School;
 4100 Baldwin Rd; Rushville, NY 14544

Report Number: 20-10-02437

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02437-093	170.1-123	10/09/2020	RM 714	<1.00	11/05/2020	
20-10-02437-094	170.1-124	10/09/2020	RM 713	1:11	11/05/2020	
20-10-02437-095	170.1-125	10/09/2020	RM 712	<1.00	11/05/2020	
20-10-02437-096	170.1-126	10/09/2020	RM 711	<1.00	11/05/2020	
20-10-02437-097	170.1-127	10/09/2020	RM 705	<1.00	11/05/2020	
20-10-02437-098	170.1-128	10/09/2020	RM 704	1.76	11/05/2020	
20-10-02437-099	170.1-129	10/09/2020	RM 703 KITCHENETTE	2.05	11/05/2020	
20-10-02437-100	170.1-131	10/09/2020	RM 019	<1.00	11/05/2020	

Method: SM 3113B-2010
 Analyst: Jennalee Hertzler
 Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Middlesex Valley Primary School	10/9/2020	34	33	1	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
170.2-4	Food Prep Area Kitchen Sink	Sink	34.7



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 20-10-02429

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 10/15/2020
 Reported Date: 11/06/2020
 Sampled By: Andrew Theal
 Tech Certification #:

Project/Test Address: 2020L-170.2; Middlesex Valley Primary; 149 NY-245; Rushville, NY 14544

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02429-001	170.2-2A	10/09/2020	CORRIDOR ACROSS FROM RM 143	<1.00	11/05/2020	
20-10-02429-002	170.2-2B	10/09/2020	CORRIDOR ACROSS FROM RM 143	<1.00	11/05/2020	
20-10-02429-003	170.2-3A	10/09/2020	CORRIDOR ACROSS FROM RM 112	<1.00	11/05/2020	
20-10-02429-004	170.2-3B	10/09/2020	CORRIDOR ACROSS FROM RM 112	<1.00	11/05/2020	
20-10-02429-005	170.2-4	10/09/2020	RM 113	1.27	11/05/2020	
20-10-02429-006	170.2-5.1	10/09/2020	FOOD PREP AREA KITCHEN SINKS	6.04	11/05/2020	
20-10-02429-007	170.2-5.2	10/09/2020	FOOD PREP AREA KITCHEN SINKS	3.74	11/05/2020	
20-10-02429-008	170.2-5.3	10/09/2020	FOOD PREP AREA KITCHEN SINKS	3.18	11/05/2020	
20-10-02429-009	170.2-5.4	10/09/2020	FOOD PREP AREA KITCHEN SINKS	34.7	11/05/2020	
20-10-02429-010	170.2-2.6	10/09/2020	FOOD PREP AREA HAND SINK	1.94	11/05/2020	
20-10-02429-011	170.2-2.7A	10/09/2020	CORRIDOR ACROSS FROM RM 208	<1.00	11/05/2020	
20-10-02429-012	170.2-2.7B	10/09/2020	CORRIDOR ACROSS FROM RM 208	<1.00	11/05/2020	
20-10-02429-013	170.2-8	10/09/2020	LIBRARY RM 219	8.62	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-170.2; Middlesex Valley Primary; 149 NY-245;
 Rushville, NY 14544

Report Number: 20-10-02429

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02429-014	170.2-9A	10/09/2020	CORRIDOR ACROSS FROM RM 205	<1.00	11/05/2020	
20-10-02429-015	170.2-9B	10/09/2020	CORRIDOR ACROSS FROM RM 205	<1.00	11/05/2020	
20-10-02429-016	170.2-10A	10/09/2020	CORRIDOR ACROSS FROM RM 111	<1.00	11/05/2020	
20-10-02429-017	170.2-10B	10/09/2020	CORRIDOR ACROSS FROM RM 111	<1.00	11/05/2020	
20-10-02429-018	170.2-11	10/09/2020	CORRIDOR ACROSS FROM RM 140	5.38	11/05/2020	
20-10-02429-019	170.2-12	10/09/2020	RM 107	2.65	11/05/2020	
20-10-02429-020	170.2-13	10/09/2020	RM 108 NURSES OFFICE	1.92	11/05/2020	
20-10-02429-021	170.2-14	10/09/2020	RM 100 C	4.76	11/05/2020	
20-10-02429-022	170.2-15	10/09/2020	RM 101	2.24	11/05/2020	
20-10-02429-023	170.2-16	10/09/2020	RM 101 A	2.32	11/05/2020	
20-10-02429-024	170.2-17	10/09/2020	RM 102	3.40	11/05/2020	
20-10-02429-025	170.2-18	10/09/2020	RM 102 A	3.48	11/05/2020	
20-10-02429-026	170.2-19	10/09/2020	RM 103 A	1.84	11/05/2020	
20-10-02429-027	170.2-20	10/09/2020	RM 104	2.35	11/05/2020	
20-10-02429-028	170.2-21	10/09/2020	RM 104 A	3.72	11/05/2020	
20-10-02429-029	170.2-22	10/09/2020	RM 105	1.08	11/05/2020	
20-10-02429-030	170.2-23	10/09/2020	RM 105 A	5.91	11/05/2020	
20-10-02429-031	170.2-25	10/09/2020	RM 153 TEACHERS BATHROOM	2.09	11/05/2020	
20-10-02429-032	170.2-26.1	10/09/2020	ART ROOM	1.73	11/05/2020	
20-10-02429-033	170.2-26.2	10/09/2020	ART ROOM	2.81	11/05/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-02429

Project/Test Address: 2020L-170.2; Middlesex Valley Primary; 149 NY-245;
Rushville, NY 14544

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-02429-034	170.2-31	10/09/2020	RM 123	7.48	11/05/2020	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion