

November, 2020

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- Tremco has completed a scan of all roof sections at Amity High; all sections that are currently under warranty as well as sections marked for restoration in the near future.
- UI replaced the bad metering transformer on the pole at Amity High.
- Sidewalk repairs were completed at AMSB in the rear of the building that were posing a trip hazard.
- UI/FCE successfully completed another test of the micro grid on 11/14/2020.
- The scoreboard for Field Three is complete.

Projects in process:

- Amity High School dishwasher is being repaired.
- Looking at the district's storage needs and options for the modular building in Bethany.
- An acoustical study is being done in both middle schools to decide the best product and design to help the noise problems in the gym and cafeterias.
- Preparations are underway to start the demolition of the Orange modular building.
- Dates for the walkway to the new bleachers on Field Three to be installed are being reviewed.
- At Amity High School the boiler hot water return line that runs underground from the boiler room to the Tech Ed side of the school developed a leak. F&F Mechanical is addressing the problem with our HVAC building maintainer.

Outstanding issues to be addressed: