

**ADDENDUM NO. 03**

Issued: February 17, 2021  
Project: Shawnee Mission School District  
2021 Roof Improvements  
Project No's: 20121.00  
Owner: Shawnee Mission School District  
8200 W. 71 St Street  
Shawnee Mission, Kansas 66204

Bidding Documents Issued: January 27,2021

This Addendum includes this 1 page and the following attachments: NONE

**BID DATE HAS BEEN CHANGED TO FEBRUARY 25, 2021 AT 2:30 PM.**  
VIRTUAL BID OPENING LINK WILL REMAIN UNCHANGED.

**GENERAL – BIDDER'S QUESTIONS**

- G1 **QUESTION: DO WE PAINT GAS LINES?**  
G1.1 Answer: Yes, all gas lines are to be painted.
- G2 **QUESTION: DO RTUS NEED TO REMAIN IN OPERATION DURING CONSTRUCTION??**  
G2.1 Answer: Yes, disconnect gas line at union. Provide and install flex gas connector during roofing project. After roofing project is complete remove flex connector and re-connect union, all dirt legs to be minimum 2" above finished roof surface.

**END OF ADDENDUM NO. 03**

