

Calvert Country School

2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting		School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
		Date	Floor #											
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	1	DF	Water fountain across from the gym	CO	5/16/2018	6:00:00 PM	5/17/2018	6:09:00 AM	5/18/2018	3.2	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	2	NO	Faucet in nurse room	CO	5/16/2018	6:00:00 PM	5/17/2018	6:07:00 AM	5/18/2018	1.1	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	3	TL	Faucet in office work room	CO	5/16/2018	6:00:00 PM	5/17/2018	6:08:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	4	KS	Left double faucet in kitchen	CO	5/16/2018	6:00:00 PM	5/17/2018	6:11:00 AM	5/18/2018	1.6	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	5	KS	Right double faucet in kitchen	CO	5/16/2018	6:00:00 PM	5/17/2018	6:11:00 AM	5/18/2018	3.3	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	6	KS	Single faucet in kitchen	CO	5/16/2018	6:00:00 PM	5/17/2018	6:11:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	7	CR	Faucet in room 19	CO	5/16/2018	6:00:00 PM	5/17/2018	6:12:00 AM	5/18/2018	2.5	No

Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	8	CR	Faucet in room 11	CO	5/16/2018	6:00:00 PM	5/17/2018	6:13:00 AM	5/18/2018	1.3	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	9	CR	Faucet in room 13	CO	5/16/2018	6:00:00 PM	5/17/2018	6:14:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	10	CR	Faucet in hallway	CO	5/16/2018	6:00:00 PM	5/17/2018	6:15:00 AM	5/18/2018	5.2	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	11	CR	Faucet in 2 year old program room	CO	5/16/2018	6:00:00 PM	5/17/2018	6:16:00 AM	5/18/2018	6.1	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	12	TL	Faucet in staff room	CO	5/16/2018	6:00:00 PM	5/17/2018	6:17:00 AM	5/18/2018	3.2	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	13	CR	Faucet in classroom	CO	5/16/2018	6:00:00 PM	5/17/2018	6:17:00 AM	5/18/2018	5.1	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	14	CR	Faucet in home living	CO	5/16/2018	6:00:00 PM	5/17/2018	6:20:00 AM	5/18/2018	1.5	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	15	CR	Left faucet in room 12	CO	5/16/2018	6:00:00 PM	5/17/2018	6:21:00 AM	5/18/2018	1.5	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	16	CR	Right faucet in room 12	CO	5/16/2018	6:00:00 PM	5/17/2018	6:21:00 AM	5/18/2018	3.6	No
Water Testing	Calvert Country School	6/23/2018	1	17	CR	Faucet in room 10	CO	5/16/2018	6:00:00 PM	5/17/2018	6:22:00 AM	5/18/2018	2.4	No

Laboratory of MD	Calvert Country School													
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	18	CR	Faucet in room 9	CO	5/16/2018	6:00:00 PM	5/17/2018	6:21:00 AM	5/18/2018	18.1	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	19	CR	Faucet in room 8	CO	5/16/2018	6:00:00 PM	5/17/2018	6:20:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	20	CR	Faucet in room 7	CO	5/16/2018	6:00:00 PM	5/17/2018	6:19:00 AM	5/18/2018	1.2	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	21b	CF	Bubbler in room 5	CO	5/16/2018	6:00:00 PM	5/17/2018	6:16:00 AM	5/18/2018	2.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	22	CS	Faucet in room 5	CO	5/16/2018	6:00:00 PM	5/17/2018	6:16:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	24	CS	Left faucet in room 6	CO	5/16/2018	6:00:00 PM	5/17/2018	6:18:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	25	CR	Right faucet in room 6	CO	5/16/2018	6:00:00 PM	5/17/2018	6:18:00 AM	5/18/2018	7.6	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	26b	CF	Bubbler room 3	CO	5/16/2018	6:00:00 PM	5/17/2018	6:15:00 AM	5/18/2018	1.1	No
Water Testing	Calvert Country School	6/23/2018	1	27	CS	Faucet in room 3	CO	5/16/2018	6:00:00 PM	5/17/2018	5:15:00 AM	5/18/2018	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	28b	CF	Bubbler in room 4	CO	5/16/2018	6:00:00 PM	5/17/2018	6:14:00 AM	5/18/2018	1.6	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	29	CS	Faucet in room 4	CO	5/16/2018	6:00:00 PM	5/17/2018	6:14:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	30	CR	Faucet in room 2	CO	5/16/2018	6:00:00 PM	5/17/2018	6:13:00 AM	5/18/2018	1.1	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	31	CR	Faucet in Music Room	CO	5/16/2018	6:00:00 PM	5/17/2018	6:12:00 AM	5/18/2018	2.7	No
Water Testing Laboratory of MD	Calvert Country School	6/23/2018	1	32	CR	Faucet in room 1	CO	5/16/2018	6:00:00 PM	5/17/2018	6:11:00 AM	5/18/2018	<1.0	No