

# Calvert High School

## 2021-2022 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	2a	DF	bottle filler outside cafeteria	FD	5/2/22	8:00pm	5/3/22	5:11am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	6a	DF	Bottle filler outside nurse room	FD	5/2/22	8:00pm	5/3/22	5:13am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	13a	DF	Bottle Filler outside 109	FD	5/2/22	8:00pm	5/3/22	5:15am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	27a	DF	bottle filler by stairs 1	FD	5/2/22	8:00pm	5/3/22	5:09am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	2	30a	DF	bottle filler outside 317	FD	5/2/22	8:00pm	5/3/22	5:07am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	34a	DF	bottle filler inside the door of the weight room	FD	5/2/22	8:00pm	5/3/22	6:09am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	37	IM	ice machine in kitchen	FD	5/2/22	8:00pm	5/3/22	5:10am	5/6/22	<1.0	No

Water Testing Laboratory of MD	Calvert High School	5/17/22	1	38	KS	2 compartment sink cold faucets	FD	5/2/22	8:00pm	5/3/22	5:11am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	39	KS	left cold faucet 3 compartment sink	FD	5/2/22	8:00pm	5/3/22	5:12am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	40	KS	right cold faucet 3 compartment sink	FD	5/2/22	8:00pm	5/3/22	5:12am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	41	KS	dish sprayer in dish room	FD	5/2/22	8:00pm	5/3/22	5:13am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	42	KS	cold faucet on solo kettle	FD	5/2/22	8:00pm	5/3/22	5:13am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	43	KS	left kettle	FD	5/2/22	8:00pm	5/3/22	5:14am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	44	KS	right kettle	FD	5/2/22	8:00pm	5/3/22	5:15am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	45	IM	ice machine 222	FD	5/2/22	8:00pm	5/3/22	5:39am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	47	CR	teacher cold faucet	FD	5/2/22	8:00pm	5/3/22	5:33am	5/6/22	<1.0	No
Water Testing	Calvert High School	5/17/22	1	48	CR	far left cold faucet	FD	5/2/22	8:00pm	5/3/22	5:44am	5/6/22	3.2	No

Laboratory of MD														
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	49	CR	left middle cold faucet	FD	5/2/22	8:00pm	5/3/22	5:34am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	50	CR	middle left cold faucet	FD	5/2/22	8:00pm	5/3/22	5:35am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	51	CR	middle right cold faucet	FD	5/2/22	8:00pm	5/3/22	5:36am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	52	CR	right middle cold faucet	FD	5/2/22	8:00pm	5/3/22	5:36am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	53	CR	far right cold faucet	FD	5/2/22	8:00pm	5/3/22	5:37am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	54	CR	cold faucet in teachers' lounge 1	FD	5/2/22	8:00pm	5/3/22	5:39am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	55	CR	cold faucet media center office	FD	5/2/22	8:00pm	5/3/22	5:40am	5/6/22	1.7	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	56	CR	cold faucet in mail room	FD	5/2/22	8:00pm	5/3/22	5:18am	5/6/22	<1.0	No
Water Testing	Calvert High School	5/17/22	1	57	NO	cold faucet in nurse room	FD	5/2/22	8:00pm	5/3/22	5:20am	5/6/22	<1.0	No

Water Testing Laboratory of MD	Calvert High School	5/17/22	1	58	IM	fridge ice machine in nurse room	FD	5/2/22	8:00pm	5/3/22	5:21am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	59	CR	front cold faucet 402	FD	5/2/22	8:00pm	5/3/22	5:27am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	60	CR	back cold faucet 402	FD	5/2/22	8:00pm	5/3/22	5:27am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	61	CR	front cold faucet 404	FD	5/2/22	8:00pm	5/3/22	5:29am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	62	CR	back cold faucet 404	FD	5/2/22	8:00pm	5/3/22	5:29am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	63	CR	cold faucet in 109 office	FD	5/2/22	8:00pm	5/3/22	5:18am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	64	CR	cold faucet in training room	FD	5/2/22	8:00pm	5/3/22	5:28am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	65	IM	left ice machine in training room	FD	5/2/22	8:00pm	5/3/22	5:28am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	66	IM	right ice machine in training room	FD	5/2/22	8:00pm	5/3/22	5:28am	5/6/22	<1.0	No
Water Testing	Calvert High School	5/17/22	1	67	CR	cold faucet 104	FD	5/2/22	8:00pm	5/3/22	5:24am	5/6/22	<1.0	No

Water Testing Laboratory of MD	Calvert High School	5/17/22	1	68	CR	cold faucet 102	FD	5/2/22	8:00pm	5/3/22	5:22am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	69	CR	cold faucet 100	FD	5/2/22	8:00pm	5/3/22	5:22am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	2	70	CR	cold faucet in teacher lounge 2	FD	5/2/22	8:00pm	5/3/22	5:05am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	2	71	CR	cold faucet in 330	FD	5/2/22	8:00pm	5/3/22	5:09am	5/6/22	1.4	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	73	IM	Right ice machine in weight room	FD	5/2/22	8:00pm	5/3/22	6:11am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	74	CR	Cold faucet 2 compartment sink in stadium concession stand	FD	5/2/22	8:00pm	5/3/22	4:14pm	5/6/22	1.1	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	2	75	IM	fridge ice machine in teacher's lounge	FD	5/2/22	8:00pm	5/3/22	5:05am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	76	IM	Ice machine in 203	FD	5/2/22	8:00pm	5/3/22	5:35am	5/6/22	<1.0	No
Water Testing	Calvert High School	5/17/22	1	77	CR	Cold faucet in 203	FD	5/2/22	8:00pm	5/3/22	5:35am	5/6/22	2.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	78	KS	cold faucet in stage/auditorium concession stand	FD	5/2/22	8:00pm	5/3/22	5:16am	5/6/22	9.1	Yes

Water Testing Laboratory of MD	Calvert High School	5/17/22	1	79	IM	Fridge right ice machine in nurse room	FD	5/2/22	8:00pm	5/3/22	5:22am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	80	NO	Faucet exam room 41	FD	5/2/22	8:00pm	5/3/22	5:23am	5/6/22	<1.0	No
Water Testing Laboratory of MD	Calvert High School	5/17/22	1	81	CR	faucet in field house	FD	5/2/22	8:00pm	5/3/22	6:11am	5/6/22	<1.0	No