

Calvert Elementary School

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	1	DF	Water fountain outside room 100	FD	5/16/2018	8:30:00 PM	5/17/2018	5:52:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	2	DF	Water fountain outside gym	FD	5/16/2018	8:30:00 PM	5/17/2018	5:33:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	3	DF	Water fountain across from 113	FD	5/16/2018	8:30:00 PM	5/17/2018	5:33:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	4	DF	Water fountain across from 117	FD	5/16/2018	8:30:00 PM	5/17/2018	5:38:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	5	DF	Water fountain across from cafeteria	FD	5/16/2018	8:30:00 PM	5/17/2018	5:45:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	6	DF	Water fountain in cafeteria	FD	5/16/2018	8:30:00 PM	5/17/2018	5:46:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	7	DF	Left water fountain across from 130	FD	5/16/2018	8:30:00 PM	5/17/2018	5:46:00 AM	5/18/2018	<1.0	No

Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	8	DF	Right water fountain across from 130	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:46:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	9	DF	Water fountain outside 141	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:34:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	10	CR	Faucet in 105	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:30:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	11	CR	Faucet in 106	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:32:00 AM	5/18/2018	1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	12	CR	Faucet in 208	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:30:00 AM	5/18/2018	1.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	B13	CF	Bubbler in 112	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:32:00 AM	5/18/2018	12.9	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	14	CS	Left faucet in 112	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:32:00 AM	5/18/2018	3.1	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	15	CR	Right Faucet in 112	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:32:00 AM	5/18/2018	4.7	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	16B	CF	Bubbler in 114	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:36:00 AM	5/18/2018	5.8	No
Water Testing	Calvert Elementary School	6/30/2018	1	17	CS	Faucet in 114	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:36:00 AM	5/18/2018	4.2	No

Laboratory of MD														
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	18B	CF	Bubbler in 118	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:40:00 AM	5/18/2018	2.1	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	19	CS	Left faucet in 118	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:40:00 AM	5/18/2018	5.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	20	CR	Right faucet in 118	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:40:00 AM	5/18/2018	7.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	21B	CF	Bubbler in 121	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:39:0 AM	5/18/2018	1.5	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	22	CS	Right faucet 121	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:39:00 AM	5/18/2018	10.6	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	23	CR	Left Faucet in 121	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:39:00 AM	5/18/2018	6.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	24B	CF	Bubbler in 217	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:42:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	25	CS	Left faucet in 217	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:42:00 AM	5/18/2018	1.1	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	26	CR	Right faucet in 217	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:42:00 AM	5/18/2018	13.9	No

Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	27B	CF	Bubbler in 216	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:44:00 AM	5/18/2018	2.6	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	28	CS	Left faucet in 216	FD	5/16/2018	8:30:00 PM	5/17/2018	5:44:00 AM	5/18/2018	7.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	29	CR	Right faucet in 216	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:44:00 AM	5/18/2018	4.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	30	KS	Left faucet in kitchen	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:48:00 AM	5/18/2018	3.9	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	31	KS	Middle faucet in kitchen	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:48:00 AM	5/18/2018	2.5	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	32	KS	Right faucet in kitchen	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:48:00 AM	5/18/2018	1.9	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	33	CR	Left faucet in 132	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:52:00 AM	5/18/2018	30.7	Yes
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	34	CR	Right faucet in 132	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:52:00 AM	5/18/2018	6.7	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	B35	CF	Bubbler in room 133	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:43:00 AM	5/18/2018	1.3	No
Water Testing	Calvert Elementary School	6/30/2018	1	36	CS	Left faucet in room 133	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:43:00 AM	5/18/2018	3.1	No

Laboratory of MD														
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	37	CR	Right faucet in room 133	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:43:00 AM	5/18/2018	3.7	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	38B	CF	Bubbler in 135	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:42:00 AM	5/18/2018	3.4	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	39	CS	Faucet in 135	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:42:00 AM	5/18/2018	5.8	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	40	CR	Faucet in 136	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:40:00 AM	5/18/2018	5.5	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	41	CR	Faucet in 210	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:40:00 AM	5/18/2018	3.9	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	42	CR	Faucet in 206	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:38:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	43B	CF	Bubbler in 139	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:37:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	44	CS	Faucet in 139	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:37:00 AM	5/18/2018	1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	45B	CF	Bubbler in 140	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:36:00 AM	5/18/2018	<1.0	No

Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	46	CS	Faucet in 140	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:36:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	47	CR	Faucet in 141	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:34:00 AM	5/18/2018	2.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	1	48	CR	Left faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:29:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	49	CR	From middle faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:29:00 AM	5/18/2018	1.6	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	50	CR	Front Right faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:29:00 AM	5/18/2018	14.3	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	51	CR	Back left faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:30:00 AM	5/18/2018	20.2	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	52	CR	Back middle faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:30:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	53	CR	Back right faucet in 201	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:30:00 AM	5/18/2018	15.0	No
Water Testing Laboratory of MD	Calvert Elementary School	6/30/2018	2	54	DF	Fountain outside room 118	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:49:00 AM	5/18/2018	<1.0	No
Water Testing	Calvert Elementary School	6/30/2018	1	55	CR	Right faucet in room 114	FD	5/16/2018	8: 30:00 PM	5/17/2018	5:36:00 AM	5/18/2018	3.3	No

