

# Plum Point Elementary School

## 2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	1	DF	Water fountain in Kindergarten	FD	5/14/2018	6:30:00 PM	5/15/2018	5:17:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	2	DF	Water fountain past main office	FD	5/14/2018	6:30:00 PM	5/15/2018	5:22:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	3	DF	Water fountain outside room 16	FD	5/14/2018	6:30:00 PM	5/15/2018	5:24:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	4	DF	Water fountain past the gym	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	5	CF	Water fountain by room 24	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	6	DF	Left water fountain by room 25	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	7	DF	Right water fountain by room 25	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	5/18/2018	<1.0	No

Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	8	DF	Water fountain by room 31	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	9	DF	Water fountain by room 35	FD	5/14/2018	6:30:00 PM	5/15/2018	5:48:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	10	DF	Water fountain by room 39	FD	5/14/2018	6:30:00 PM	5/15/2018	5:24:00 AM	5/18/2018	1.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	11	DF	Water fountain by room 41	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	12	DF	Water fountain by room 45	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	13	DF	Water fountain by room 46	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	14	DF	Water fountain by gym	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	15	DF	Water fountain in cafeteria	FD	5/14/2018	6:30:00 PM	5/15/2018	5:56:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b16	CF	Bubbler in room 11	FD	5/14/2018	6:30:00 PM	5/15/2018	5:19:00 AM	5/18/2018	8.5	No
Water Testing	Plum Point Elementary School	6/23/2018	1	17	CS	Faucet in room 11	FD	5/14/2018	6:30:00 PM	5/15/2018	5:19:00 AM	5/18/2018	4.3	No

Laboratory of MD														
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b18	CF	Bubbler in room 12	FD	5/14/2018	6:30:00 PM	5/15/2018	5:20:00 AM	5/18/2018	1.6	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	19	CS	Faucet in room 12	FD	5/14/2018	6:30:00 PM	5/15/2018	5:20:00 AM	5/18/2018	2.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b20	CF	Bubbler in room 14	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	21	CS	Faucet in room 14	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b22	CF	Bubbler in room 14	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	23	CS	Faucet in room 15	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	24	CR	Faucet in room 18	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	5/18/2018	10.6	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	25	CR	Faucet in room 20	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	5/18/2018	3.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b26	CF	Bubbler in room 21	FD	5/14/2018	6:30:00 PM	5/15/2018	5:31:00 AM	5/18/2018	3.4	No

Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	27	CS	Faucet in room 21	FD	5/14/2018	6:30:00 PM	5/15/2018	5:31:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b28	CF	Bubbler in room 22	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	5/18/2018	1.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	29	CS	Faucet in room 22	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b30	CF	Bubbler in room 23	FD	5/14/2018	6:30:00 PM	5/15/2018	5:34:00 AM	5/18/2018	1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	31	CS	Faucet in room 23	FD	5/14/2018	6:30:00 PM	5/15/2018	5:34:00 AM	5/18/2018	3.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b32	CF	Bubbler in room 25	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	33	CS	Faucet in room 25	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b34	CF	Bubbler in room 26	FD	5/14/2018	6:30:00 PM	5/15/2018	5:38:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	35	CS	Faucet in room 26	FD	5/14/2018	6:30:00 PM	5/15/2018	5:38:00 AM	5/18/2018	<1.0	No
Water Testing	Plum Point Elementary School	6/23/2018	1	b36	CF	Bubbler in room 27	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	5/18/2018	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	37	CS	Faucet in room 27	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b38	CF	Bubbler in room 30	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	5/18/2018	1.8	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	39	CS	Faucet in room 30	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	5/18/2018	1.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b40	CF	Bubbler in room 31	FD	5/14/2018	6:30:00 PM	5/15/2018	5:47:00 AM	5/18/2018	3.8	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	41	CS	Faucet in room 31	FD	5/14/2018	6:30:00 PM	5/15/2018	5:47:00 AM	5/18/2018	5.1	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b42	CF	Bubbler in room 32	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	5/18/2018	5.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	43	CS	Faucet in room 32	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	5/18/2018	4.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b44	CF	Bubbler in room 33	FD	5/14/2018	6:30:00 PM	5/15/2018	5:51:00 AM	5/18/2018	2.1	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	45	CS	Faucet in room 33	FD	5/14/2018	6:30:00 PM	5/15/2018	5:51:00 AM	5/18/2018	3.7	No

Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b46	CF	Bubbler in room 34	FD	5/14/2018	6:30:00 PM	5/15/2018	5:52:00 AM	5/18/2018	11.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	47	CS	Faucet in room 34	FD	5/14/2018	6:30:00 PM	5/15/2018	5:52:00 AM	5/18/2018	6.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b48	CF	Bubbler in room 36	FD	5/14/2018	6:30:00 PM	5/15/2018	5:53:00 AM	5/18/2018	2.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	49	CS	Faucet in room 36	FD	5/14/2018	6:30:00 PM	5/15/2018	5:53:00 AM	5/18/2018	3.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b50	CF	Bubbler in room 38	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	5/18/2018	12.6	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	51	CS	Faucet in room 38	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	5/18/2018	4.6	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b52	CF	Bubbler in room 39	FD	5/14/2018	6:30:00 PM	5/15/2018	5:25:00 AM	5/18/2018	12.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	53	CS	Faucet in room 39	FD	5/14/2018	6:30:00 PM	5/15/2018	5:25:00 AM	5/18/2018	9.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b54	CF	Bubbler in room 40	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	5/18/2018	6.6	No
Water Testing	Plum Point Elementary School	6/23/2018	1	55	CS	Faucet in room 40	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	5/18/2018	3.9	No

Laboratory of MD														
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	b56	CF	Bubbler in room 41	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	5/18/2018	5.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	57	CS	Faucet in room 41	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	5/18/2018	3.1	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B58	CF	Bubbler in room 42	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	5/18/2018	2.7	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	59	CS	Faucet in room 42	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	5/18/2018	3.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B60	CF	Bubbler in room 43	FD	5/14/2018	6:30:00 PM	5/15/2018	5:30:00 AM	5/18/2018	2.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	61	CS	Faucet in room 43	FD	5/14/2018	6:30:00 PM	5/15/2018	5:30:00 AM	5/18/2018	2.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B62	CF	Bubbler in room 44	FD	5/14/2018	6:30:00 PM	5/15/2018	5:32:00 AM	5/18/2018	2.8	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	63	CS	Faucet in room 44	FD	5/14/2018	6:30:00 PM	5/15/2018	5:32:00 AM	5/18/2018	4.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B64	CF	Bubbler in room 45	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	5/18/2018	2.3	No

Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	65	CS	Faucet in room 45	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	5/18/2018	3.4	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B66	CF	Bubbler in room 46	FD	5/14/2018	6:30:00 PM	5/15/2018	5:35:00 AM	5/18/2018	3.1	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	67	CS	Faucet in room 46	FD	5/14/2018	6:30:00 PM	5/15/2018	5:35:00 AM	5/18/2018	2.8	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B68	CF	Bubbler in room 47	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	5/18/2018	6.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	69	CS	Faucet in room 47	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	5/18/2018	5.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B70	CF	Bubbler in room 48	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	5/18/2018	2.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	71	CS	Faucet in room 48	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	5/18/2018	3.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B72	CF	Bubbler in room 50	FD	5/14/2018	6:30:00 PM	5/15/2018	5:39:00 AM	5/18/2018	2.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	73	CS	Faucet in room 50	FD	5/14/2018	6:30:00 PM	5/15/2018	5:39:00 AM	5/18/2018	2.0	No
Water Testing	Plum Point Elementary School	6/23/2018	1	74	TL	Faucet in lounge	FD	5/14/2018	6:30:00 PM	5/15/2018	5:41:00 AM	5/18/2018	1.8	No



Laboratory of MD														
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	75	CR	Left faucet in room 54	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	5/18/2018	3.3	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	76	CR	Right faucet in room 54	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	5/18/2018	1.1	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	B77	CF	Bubbler in room 55	FD	5/14/2018	6:30:00 PM	5/15/2018	5:43:00 AM	5/18/2018	2.9	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	78	CS	Faucet in room 55	FD	5/14/2018	6:30:00 PM	5/15/2018	5:43:00 AM	5/18/2018	4.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	79	KS	Solo faucet in kitchen	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	5/18/2018	5.4	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	80	KS	Left faucet in kitchen	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	5/18/2018	3.5	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	81	KS	Right faucet in kitchen	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	5/18/2018	4.2	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	82	NO	Faucet in nurse office	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	83	TL	Faucet record room 3	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	5/18/2018	<1.0	No

Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	84	CR	Left faucet in head start	FD	5/14/2018	6:30:00 PM	5/15/2018	5:57:00 AM	5/18/2018	1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	85	DF	Water fountain in head start	FD	5/14/2018	6:30:00 PM	5/15/2018	5:57:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	86	DF	Outside fountain at the playground	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	5/18/2018	<1.0	No
Water Testing Laboratory of MD	Plum Point Elementary School	6/23/2018	1	87	IM	Ice machine in kitchen	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	5/18/2018	<1.0	No