

Patuxent Elementary School

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	1	DF	Fountain in 8	FD	4/30/2018	6:30:00 AM	5/01/2018	5:31:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	2	DF	Fountain past main office	FD	4/30/2018	6:30:00 AM	5/01/2018	5:32:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	3	DF	Fountain outside of 12	FD	4/30/2018	6:30:00 AM	5/01/2018	5:43:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	4	DF	Fountain outside of gym	FD	4/30/2018	6:30:00 AM	5/01/2018	5:52:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	5	DF	Fountain outside of 21	FD	4/30/2018	6:30:00 AM	5/01/2018	5:59:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	6	DF	Left fountain outside of 1001	FD	4/30/2018	6:30:00 AM	5/01/2018	6:00:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	7	DF	Right fountain outside of 1001	FD	4/30/2018	6:30:00 AM	5/01/2018	6:00:00 AM	5/7/2018	1.20	No

Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	8	DF	Fountain outside of 27	FD	4/30/2018	6:30:00 AM	5/01/2018	6:08:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	9	DF	Fountain outside of 38	FD	4/30/2018	6:30:00 AM	5/01/2018	6:09:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	10	DF	Fountain outside of 52	FD	4/30/2018	6:30:00 AM	5/01/2018	5:59:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	11	DF	Fountain outside of 48	FD	4/30/2018	6:30:00 AM	5/01/2018	5:53:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	12	DF	Fountain outside of 44	FD	4/30/2018	6:30:00 AM	5/01/2018	5:49:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	13	DF	Fountain in gym	FD	4/30/2018	6:30:00 AM	5/01/2018	5:36:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	14	DF	Fountain in cafeteria	FD	4/30/2018	6:30:00 AM	5/01/2018	5:28:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b15	CF	Bubbler in 8	FD	4/30/2018	6:30:00 AM	5/01/2018	5:32:00 AM	5/7/2018	2.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	16	CS	Faucet in 8	FD	4/30/2018	6:30:00 AM	5/01/2018	5:32:00 AM	5/7/2018	1.60	No
Water Testing	Patuxent Elementary School	6/08/2018	1	b17	CF	Bubbler in 9	FD	4/30/2018	6:30:00 AM	5/01/2018	5:40:00 AM	5/7/2018	1.70	No

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	18	CS	Faucet in 9	FD	4/30/2018	6:30:00 AM	5/01/2018	5:40:00 AM	5/7/2018	2.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b19	CF	Bubbler in 10	FD	4/30/2018	6:30:00 AM	5/01/2018	5:41:00 AM	5/7/2018	1.50	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	20	CS	Faucet in 10	FD	4/30/2018	6:30:00 AM	5/01/2018	5:41:00 AM	5/7/2018	2.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b21	CF	Bubbler in 13	FD	4/30/2018	6:30:00 AM	5/01/2018	5:44:00 AM	5/7/2018	2.90	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	22	CS	Faucet in 13	FD	4/30/2018	6:30:00 AM	5/01/2018	5:44:00 AM	5/7/2018	2.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b23	CF	Bubbler in 14	FD	4/30/2018	6:30:00 AM	5/01/2018	5:45:00 AM	5/7/2018	1.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	24	CS	Faucet in 14	FD	4/30/2018	6:30:00 AM	5/01/2018	5:45:00 AM	5/7/2018	2.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	25b	CF	Bubbler in 15	FD	4/30/2018	6:30:00 AM	5/01/2018	5:47:00 AM	5/7/2018	1.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	26	CS	Faucet in 15	FD	4/30/2018	6:30:00 AM	5/01/2018	5:47:00 AM	5/7/2018	1.90	No

Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	27	CR	Faucet in 16	FD	4/30/2018	6:30:00 AM	5/01/2018	5:49:00 AM	5/7/2018	6.90	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	28	CR	Faucet in 18	FD	4/30/2018	6:30:00 AM	5/01/2018	5:49:00 AM	5/7/2018	6.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b29	CF	Bubbler in 19	FD	4/30/2018	6:30:00 AM	5/01/2018	5:54:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	30	CS	Faucet in 19	FD	4/30/2018	6:30:00 AM	5/01/2018	5:54:00 AM	5/7/2018	2.60	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b31	CF	Bubbler in 23	FD	4/30/2018	6:30:00 AM	5/01/2018	5:55:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	32	CS	Faucet in 23	FD	4/30/2018	6:30:00 AM	5/01/2018	5:55:00 AM	5/7/2018	2.60	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b33	CF	Bubbler in 24	FD	4/30/2018	6:30:00 AM	5/01/2018	5:57:00 AM	5/7/2018	3.10	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	34	CS	Faucet in 24	FD	4/30/2018	6:30:00 AM	5/01/2018	5:57:00 AM	5/7/2018	3.60	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b35	CF	Bubbler in 1001	FD	4/30/2018	6:30:00 AM	5/01/2018	6:01:00 AM	5/7/2018	<1.0	No
Water Testing	Patuxent Elementary School	6/08/2018	1	36	CS	Faucet in 1001	FD	4/30/2018	6:30:00 AM	5/01/2018	6:01:00 AM	5/7/2018	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b37	CF	Bubbler in 1004	FD	4/30/2018	6:30:00 AM	5/01/2018	6:02:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	38	CS	Faucet In 1004	FD	4/30/2018	6:30:00 AM	5/01/2018	6:02:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b39	CF	Bubbler in 1015	FD	4/30/2018	6:30:00 AM	5/01/2018	6:04:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	40	CS	Faucet in 1015	FD	4/30/2018	6:30:00 AM	5/01/2018	6:04:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b41	CF	Bubbler in 1012	FD	4/30/2018	6:30:00 AM	5/01/2018	6:06:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	42	CS	Faucet in 1012	FD	4/30/2018	6:30:00 AM	5/01/2018	6:06:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b43	CF	Bubbler in 25	FD	4/30/2018	6:30:00 AM	5/01/2018	5:53:00 AM	5/7/2018	1.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	44	CS	Faucet in 25	FD	4/30/2018	6:30:00 AM	5/01/2018	5:53:00 AM	5/7/2018	3.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b45	CF	Bubbler in 30	FD	4/30/2018	6:30:00 AM	5/01/2018	6:10:00 AM	5/7/2018	1.30	No

Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	46	CS	Faucet in 30	FD	4/30/2018	6:30:00 AM	5/01/2018	6:10:00 AM	5/7/2018	2.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b47	CF	Bubbler in 31	FD	4/30/2018	6:30:00 AM	5/01/2018	6:11:00 AM	5/7/2018	1.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	48	CS	Faucet in 31	FD	4/30/2018	6:30:00 AM	5/01/2018	6:11:00 AM	5/7/2018	2.90	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b49	CF	Bubbler in 34	FD	4/30/2018	6:30:00 AM	5/01/2018	6:13:00 AM	5/7/2018	1.50	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	50	CS	Faucet in 34	FD	4/30/2018	6:30:00 AM	5/01/2018	6:13:00 AM	5/7/2018	2.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b51	CF	Bubbler in 35	FD	4/30/2018	6:30:00 AM	5/01/2018	6:11:00 AM	5/7/2018	2.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	52	CS	Faucet in 35	FD	4/30/2018	6:30:00 AM	5/01/2018	6:11:00 AM	5/7/2018	3.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b53	CF	Bubbler in 36	FD	4/30/2018	6:30:00 AM	5/01/2018	6:10:00 AM	5/7/2018	1.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	54	CS	Faucet in 36	FD	4/30/2018	6:30:00 AM	5/01/2018	6:10:00 AM	5/7/2018	2.50	No
Water Testing	Patuxent Elementary School	6/08/2018	1	b55	CF	Bubbler in 40	FD	4/30/2018	6:30:00 AM	5/01/2018	6:08:00 AM	5/7/2018	1.20	No

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	56	CS	Faucet in 40	FD	4/30/2018	6:30:00 AM	5/01/2018	6:08:00 AM	5/7/2018	2.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b57	CF	Bubbler in 47	FD	4/30/2018	6:30:00 AM	5/01/2018	5:58:00 AM	5/7/2018	3.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	58	CS	Faucet in 47	FD	4/30/2018	6:30:00 AM	5/01/2018	5:58:00 AM	5/7/2018	4.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b59	CF	Bubbler in 49	FD	4/30/2018	6:30:00 AM	5/01/2018	6:00:00 AM	5/7/2018	5.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	60	CS	Faucet in 49	FD	4/30/2018	6:30:00 AM	5/01/2018	6:00:00 AM	5/7/2018	4.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b61	CF	Bubbler in 50	FD	4/30/2018	6:30:00 AM	5/01/2018	6:02:00 AM	5/7/2018	2.40	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	62	CS	Faucet in 50	FD	4/30/2018	6:30:00 AM	5/01/2018	6:02:00 AM	5/7/2018	4.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b63	CF	Bubbler in 54	FD	4/30/2018	6:30:00 AM	5/01/2018	5:57:00 AM	5/7/2018	1.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	64	CS	Faucet in 54	FD	4/30/2018	6:30:00 AM	5/01/2018	5:57:00 AM	5/7/2018	2.90	No

Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b65	CF	Bubbler in 55	FD	4/30/2018	6:30:00 AM	5/01/2018	5:55:00 AM	5/7/2018	1.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	66	CS	Faucet in 55	FD	4/30/2018	6:30:00 AM	5/01/2018	5:55:00 AM	5/7/2018	2.40	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b67	CF	Bubbler in 56	FD	4/30/2018	6:30:00 AM	5/01/2018	5:54:00 AM	5/7/2018	1.10	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	68	CS	Faucet in 56	FD	4/30/2018	6:30:00 AM	5/01/2018	5:54:00 AM	5/7/2018	2.10	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b69	CF	Bubbler in 42	FD	4/30/2018	6:30:00 AM	5/01/2018	5:48:00 AM	5/7/2018	1.50	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	70	CS	Faucet in 42	FD	4/30/2018	6:30:00 AM	5/01/2018	5:48:00 AM	5/7/2018	2.40	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b71	CF	Bubbler in 45	FD	4/30/2018	6:30:00 AM	5/01/2018	5:50:00 AM	5/7/2018	1.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	72	CS	Faucet in 45	FD	4/30/2018	6:30:00 AM	5/01/2018	5:50:00 AM	5/7/2018	3.60	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b73	CF	Bubbler in 46	FD	4/30/2018	6:30:00 AM	5/01/2018	5:51:00 AM	5/7/2018	2.80	No
Water Testing	Patuxent Elementary School	6/08/2018	1	74	CS	Faucet in 46	FD	4/30/2018	6:30:00 AM	5/01/2018	5:51:00 AM	5/7/2018	2.70	No

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b75	CF	Bubbler in 33	FD	4/30/2018	6:30:00 AM	5/01/2018	5:45:00 AM	5/7/2018	1.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	76	CS	Faucet In 33	FD	4/30/2018	6:30:00 AM	5/01/2018	5:45:00 AM	5/7/2018	4.20	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	77	TL	Faucet in staff lounge	FD	4/30/2018	6:30:00 AM	5/01/2018	5:40:00 AM	5/7/2018	<1.0	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	78	CR	Left faucet in 58	FD	4/30/2018	6:30:00 AM	5/01/2018	5:42:00 AM	5/7/2018	1.40	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	79	CR	Right faucet in 58	FD	4/30/2018	6:30:00 AM	5/01/2018	5:42:00 AM	5/7/2018	1.50	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b80	CF	Bubbler in 59	FD	4/30/2018	6:30:00 AM	5/01/2018	5:43:00 AM	5/7/2018	4.00	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	81	CS	Faucet in 59	FD	4/30/2018	6:30:00 AM	5/01/2018	5:43:00 AM	5/7/2018	3.90	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	82	KS	Solo faucet in kitchen	FD	4/30/2018	6:30:00 AM	5/01/2018	5:30:00 AM	5/7/2018	2.90	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	83	KS	Left double sink faucet in kitchen	FD	4/30/2018	6:30:00 AM	5/01/2018	5:30:00 AM	5/7/2018	1.10	No

Water Testing Laboratory of MD	Patuxent Elementary School		1	84	KS	Right double sink faucet in kitchen	FD	4/30/2018	6:30:00 AM	5/01/2018	5:30:00 AM	5/7/2018	1.70	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	85	NO	Sink in health room	FD	4/30/2018	6:30:00 AM	5/01/2018	5:31:00 AM	5/7/2018	1.80	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	86	TL	Sink in 4	FD	4/30/2018	6:30:00 AM	5/01/2018	5:34:00 AM	5/7/2018	2.80	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	87	CR	1 st faucet in Judy center trailer	FD	4/30/2018	6:30:00 AM	5/01/2018	6:17:00 AM	5/7/2018	2.30	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	b88	CF	Bubbler in Judy center trailer	FD	4/30/2018	6:30:00 AM	5/01/2018	6:18:00 AM	5/7/2018	1.10	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	89	CS	Back faucet in Judy Center	FD	4/30/2018	6:30:00 AM	5/01/2018	6:19:00 AM	5/7/2018	3.40	No
Water Testing Laboratory of MD	Patuxent Elementary School	6/08/2018	1	90	IM	Ice machine in nurse office	FD	4/30/2018	6:30:00 AM	5/01/2018	5:33:00 AM	5/7/2018	<1.0	No