

Calvert Board of Education

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	1	DF	Left fountain in lobby	FD	5/30/2018	6:30PM	5/31/2018	5:10 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	2	DF	Right fountain in lobby	FD	5/30/2018	6:30PM	5/31/2018	5:10 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	3	TL	Faucet in caucus room in administration	FD	5/30/2018	6:30PM	5/31/2018	5:12 AM	6/3/2018	1.1	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	4	TL	Sink in instruction kitchen	FD	5/30/2018	6:30PM	5/31/2018	5:14 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	5	DF	Fountain in instruction	FD	5/30/2018	6:30PM	5/31/2018	5:15 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	6	DF	Fountain outside human resources	FD	5/30/2018	6:30PM	5/31/2018	5:08 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	7	IM	Fountain in student services	FD	5/30/2018	6:30PM	5/31/2018	5:15 AM	6/3/2018	1.4	No
Water Testing	Board of Education	7/7/2018	1	8	TL	Ice machine in maintenance lounge	FD	5/30/2018	6:30PM	5/31/2018	5:18 AM	6/3/2018		No

Laboratory of MD														
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	9	DF	Faucet in maintenance lounge	FD	5/30/2018	6:30PM	5/31/2018	5:07 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	10	DF	Fountain in maintenance	FD	5/30/2018	6:30PM	5/31/2018	5:08 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	11	DF	Fountain in special education	FD	5/30/2018	6:30PM	5/31/2018	5:10 AM	6/3/2018	<1.0	No
Water Testing Laboratory of MD	Board of Education	7/7/2018	1	12	TL	Fountain in warehouse	FD	5/30/2018	6:30pm	5/31/2018	6:45 AM	6/3/2018	<1.0	No