



TOWN OF VERNON

14 PARK PLACE, VERNON, CONNECTICUT 06066

OFFICE OF PERMANENT MUNICIPAL
BUILDING COMMITTEE

Office of the Permanent Municipal Building Committee

APPROVED MINUTES

Regular Meeting:

January 28, 2020

RECEIVED
VERNON TOWN CLERK
20 MAR - 2 PM 3:38

There was No Quorum and No Meeting was Held

The inspection of Fire Station #1 – Vernon Center was completed.

Julie A. Mathison, Recording Secretary

*** APPROVED ***

INSPECTION OF TOWN BUILDINGS

FIRE STATION #1 – VERNON CENTER

PERFORMED BY THE PERMANENT MUNICIPAL BUILDING COMMITTEE

JANUARY 28, 2020

1. The committee recommended in our last inspection of 2/21/18 that the old exhaust in the lower bay be removed as the building was losing heat. This matter has not been addressed.
2. The dormers continue to leak in the upstairs meeting and exercise rooms. It has caused significant damage. Repairs are being made at this time.
3. The bottom panel layers on the rear garage doors are delaminating.
4. It was confirmed by fire personnel that this fire station has a proper functioning fire alarm system and carbon monoxide detectors.

* * * * *

Vernon Center Fire Station personnel expressed to this committee that an updated electrical system is needed for the building.

It is also essential that a properly sized generator be purchased for the building.