



STATE OF WASHINGTON
DEPARTMENT OF HEALTH
OFFICE OF ENVIRONMENTAL PUBLIC HEALTH SCIENCES
243 Israel Road SE • PO Box 47825 • Olympia, Washington 98504-7825
TDD Relay Service: 1-800-833-6388

June 26, 2019

Liliana Cardenas
Director of Maintenance and Operations
Cascade View Elementary
13601 32nd Ave South
Tukwila, Washington 98168

Dear Liliana Cardenas:

Thank you for helping us implement the governor's directive on lead and improve the health and safety of children in Washington.

On June 18, 2019, water samples were collected from eight drinking water fixtures at Cascade View Elementary and tested for lead. Although there were no fixtures that had lead in amounts that were equal to or above twenty parts per billion (ppb), some samples did have measureable lead. The test results from your school are attached.

Children are exposed to lead from a variety of sources in their environments. Exposure sources include dust from old, deteriorating lead paint, contaminated soil, take-home exposures from parents who work in certain industries, and many others. Each of these sources contributes to the amount of lead in the bodies of children.

It is important to reduce exposure from every source as much as possible. There were six fixtures in your school that were below the action level, but still had measurable amounts of lead. The attached recommendations can help you reduce the amount of lead in your school's drinking water as much as possible.

What to do next:

1. **Communicate** with staff, students, parents and the community about water test results and any actions you are taking in response. Please note: we will post results on the DOH website, no sooner than one month from the date of this letter.
 - We have included a template letter that can be customized to communicate to parents and your school community.
 - We suggest making the results available on your district website and through your office.
2. **Address** the sources of lead in the drinking water at your school. To assist you we have included the "Guidelines for Responding to Lead Test Results" matrix and a list of recommended actions. *There are resources in the capital facilities budget set aside for remediation. Please contact Justin Rogers with the Office of the Superintendent of Public Instruction at 360-725-6261 or email at Justin.rogers@k12.wa.us for further information.*

3. **Notify** us if your school district cannot immediately address issues identified by these results. Please describe interim measures that will be taken to reduce exposure to lead from those fixtures which had elevated lead results and any plans for remediation. This information should also be provided to staff and your community.

How were the samples taken and analyzed?

Cold water samples were collected from every tap used by students for drinking or used to prepare food for students. These were “first draw” samples, in which the water is allowed to sit in the plumbing system for 8 to 18 hours before the sample is collected. Samples were analyzed by our Public Health Laboratory using EPA method 200.8.

If you have questions regarding test results, or need additional information please contact me at 360.236.3248, or e-mail at annemarie.charles@doh.wa.gov.

Sincerely,



Anne Marie Charles
School Lead in Drinking Water Coordinator

Recommended Actions

In order to assist you we are including the information below to help you reduce lead in your drinking water. If you need further technical assistance please contact DOH.

- For each fixture with lead results between 10 and 19 ppb we recommend that you choose one or more of the following:
 - Replace fixtures with certified lead-free fixtures or remove the fixtures permanently if they are not needed. You can provide bottled water to students and staff on an interim basis while you are replacing fixtures if necessary.
 - Implement a flushing program to help reduce lead levels that may increase while fixtures are not in use.
 - Clean aerators regularly to remove particulates that may contain lead.
 - Install a National Sanitation Foundation (NSF) certified filter to remove lead and replace it as recommended by the manufacturer.
 - Permanently convert these fixtures to hand wash only stations. An example of a hand wash only graphic is available [here](#).
 - Remove the fixture permanently.
 - If you plan to replace fixtures, contact DOH to discuss the steps you can take to ensure the water is safe to drink before returning it to use.

- For each fixture with lead results between 2 and 9 ppb we recommend that you:
 - Implement a flushing program to help reduce lead levels that may increase while fixtures are not in use.
 - Clean aerators regularly to remove particulates that may contain lead.



Name of Sampler: Lisa Christensen
Date Collected: 6/18/2019
School Name: Cascade View Elementary
School Code: 3226
School District: Tukwila
School Address: 13601 32nd Ave South, Tukwila WA 98168
School County: King
Number of Samples Collected: 8
School Point of Contact (POC): Liliana Cardenas
POC Title: Director of Maintenance and Operations
POC Email: cardenasl@tukwila.wednet.edu
POC Phone Number: (206) 901-8020
Date Samples Sent to Lab: 06/18/2019
Date Samples Received by Lab: 6/20/2019
Shipment Tracking Number: 787958786565

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25713	other	other		<1	6/21/2019	06693, 8:05 AM
25714	FirstDraw	Tap	Room C105	2	6/21/2019	Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week
25715	FirstDraw	Tap	Room E102	3	6/21/2019	Used this morning, Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25716	FirstDraw	Tap	Room E106	3	6/21/2019	Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week
25717	FirstDraw	Tap	Room E115	3	6/21/2019	
25718	FirstDraw	Tap	Room E111	1	6/21/2019	Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week
25719	FirstDraw	Tap	Room D102	3	6/22/2019	Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week
25720	FirstDraw	Tap	Room D107	3	6/22/2019	Post fixture replacement, conditioned 2x a day for 2-3 minutes over a week