

Windy Hill Elementary School

2020-2021 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date and Time Water Last Used	Date and Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	3b	DF	Bottle Filler Bubbler outside gym	FD	3/3/21 7:00 PM	3/4/21 6:49 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	8	CF	Bubbler in 24	FD	3/3/21 7:00 PM	3/4/21 6:06 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	9	CS	Fountain in 24	FD	3/3/21 7:00 PM	3/4/21 6:06 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	10	CF	Bubbler in 25	FD	3/3/21 7:00 PM	3/4/21 6:08 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	11	CS	Fountain in 25	FD	3/3/21 7:00 PM	3/4/21 6:08 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	12	CF	Bubbler in 26	FD	3/3/21 7:00 PM	3/4/21 6:12 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	13	CS	Faucet in 26	FD	3/3/21 7:00 PM	3/4/21 6:12 AM	3/10/2021	<1.0	yes

Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	14	CF	Bubber in 27	FD	3/3/21 7:00 PM	3/4/21 6:15 AM	3/10/2021	1.1	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	15	CS	Faucet in 27	FD	3/3/21 7:00 PM	3/4/21 6:15 AM	3/10/2021	5.4	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	16	CF	Bubbler in 42	FD	3/3/21 7:00 PM	3/4/21 6:20 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	17	CS	Faucet in 42	FD	3/3/21 7:00 PM	3/4/21 6:20 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	18	CF	Bubbler in 43	FD	3/3/21 7:00 PM	3/4/21 6:23 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	19	CS	Faucet in 43	FD	3/3/21 7:00 PM	3/4/21 6:23 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	20	CF	Bubbler in 44	FD	3/3/21 7:00 PM	3/4/21 6:26 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	21	CS	Faucet in 44	FD	3/3/21 7:00 PM	3/4/21 6:26 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	22	CF	Bubbler in 45	FD	3/3/21 7:00 PM	3/4/21 6:30 AM	3/10/2021	<1.0	yes
Water Testing	Windy Hill Elementary School	3/19/2021	1	23	CS	Faucet in 45	FD	3/3/21 7:00 PM	3/4/21 6:30 AM	3/10/2021	<1.0	yes

Laboratory of MD													
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	24	CF	Bubbler in 46	FD	3/3/21 7:00 PM	3/4/21 6:32 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	25	CS	Faucet in 46	FD	3/3/21 7:00 PM	3/4/21 6:32 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	26	CR	Faucet in 29	FD	3/3/21 7:00 PM	3/4/21 6:34 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	27	CF	Bubbler in 47	FD	3/3/21 7:00 PM	3/4/21 6:34 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	28	CS	Faucet in 47	FD	3/3/21 7:00 PM	3/4/21 6:36 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	29	CF	Bubbler in 48	FD	3/3/21 7:00 PM	3/4/21 6:36 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	30	CS	Faucet in 48	FD	3/3/21 7:00 PM	3/4/21 6:38 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	31	CF	Bubbler in 49	FD	3/3/21 7:00 PM	3/4/21 6:38 AM	3/10/2021	<1.0	yes	
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	32	CS	Faucet in 49	FD	3/3/21 7:00 PM	3/4/21 6:42 AM	3/10/2021	<1.0	yes	

Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	33	CF	Bubbler in 50	FD	3/3/21 7:00 PM	3/4/21 6:42 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	34	CS	Faucet in 50	FD	3/3/21 7:00 PM	3/4/21 6:44 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	35	CF	Bubbler in 51	FD	3/3/21 7:00 PM	3/4/21 6:44 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	36	CS	Faucet in 51	FD	3/3/21 7:00 PM	3/4/21 6:48 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	37	CF	Bubbler in 201	FD	3/3/21 7:00 PM	3/4/21 6:48 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	38	CS	Faucet in 201	FD	3/3/21 7:00 PM	3/4/21 6:50 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	39	CF	Bubbler in 202	FD	3/3/21 7:00 PM	3/4/21 6:50 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	40	CS	Faucet in 202	FD	3/3/21 7:00 PM	3/4/21 6:50 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	41	CF	Bubbler in 60	FD	3/3/21 7:00 PM	3/4/21 6:49 AM	3/10/2021	<1.0	yes
Water Testing	Windy Hill Elementary School	3/19/2021	1	42	CS	Faucet in 60	FD	3/3/21 7:00 PM	3/4/21 6:54 AM	3/10/2021	<1.0	yes

Laboratory of MD												
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	43	CF	Bubbler in 70	FD	3/3/21 7:00 PM	3/4/21 6:52 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	44	CS	Faucet in 70	FD	3/3/21 7:00 PM	3/4/21 6:52 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	45	CF	Bubbler in 69	FD	3/3/21 7:00 PM	3/4/21 6:50 AM	3/10/2021	1.4	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	46	CS	Faucet in 69	FD	3/3/21 7:00 PM	3/4/21 6:50 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	47	CF	Bubbler in 72	FD	3/3/21 7:00 PM	3/4/21 6:44 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	48	CS	Faucet in 72	FD	3/3/21 7:00 PM	3/4/21 6:44 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	49	CF	Bubbler in 71	FD	3/3/21 7:00 PM	3/4/21 6:42 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	50	CS	Faucet in 71	FD	3/3/21 7:00 PM	3/4/21 6:42 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	51	CF	Bubbler in 76	FD	3/3/21 7:00 PM	3/4/21 6:40 AM	3/10/2021	<1.0	yes

Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	52	CS	Faucet in 76	FD	3/3/21 7:00 PM	3/4/21 6:40 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	53	CF	Bubbler in 77	FD	3/3/21 7:00 PM	3/4/21 6:38 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	54	CS	Faucet in 77	FD	3/3/21 7:00 PM	3/4/21 6:38 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	55	CF	Bubbler in 78	FD	3/3/21 7:00 PM	3/4/21 6:36 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	56	CS	Faucet in 78	FD	3/3/21 7:00 PM	3/4/21 6:36 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	57	CF	Bubbler in 79	FD	3/3/21 7:00 PM	3/4/21 6:36 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	58	CS	Faucet in 79	FD	3/3/21 7:00 PM	3/4/21 6:34 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	59	CF	Bubbler in 81	FD	3/3/21 7:00 PM	3/4/21 6:34 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	60	CS	Faucet in 81	FD	3/3/21 7:00 PM	3/4/21 6:32 AM	3/10/2021	<1.0	yes
Water Testing	Windy Hill Elementary School	3/19/2021	1	61	CF	Bubbler in 89	FD	3/3/21 7:00 PM	3/4/21 6:32 AM	3/10/2021	<1.0	yes

Laboratory of MD												
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	62	CS	Faucet in 89	FD	3/3/21 7:00 PM	3/4/21 6:31 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	63	CF	Bubbler in 90	FD	3/3/21 7:00 PM	3/4/21 6:31 AM	3/10/2021	2.7	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	64	CS	Faucet in 90	FD	3/3/21 7:00 PM	3/4/21 6:30 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	65	CF	Bubbler in 91	FD	3/3/21 7:00 PM	3/4/21 6:30 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	66	CS	Faucet in 91	FD	3/3/21 7:00 PM	3/4/21 6:26 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	67	CF	Bubbler in 92	FD	3/3/21 7:00 PM	3/4/21 6:26 AM	3/10/2021	1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	68	CS	Faucet in 92	FD	3/3/21 7:00 PM	3/4/21 6:24 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	69	CF	Bubbler in 97	FD	3/3/21 7:00 PM	3/4/21 6:24 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	70	CS	Faucet in 97	FD	3/3/21 7:00 PM	3/4/21 6:23 AM	3/10/2021	<1.0	yes

Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	71	CF	Bubbler in 100	FD	3/3/21 7:00 PM	3/4/21 6:23 AM	3/10/2021	1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	72	CS	Faucet in 100	FD	3/3/21 7:00 PM	3/4/21 6:21 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	73	CF	Bubbler in 105	FD	3/3/21 7:00 PM	3/4/21 6:21 AM	3/10/2021	1.5	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	74	CR	Faucet in 105	FD	3/3/21 7:00 PM	3/4/21 6:19 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	75	TL	Faucet in lounge	FD	3/3/21 7:00 PM	3/4/21 6:19 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	76	CR	Left faucet in 115	FD	3/3/21 7:00 PM	3/4/21 6:15 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	77	CR	Right faucet 115	FD	3/3/21 7:00 PM	3/4/21 6:14 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	78	CF	Bubbler in 123	FD	3/3/21 7:00 PM	3/4/21 6:14 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	79	CS	Faucet in 123	FD	3/3/21 7:00 PM	3/4/21 6:12 AM	3/10/2021	1.1	no
Water Testing	Windy Hill Elementary School	3/19/2021	1	80	CF	Bubbler in 124	FD	3/3/21 7:00 PM	3/4/21 6:12 AM	3/10/2021	1.2	no

Laboratory of MD												
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	81	CS	Faucet in 124	FD	3/3/21 7:00 PM	3/4/21 6:06 AM	3/10/2021	1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	82	KS	Left Solo Faucet in Kitchen	FD	3/3/21 7:00 PM	3/4/21 6:06 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	83	KS	Right Faucet 3 Compartment Sink in Kitchen	FD	3/3/21 7:00 PM	3/4/21 6:11 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	84	KS	Right Faucet 3 Compartment Sink in kitchen	FD	3/3/21 7:00 PM	3/4/21 6:11 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	85	NO	Faucet in health room	FD	3/3/21 7:00 PM	3/4/21 6:47 AM	3/10/2021	<1.0	yes
Water Testing Laboratory of MD	Windy Hill Elementary School	3/19/2021	1	86	CR	Faucet in 5	FD	3/3/21 7:00 PM	3/4/21 6:47 AM	3/10/2021	<1.0	yes