

Barnes Elementary – Window Replacement Phase #2 specifications

Required materials:

- i) Storefront frames: U.S. Aluminum (or equivalent), IT 451 2" inch x 4.5" inch thermally broken framing, clear adonized aluminum, center glazed, break shapes 040 clear adonized aluminum.
- ii) Glass: 1" OA 1/4" inch solar ban tempered over 1/4" inch clear tempered glass.
- iii) Awning windows: U.S. Aluminum (or equivalent) 7400 series awning windows with 1" inch glass pocket/glazed with same glass as specified in line ii. above. Include removable stops, NO wet glazing.
- iv) Caulking: Dow Corning 795

A100, A102 - Existing
windows.



A101, Staff Room,
Boys Restroom, Girls
Restroom - Existing
windows





ADD-Alternate - Lower window example of how window should look when completed.