

HEALTH, SAFETY & RISK MANAGEMENT Christy Fischer

175 Route 32 North • New Paltz, NY 12561 Telephone: 845-255-1400 • Facsimile: 845-255-3826 Email:cfische@ulsterboces.org



Environmental Hygiene Report

Attn: Dr. Charles Khoury
District Superintendent
Ulster Board of Cooperative Educational Services
175 Route 32N, New Paltz, NY 12561
Prepared by: Christy Fischer

Location(s)	Center for Innovative Teaching and
	Learning at Port Ewen
Project No.	002-2021
Site Visit(s)	March 10, 2021
Report Date	May 4, 2021
Investigator(s)	Christy Fischer

Ulster County BOCES *Health, Safety & Risk Management* does not assert that all potential health or safety hazards at this site were evaluated during this survey. This survey is strictly limited to that which is identified in the Project Scope of the report.

TABLE OF CONTENTS

Executive Summary	2
Project Scope	2
Materials & Methods	2
Results Summary	3
Discussion	3
Comments & Recommendations	3
References	4
Appendix	Tabular Results

Author's Note: Parenthetical numerals at the end of a sentence reference the work with the corresponding notation in the References section. *Please read this report in its entirety, including any attached appendices, to fully understand this investigation.*

Executive Summary

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, water outlets at the Ulster BOCES Center for Innovative Teaching and Learning at Port Ewen were sampled on March 10, 2021. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 41 such water outlets in the building. Of these 41 locations, two exceeded the 15 parts per billion (ppb) action level. Signage has been posted at both these outlets and remedial action is being taken. The two outlets will be resampled as necessary once remediation is complete. A copy of the results has been forwarded to the Ulster County Health Department.

Project Scope

Identify appropriate potable water sampling locations and collect samples from plumbing fixtures at the Ulster BOCES Career for Innovative Teaching and Learning at Port Ewen, for analysis for lead content. Review the data and information and prepare a written report for the Ulster BOCES administration.

Materials & Methods

All samples were collected from the type of plumbing fixtures where potable water is commonly drawn using the NYSDOH protocol. First-draw samples for lead were collected after the water had sat in the pipes for at least eight hours. All samples were collected in 250 ml containers provided by EnviroTest Laboratories in Newburgh, NY. The samples were brought to the laboratory for analysis. EnviroTest is NYS ELAP-approved (#10142) for potable and non-potable water analysis.

Results Summary

All sample results and other data were reported to the administration of the local educational agency (LEA) via phone, fax, or e-mail as they became available to our department. See Appendix for full laboratory reports.

Water Samples that Exceeded Action Level

Career & Technical Center

Sample Location	Result (ppb)
Bath Sink Between 107 & 108	49
125 Handwash Sink 1	29

Discussion

In order to be used as healthful fluid for human consumption, water must be free from organisms that are capable of causing disease and from minerals and organic substances that could produce adverse physiological effects. (1) The Safe Drinking Water Act sets maximum contaminant levels (MCLs) for numerous contaminants. These include various inorganic, volatile organic, and synthetic organic compounds. Public water systems are required to do initial and periodic testing of their source water.

Comments & Recommendations

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, water outlets at the Ulster BOCES Center for Innovative Teaching and Learning at Port Ewen were sampled on March 10, 2021. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 41 such water outlets in the building. Of these 41 locations, two exceeded the 15 parts per billion (ppb) action level. Signage has been posted at both these outlets and remedial action is being taken. The two outlets will be resampled as necessary once

remediation is complete. A copy of the results has been forwarded to the Ulster County Health Department.

References

- 1. **American Water Works Association:** *Water Quality and Treatment.* New York, NY: McGraw-Hill, 1990
- 2. Bailey, R.A. et. al.: Chemistry of the Environment. New York, NY: Academic Press, 1978.
- 3. USEPA: 3Ts for Reducing Lead in Drinking Water in Schools. Washington, DC: USEPA, 2006.



ANALYTICAL REPORT

Job Number: 420-192860-1
SDG Number: Port Ewen CITL
Job Description: Ulster BOCES

For: Ulster BOCES 175 Route 32 North New Paltz, NY 12561

Attention: Christy Fischer

Meredith W Ruthven

Meredith Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

03/29/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554



METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-192860-1

SDG Number: Port Ewen CITL

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev	v.5.4
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES Job Number: 420-192860-1

SDG Number: Port Ewen CITL

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-192860-1

SDG Number: Port Ewen CITL

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-192860-1	104 Sink	Drinking Water	03/10/2021 0550	03/11/2021 1430
420-192860-2	118 Bath Sink 1	Drinking Water	03/10/2021 0551	03/11/2021 1430
420-192860-3	118 Bath Sink 2	Drinking Water	03/10/2021 0551	03/11/2021 1430
420-192860-4	116 Sink	Drinking Water	03/10/2021 0553	03/11/2021 1430
420-192860-5	115 Bath Sink	Drinking Water	03/10/2021 0554	03/11/2021 1430
420-192860-6	116A Bath Sink	Drinking Water	03/10/2021 0554	03/11/2021 1430
420-192860-7	106 Sink 1	Drinking Water	03/10/2021 0555	03/11/2021 1430
420-192860-8	106 Sink 2	Drinking Water	03/10/2021 0555	03/11/2021 1430
420-192860-9	111A Bath Sink	Drinking Water	03/10/2021 0556	03/11/2021 1430
420-192860-10	114 Sink	Drinking Water	03/10/2021 0556	03/11/2021 1430
420-192860-11	Bath Sik Between 107 & 108	Drinking Water	03/10/2021 0557	03/11/2021 1430
420-192860-12	107 Sink	Drinking Water	03/10/2021 0557	03/11/2021 1430
420-192860-13	108 Sink	Drinking Water	03/10/2021 0558	03/11/2021 1430
420-192860-14	110A Bath Sink	Drinking Water	03/10/2021 0559	03/11/2021 1430
420-192860-15	120 Bath Sink 1	Drinking Water	03/10/2021 0600	03/11/2021 1430
420-192860-16	120 Bath Sink 2	Drinking Water	03/10/2021 0600	03/11/2021 1430
420-192860-17	125 HW Sink 1	Drinking Water	03/10/2021 0602	03/11/2021 1430
420-192860-18	125 Sink 2	Drinking Water	03/10/2021 0602	03/11/2021 1430
420-192860-19	125 Sink 3	Drinking Water	03/10/2021 0603	03/11/2021 1430
420-192860-20	125 Sink 4	Drinking Water	03/10/2021 0603	03/11/2021 1430
420-192860-21	125 Sink 5	Drinking Water	03/10/2021 0604	03/11/2021 1430
420-192860-22	126 Bath Sink	Drinking Water	03/10/2021 0605	03/11/2021 1430
420-192860-23	127 Bath Sink 1	Drinking Water	03/10/2021 0605	03/11/2021 1430
420-192860-24	127 Sink 2	Drinking Water	03/10/2021 0605	03/11/2021 1430
420-192860-25	204 Sink	Drinking Water	03/10/2021 0607	03/11/2021 1430
420-192860-26	214 Bath Sink 1	Drinking Water	03/10/2021 0608	03/11/2021 1430
420-192860-27	214 Bath Sink 2	Drinking Water	03/10/2021 0608	03/11/2021 1430
420-192860-28	212A Bath Sink	Drinking Water	03/10/2021 0609	03/11/2021 1430
420-192860-29	212 Sink	Drinking Water	03/10/2021 0609	03/11/2021 1430
420-192860-30	211B Sink	Drinking Water	03/10/2021 0610	03/11/2021 1430
420-192860-31	216 Bath Sink 1	Drinking Water	03/10/2021 0611	03/11/2021 1430
420-192860-32	216 Bath Sink 2	Drinking Water	03/10/2021 0611	03/11/2021 1430
420-192860-33	228 Sink	Drinking Water	03/10/2021 0613	03/11/2021 1430
420-192860-34	227 Sink 1	Drinking Water	03/10/2021 0613	03/11/2021 1430
420-192860-35	227 Sink 2	Drinking Water	03/10/2021 0613	03/11/2021 1430
420-192860-36	227 Handwash Sink 3	Drinking Water	03/10/2021 0614	03/11/2021 1430
420-192860-37	225 Sink	Drinking Water	03/10/2021 0615	03/11/2021 1430
420-192860-38	218A Sink	Drinking Water	03/10/2021 0615	03/11/2021 1430
420-192860-39	220 Bath Sink 1	Drinking Water	03/10/2021 0616	03/11/2021 1430
420-192860-40	220 Bath Sink 2	Drinking Water	03/10/2021 0616	03/11/2021 1430
420-192860-41	219 Bath Sink	Drinking Water	03/10/2021 0616	03/11/2021 1430

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 104 Sink Lab Sample ID: 420-192860-1 Date Sampled: 03/10/2021 0550
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0807	
Prep Method: 200.7/200.8		Date Pre	epared:	03/17/2021 1030	
Pb	3.4	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 118 Bath Sink 1 Lab Sample ID: 420-192860-2 Date Sampled: 03/10/2021 0551

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date An	alyzed:	03/25/2021 1108	
Prep Method: 200.7/200.8			Date Pr	epared:	03/22/2021 1500	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 118 Bath Sink 2 Lab Sample ID: 420-192860-3 Date Sampled: 03/10/2021 0551

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0815	
Prep Method: 200.7/200.8		Date Pr	epared:	03/17/2021 1030	
Pb	1.1	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 116 Sink Lab Sample ID: 420-192860-4 Date Sampled: 03/10/2021 0553

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	alyzed:	03/23/2021 0817	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 115 Bath Sink Lab Sample ID: 420-192860-5

Date Sampled: 03/10/2021 0554
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	alyzed:	03/23/2021 0819	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 116A Bath Sink Lab Sample ID: 420-192860-6

Date Sampled: 03/10/2021 0554
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0821	
Prep Method: 200.7/200.8		Date Pre	epared:	03/17/2021 1030	
Pb	2.6	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 106 Sink 1 Lab Sample ID: 420-192860-7 Date Sampled: 03/10/2021 0555

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Quali	fier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0828	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 106 Sink 2 Lab Sample ID: 420-192860-8 Date Sampled: 03/10/2021 0555

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/25/2021 1127	
Prep Method: 200.7/200.8		Date Pr	epared:	03/22/2021 1500	
Pb	1.0	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 111A Bath Sink Lab Sample ID: 420-192860-9

Date Sampled: 03/10/2021 0556

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0830	
Prep Method: 200.7/200.8		Date Pre	epared:	03/17/2021 1030	
Pb	5.9	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 114 Sink Lab Sample ID: 420-192860-10 Date Sampled: 03/10/2021 0556

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0832	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: Bath Sik Between 107 & 108

Lab Sample ID: 420-192860-11

Date Sampled: 03/10/2021 0557

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0834	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	49	g	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 107 Sink Lab Sample ID: 420-192860-12 Date Sampled: 03/10/2021 0557

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0836	
Prep Method: 200.7/200.8		Date Pre	epared:	03/17/2021 1030	
Pb	1.8	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 108 Sink Lab Sample ID: 420-192860-13 Date Sampled: 03/10/2021 0558

Date Received: 03/11/2021 1430

Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0838	
Prep Method: 200.7/200.8		Date Pro	epared:	03/17/2021 1030	
Pb	1.8	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 110A Bath Sink Lab Sample ID: 420-192860-14

Date Sampled: 03/10/2021 0559
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0842	
Prep Method: 200.7/200.8		Date Pre	epared:	03/17/2021 1030	
Pb	4.5	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 120 Bath Sink 1 Lab Sample ID: 420-192860-15 Date Sampled: 03/10/2021 0600
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/25/2021 1106	
Prep Method: 200.7/200.8			Date Pr	epared:	03/22/2021 1500	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 120 Bath Sink 2 Lab Sample ID: 420-192860-16 Date Sampled: 03/10/2021 0600
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0844	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 125 HW Sink 1 Lab Sample ID: 420-192860-17 Date Sampled: 03/10/2021 0602
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date A	nalyzed:	03/23/2021 0847	
Prep Method: 200.7/200.8		Date Pr	repared:	03/17/2021 1030	
Pb	29 g	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 125 Sink 2 Lab Sample ID: 420-192860-18 Date Sampled: 03/10/2021 0602
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0853	
Prep Method: 200.7/200.8		Date Pro	epared:	03/17/2021 1030	
Pb	7.2	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 125 Sink 3
Lab Sample ID: 420-192860-19

Date Sampled: 03/10/2021 0603
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Ar	nalyzed:	03/23/2021 0855	
Prep Method: 200.7/200.8		Date Pr	epared:	03/17/2021 1030	
Pb	2.5	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 125 Sink 4
Lab Sample ID: 420-192860-20

Date Sampled: 03/10/2021 0603
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Ar	alyzed:	03/23/2021 0857	
Prep Method: 200.7/200.8		Date Pr	epared:	03/17/2021 1030	
Pb	2.0	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 125 Sink 5
Lab Sample ID: 420-192860-21

Date Sampled: 03/10/2021 0604
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0859	
Prep Method: 200.7/200.8		Date Pro	epared:	03/17/2021 1030	
Pb	1.2	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 126 Bath Sink Lab Sample ID: 420-192860-22 Date Sampled: 03/10/2021 0605
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0901	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 127 Bath Sink 1 Lab Sample ID: 420-192860-23 Date Sampled: 03/10/2021 0605
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0903	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 127 Sink 2 Lab Sample ID: 420-192860-24 Date Sampled: 03/10/2021 0605
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0906	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 204 Sink Lab Sample ID: 420-192860-25 Date Sampled: 03/10/2021 0607
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/25/2021 1110	
Prep Method: 200.7/200.8		Date Pro	epared:	03/22/2021 1500	
Pb	5.5	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 214 Bath Sink 1 Lab Sample ID: 420-192860-26 Date Sampled: 03/10/2021 0608
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/25/2021 1117	
Prep Method: 200.7/200.8		Date Pro	epared:	03/22/2021 1500	
Pb	1.5	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 214 Bath Sink 2 Lab Sample ID: 420-192860-27 Date Sampled: 03/10/2021 0608
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0918	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 212A Bath Sink Lab Sample ID: 420-192860-28

Date Sampled: 03/10/2021 0609
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0920	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 212 Sink Lab Sample ID: 420-192860-29 Date Sampled: 03/10/2021 0609
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0922	
Prep Method: 200.7/200.8		Date Prepared:			
Pb	1.3	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 211B Sink Lab Sample ID: 420-192860-30 Date Sampled: 03/10/2021 0610
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0924	
Prep Method: 200.7/200.8		Date Prepared:		03/17/2021 1030	
Pb	4.1	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 216 Bath Sink 1 Lab Sample ID: 420-192860-31 Date Sampled: 03/10/2021 0611
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date An	alyzed:	03/23/2021 0927	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 216 Bath Sink 2 Lab Sample ID: 420-192860-32 Date Sampled: 03/10/2021 0611
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0929	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 228 Sink Lab Sample ID: 420-192860-33 Date Sampled: 03/10/2021 0613
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualit	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0931	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 227 Sink 1
Lab Sample ID: 420-192860-34

Date Sampled: 03/10/2021 0613
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	alyzed:	03/23/2021 0933	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 227 Sink 2
Lab Sample ID: 420-192860-35

Date Sampled: 03/10/2021 0613
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/25/2021 1125	
Prep Method: 200.7/200.8			Date Pr	epared:	03/22/2021 1500	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 227 Handwash Sink 3

Lab Sample ID: 420-192860-36

Date Sampled: 03/10/2021 0614
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualif	ier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0935	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 225 Sink Lab Sample ID: 420-192860-37 Date Sampled: 03/10/2021 0615
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0937	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 218A Sink Lab Sample ID: 420-192860-38 Date Sampled: 03/10/2021 0615
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date An	alyzed:	03/23/2021 0946	
Prep Method: 200.7/200.8		Date Prepared:			
Pb	6.5	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 220 Bath Sink 1 Lab Sample ID: 420-192860-39 Date Sampled: 03/10/2021 0616
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	alyzed:	03/23/2021 0948	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 220 Bath Sink 2 Lab Sample ID: 420-192860-40 Date Sampled: 03/10/2021 0616
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualifi	er	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0950	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Job Number: 420-192860-1 Sdg Number: Port Ewen CITL

Client Sample ID: 219 Bath Sink Lab Sample ID: 420-192860-41 Date Sampled: 03/10/2021 0616
Date Received: 03/11/2021 1430
Client Matrix: Drinking Water

Analyte	Result/Qualit	fier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Ar	nalyzed:	03/23/2021 0952	
Prep Method: 200.7/200.8			Date Pr	epared:	03/17/2021 1030	
Pb	1.0	U	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: Port Ewen CITL

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	Ü	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES Job Number:

Sdg Number: Port Ewen CITL

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES Job Number:

Sdg Number: Port Ewen CITL

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue Newburgh, NY 12550

Chain of Custody Record

EnviroTest Laboratories

Phone (845) 562-0890 Fax (845) 562-0841	Sampler: C Fischer			II e	ab PM:							Į,	Deliver	able	Tvne [,]				JOB #:			_		
Client Information												- 1	_evel	I, Le	evel II				Tanc	<i>^</i>	105-	2		
Client Contact: C Fischer	Phone:845 255-140)0 X1361		E-	-Mail:	i: NYS ASP Cat B EDD (Specify):					192860 18-3													
Company: Ulster BOCES		-							Aı	nalv	sis F	Rea	uest	ed					Page: Page 1 of 3					
Address: 175 North Chestnut Street	Due Date Request	Due Date Requested:							T		Ť		T	Ī	T				Preservation Cod)S:		7		
City: New Paltz	TAT Requested (d	ays):		· · · · · · · · · · · · · · · · · · ·	$\exists 1$														A - HCL B - NaOH	L- EDA M - Sodium	Sulfite			
State, Zip: NY, 12561																			C - Zn Acetate D - Nitric Acid	N - None O - MCAA	Cume			
Phone: 845-2551400 X1361	PO#:				-1							ļ							E - H2SO4 F - MeOH G - NH4CL	P - Other (s	pecify)			
Email: cfischer@ulsterboces.org	PWS#:				- <u>Ş</u>														H - Ascorbic Acid					
		<u> </u>			S or	or No	2				1		- 1					2	J - Di Water					
Project Name: Ulster BOCES	Project #:			,	క్రి	8	98 O										.	taine	Thiosulfate					
Site: Port Ewen CITL	Additional Contacts	\$1			ampl	S as	resent (Y											fcor	Other:		,	ı		
			Sample	Matrix (DV drinking		WSI .	24 CO2004				İ						1	berc	Upon Receipt P	reservatio	on verifie	d:		
		0	Туре	water, W=water		Ę.		[Num		, ,,				
Sample Identification Client ID (Lab ID)	Sample Date	Sample Time	(C≔comp, G≕grab)		oil,	Perform	Chlorine Lead (DW											Tota						
	$\rightarrow <$	><		ation Code		X	\swarrow											×	Special Ins	tructions	/Note:	\Box		
104 Sink	3/10/21	550	G	DW	$\perp \! \! \! \! \! \! \! \perp \! \! \! \! \! \! \! \! \! \! \!$	_	<u>`</u>	4	1					_		_						_		
118 Bath Sink 1	3/10/21	551	G	DW	Щ	\perp	×		Ш						\perp	\perp	_					_		
118 Bath Sink 2	3/10/21	551	G	DW		\perp	×	(L	\perp								╛		
116 Sink	3/10/21	553	G	DW			×		<u> </u>							Hitin	H i in							
115 Bath Sink	3/10/21	554	G	DW			×		_	*** ***		120 120	#### -10	29	60-E			Ш						
116A Bath Sink	3/10/21	554	G	DW			×		1	104 S	nk		13	20	0U-E	3-7					,			
106 Sink 1	3/10/21	555	G	DW			×		_	ate S	ample	d: 2/-	10/200									\Box		
106 Sink 2	3/10/21	555	G	DW	П	1	×		- 1 i	 I I	ı	u. 3/		21	4	20-1	643	153	7			٦		
111A Bath Sink	3/10/21	556	G	DW			Х															7		
114 Sink	3/10/21	556	G	DW	\Box		X												3	-		7		
Bath Sink Between 107 & 108	3/10/21	557	G	DW	\top	1	×		\prod		İ	\dashv	\top	\top			1					7		
107 Sink	3/10/21	557	G	DW	$\top \!\!\!\! \top$	\top	×						\dashv			\top						7		
108 Sink	3/10/21	558`	G	DW	\top	T	Х		\top			\top		\top		\top	T					\dashv		
110A Bath Sink	3/10/21	559	G	DW	\parallel	\top	X					\dashv	\top	\top		\dagger	\top					\dashv		
120 Bath Sink 1	3/10/21	600	G	DW	$\top\!$	\dagger	×				1	7	\top	\dagger	\top							7		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacter	ria, C=Cube, O=Oth	er, T=Terrac	ore, D=BOD	Bottle		_			\top		\top		\top	\forall	\top	T	\dagger		Container Type I	, ,		\forall		
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=F		r				I					\Box						I	I	Container Size 2			<u>]</u> .		
Preservation Added Upon Receipt: Manufacturer/Lot #:		Date:			Tim	ne:				_			S	ample	e # (s):									
Relinquished by:	Date/Time 3 (1) 2(230	-	Company	. 636	Re	eceived	i by:	1/2		6	L	7	Service de la constitución de la	Da	te/Tim	10; Z /	'n/.	21 1430	Company	12	┪		
Relinquished by:	Date/Time!			Company	nis_	Re	eceive	by:	- 21				L			te/Tim	<u> </u>	**/.		Company		\dashv		
Relinquished by:	Date/Time:			Company		Re	eceived	i by:							Da	te/Tim	ie:	**		Company		\dashv		
		, ,	Custada		.					90::-			_	-										
ICE Present: Custody Seal No.: Δ Yes Δ No.			Custody p S Yes ∆ N	io Agentati	9 0:	E 9	pozier To	emper	rature(s)	°C/ IR	GUN #	* /	<u>Z1</u>	, 0	<u> </u>						03/	29		

EnviroTest Laboratories, LLC

Custody Seal No .:

ICE Present:

Δ Yes Δ^{*}No

315 Fullerton Avenue

Chain of Custody Record

EnviroTest Laboratories

03/29

/2021

Newburgh, NY 12550 Phone (845) 562-0890 Fax (845) 562-0841 Sampler: C Fischer Lab PM: Deliverable Type: 192860 20\$3 Level I, Level II, Client Information E-Mail: NYS ASP Cat B Phone:845 255-1400 X1361 Client Contact: C Fischer EDD (Specify): Company: Ulster BOCES Page 2 of 3 **Analysis Requested** Due Date Requested: Address: 175 North Chestnut Street Preservation Codes: A - HCL L- EDA City: New Paltz TAT Requested (days): B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid State, Zip: NY, 12561 O - MCAA E - H2SO4 P - Other (specify) F - MeOH PO #: Phone: 845-2551400 X1361 G - NH4CL H - Ascorbic Acid Email: cfischer@ulsterboces.org PWS #: I - Ice J - DI Water K - Sodium Project #: Project Name: Ulster BOCES Thiosulfate Additional Contacts: Other: Site: Port Ewen CITL Matrix (DW= Upon Receipt Preservation verified: drinking Sample Y / N Lead (DW water, Type W=water. Sample (C=comp, S=solid, Sample Identification Client ID (Lab ID) Sample Date Time G=grab) O=waste/oil Preservation Code: Special Instructions/Note: DW Х 3/10/21 600 G 120 Bath Sink 2 DW Х G 125 HW Sink 1 3/10/21 602 DW Х 125 Sink 2 3/10/21 602 G 3/10/21 603 G DW Х 125 Sink 3 3/10/21 603 G DW Х 125 Sink 4 3/10/21 604 G DW Х 125 Sink 5 3/10/21 605 G DW Х 126 Bath Sink DW Х 127 Bath Sink 1 3/10/21 605 G Х 127 Sink 2 3/10/21 605 G DW Х 3/10/21 607 G DW 204 Sink G DW Х 214 Bath Sink 1 3/10/21 608 Х DW 3/10/21 G 214 Bath Sink 2 608 DW Χ 212A Bath Sink 3/10/21 609 G 3/10/21 609 G DW Х 212 Sink 3/10/21 Х 610 211B Sink Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Container Type P Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other Container Size 2 Preservation Added Upon Receipt: Time: Sample # (s): Manufacturer/Lot # 3 11 21 Company WYW/00(2) 230 Received by: Relinquished by: Date/Time: Company Received by: Date/Time: Relinguished by: Cepler Temperature(s) °C/ IR GUN #:

EnviroTest Laboratories, LLC

315 Fullerton Avenue

Chain of Custody Record

EnviroTest Laboratories

Newburgh, NY 12550 Phone (845) 562-0890 Fax (845) 562-0841

Filolie (043) 302-00301 ax (040) 302-0041	Sampler: C Fischer			La	b PM:							1	Delive	rable	Гуре:				JOB#				_
Client Information	Phone:845 255-140	00 V1261			Mail:		-						Leve						1	101	10,	50	2 F
Client Contact: C Fischer	-110116.043 230-140				wan.		NYS ASP Cat B EDD (Specify):						<u>x 8</u> (\sim	<u> </u>								
Company: Ulster BOCES									An	aly	sis F	Requ	uest	ed					Page: Page	3013			
Address: 175 North Chestnut Street	Due Date Request	ed:																		ervation (Codes:		
City: New Paltz	TAT Requested (d	ays):			II														A - HO B - Na		L- E M -	DA Sodium Su	lfite
State, Zip: NY, 12561																				tric Acid	0 -	None MCAA	
Phone: 845-2551400 X1361	PO #:				$\exists 1$	1													F - Me G - NI	OH	P-	Other (spe	cify)
Email: cfischer@ulsterboces.org	PWS #:				၂회														I - Ice	corbic Acid	d		
Project Name: Ulster BOCES	Project #:					٥ ا	2												J - DI K - So	dium			
	Additional Contacts				그림		es of						ŧ						Other:	Thiosulfate			
Site: Port Ewen CITL	Additional Contact			T	Sam) (8:												5				
Sample Identification Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (DW drinking water, W=water S=solid, O=waste/o ation Code	Fleid Fill	Nerform MS/MSD	Lead (DW 200.8)														Y /		
211B Sink	3/10/21	610	G	DW	\mathcal{H}	Υ	\downarrow_{x}											\dashv'		Special	Instru	ctions/N	ote:
216 Bath Sink 1	3/10/21	611	G	DW	\dashv	╁	×	+-	+	\dashv		+	\dagger	+	\dashv		+						
216 Bath Sink 2	3/10/21	611	G	DW	+	+	x	+	+	-		\dashv	+	\dashv	+	-	+						-
228 Sink	3/10/21	613	G	DW	+		T x	+	+					+	\dashv		-		+				
227 Sink 1	3/10/21	613	G	DW	+		x	+	+				\dashv		+	+	1						
227 Sink 2	3/10/21	613	G	DW	+	+	T _x	+	+		\dashv		-	+		+	-						
227 Handwash Sink 3	3/10/21	614	G	DW	+	+	T _x	+	+		\dashv			-	-		+						
225 Sink	3/10/21	615	G	DW	+	+	T _x	+-			\dashv	+	+		\dashv	+	+						
218A Sink	3/10/21	615	G	DW	$\forall t$	\dagger	T _x	+-			\dashv	+	+		+		+						
220 Bath Sink 1	3/10/21	616	G	DW	+	t	+	+			\dashv	1	_	\dashv	\dagger	_	+						
220 Bath Sink 2	3/10/21	616	G	DW	++	+	x	+	+		\dashv	\dashv	\dashv	\dagger	+	+	+						
219 Bath Sink	3/10/21	616	G	DW	╫	+	×	+	+	\dashv	\dashv	+	\dashv	+	+	+	+						
				 	+	+		+	++	\dashv		+	\dashv	\dagger	+	+	+						
			 		+	+	+	+	$\dagger \dagger$	\dashv	\dashv		+		+	+	+						
	- -		 	 	+	+	\dashv	\dagger	++	\dashv	\dashv		_		+	+	+						
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bac	teria, C=Cube, O=Oth	ıer, T≃Terrad	core, D=BOL) Bottle		十	+	\dagger	$\dagger \dagger$	\dashv	\dashv	\dashv	\dashv	\dagger	+	+	+		Conta	ainer Ty	pe P		
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6						1	工									士	1		_	iner Siz	•		
Preservation Added Upon Receipt: Manufacturer/Lot #:/		Date:			Tim	ie:							S	ample									
Relinguistics by:	Date/Time:	230		Company	nivat	Re	eceived	by:	7	_				1	D	ate/Ti	me:	(1)	21	143	Corr	pany T	7 .
Relinquished by)	Date/Time:			Company	1(11)	Re	eceived		T		» Le	<u> </u>	-		D	ate/Ti	<u>/</u> me:	H	<u>L1</u>	192		pany	
Relinquished by:	Date/Time:			Company		Re	eceived	i by:							D	ate/Ti	me:				Con	pany	
			Touchards of					-	ada sanc de contra	90/15		и.											
ICE Present; Custody Seal No.: Δ Yes Δμ/Νο			Yes A	eale interi	of	` 1 52	2 01er 1 e	empera	ature(s)	C/ IR	GUN	#:	21	0	6								03/2

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES Job Number: 420-192860-1
SDG Number: Port Ewen CITL

Login Number: 192860

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	