

Barstow Elementary School

2020-2021 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	1b	DF	Bottle Filler Outside of Cafeteria	FD	3/17/2021	7:00 PM	3/18/2021	6:18 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	8	NO	Faucet in health suite	FD	3/17/2021	7:00 PM	3/18/2021	6:12 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	9	NO	Faucet in health suite exam room	FD	3/17/2021	7:00 PM	3/18/2021	6:35 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	10	TL	Faucet in main office work room	FD	3/17/2021	7:00 PM	3/18/2021	6:13 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	11	TL	Faucet in lounge	FD	3/17/2021	7:00 PM	3/18/2021	6:15 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	12	KS	Left faucet in kitchen	FD	3/17/2021	7:00 PM	3/18/2021	6:17 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	13	KS	Right faucet in kitchen	FD	3/17/2021	7:00 PM	3/18/2021	6:17 AM	3/25/31	1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	15	CR	Faucet in music room	FD	3/17/2021	7:00 PM	3/18/2021	6:37 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	16	CR	Faucet in art room	FD	3/17/2021	7:00 PM	3/18/2021	6:37 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	17	CR	Faucet in media center work room	FD	3/17/2021	7:00 PM	3/18/2021	6:21 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b18	CF	Bubbler in room 125	FD	3/17/2021	7:00 PM	3/18/2021	6:23 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	19	CS	Faucet in room 125	FD	3/17/2021	7:00 PM	3/18/2021	6:23 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b20	CF	Bubbler in room 124	FD	3/17/2021	7:00 PM	3/18/2021	6:25 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	21	CS	Faucet in room 124	FD	3/17/2021	7:00 PM	3/18/2021	6:25 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b22	CF	Bubbler in room 123	FD	3/17/2021	7:00 PM	3/18/2021	6:27 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	23	CS	Faucet in room 123	FD	3/17/2021	7:00 PM	3/18/2021	6:27 AM	3/25/31	1.0	No
Water Testing	Barstow Elementary School	4/29/2021	1	b24	CF	Bubbler in room 122	FD	3/17/2021	7:00 PM	3/18/2021	6:29 AM	3/25/31	1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	25	CS	Faucet in room 122	FD	3/17/2021	7:00 PM	3/18/2021	6:29 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b26	CF	Bubbler in room 121	FD	3/17/2021	7:00 PM	3/18/2021	6:31 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	27	CS	Faucet in room 121	FD	3/17/2021	7:00 PM	3/18/2021	6:31 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b28	CF	Bubbler in room 120	FD	3/17/2021	7:00 PM	3/18/2021	6:33 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	29	CS	Faucet in room 120	FD	3/17/2021	7:00 PM	3/18/2021	6:33 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b30	CF	Bubbler in room 115	FD	3/17/2021	7:00 PM	3/18/2021	6:11 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	31	CS	Faucet in room 115	FD	3/17/2021	7:00 PM	3/18/2021	6:11 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b32	CF	Bubbler in room 114	FD	3/17/2021	7:00 PM	3/18/2021	6:15 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	33	CS	Faucet in room 114	FD	3/17/2021	7:00 PM	3/18/2021	6:15 AM	3/25/31	1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b34	CF	Bubbler in room 113	FD	3/17/2021	7:00 PM	3/18/2021	6:18 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	35	CS	Faucet in room 113	FD	3/17/2021	7:00 PM	3/18/2021	6:18 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b36	CF	Bubbler in room 112	FD	3/17/2021	7:00 PM	3/18/2021	6:20 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	37	CS	Faucet in room 112	FD	3/17/2021	7:00 PM	3/18/2021	6:20 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b38	CF	Bubbler in room 111	FD	3/17/2021	7:00 PM	3/18/2021	6:22 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	39	CS	Faucet in room 111	FD	3/17/2021	7:00 PM	3/18/2021	6:22 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b40	CF	Bubbler in room 110	FD	3/17/2021	7:00 PM	3/18/2021	6:25 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	41	CS	Faucet in room 110	FD	3/17/2021	7:00 PM	3/18/2021	6:25 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	42	CR	Faucet in grade 1 work room	FD	3/17/2021	7:00 PM	3/18/2021	6:26 AM	3/25/31	1.0	No
Water Testing	Barstow Elementary School	4/29/2021	1	b43	CF	Bubbler in room 106	FD	3/17/2021	7:00 PM	3/18/2021	6:29 AM	3/25/31	1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	44	CS	Faucet in room 106	FD	3/17/2021	7:00 PM	3/18/2021	6:29 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b45	CF	Bubbler in room 105	FD	3/17/2021	7:00 PM	3/18/2021	6:33 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	46	CS	Faucet in room 105	FD	3/17/2021	7:00 PM	3/18/2021	6:33 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b47	CF	Bubbler in room 104	FD	3/17/2021	7:00 PM	3/18/2021	6:36 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	48	CS	Faucet in room 104	FD	3/17/2021	7:00 PM	3/18/2021	6:36 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b49	CF	Bubbler in room 103	FD	3/17/2021	7:00 PM	3/18/2021	6:38 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	50	CS	Faucet in room 103	FD	3/17/2021	7:00 PM	3/18/2021	6:38 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b51	CF	Bubbler in room 102	FD	3/17/2021	7:00 PM	3/18/2021	6:40 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	52	CS	Faucet in room 102	FD	3/17/2021	7:00 PM	3/18/2021	6:40 AM	3/25/31	1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	b53	CF	Bubbler in room 101	FD	3/17/2021	7:00 PM	3/18/2021	6:43 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	54	CS	Faucet in room 101	FD	3/17/2021	7:00 PM	3/18/2021	6:43 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	55	CR	Faucet in room 130	FD	3/17/2021	7:00 PM	3/18/2021	6:47 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b56	CF	Bubbler in room 225	FD	3/17/2021	7:00 PM	3/18/2021	7:02 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	57	CS	Faucet in room 225	FD	3/17/2021	7:00 PM	3/18/2021	7:02 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b58	CF	Bubbler in room 224	FD	3/17/2021	7:00 PM	3/18/2021	7:02 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	59	CS	Faucet in room 224	FD	3/17/2021	7:00 PM	3/18/2021	7:02 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b60	CF	Bubbler in room 223	FD	3/17/2021	7:00 PM	3/18/2021	7:00 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	61	CS	Faucet in room 223	FD	3/17/2021	7:00 PM	3/18/2021	7:00 AM	3/25/31	1.0	No
Water Testing	Barstow Elementary School	4/29/2021	2	b62	CF	Bubbler in room 222	FD	3/17/2021	7:00 PM	3/18/2021	7:00 AM	3/25/31	1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	63	CS	Faucet in room 222	FD	3/17/2021	7:00 PM	3/18/2021	7:00 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b64	CF	Bubbler in room 221	FD	3/17/2021	7:00 PM	3/18/2021	6:58 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	65	CS	Faucet in room 221	FD	3/17/2021	7:00 PM	3/18/2021	6:58 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b66	CF	Bubbler in room 220	FD	3/17/2021	7:00 PM	3/18/2021	6:58 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	67	CS	Faucet in room 220	FD	3/17/2021	7:00 PM	3/18/2021	6:58 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b68	CF	Bubbler in room 215	FD	3/17/2021	7:00 PM	3/18/2021	6:55 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	69	CS	Faucet in room 215	FD	3/17/2021	7:00 PM	3/18/2021	6:55 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b70	CF	Bubbler in room 214	FD	3/17/2021	7:00 PM	3/18/2021	6:55 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	71	CS	Faucet in room 214	FD	3/17/2021	7:00 PM	3/18/2021	6:55 AM	3/25/31	1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b72	CF	Bubbler in room 213	FD	3/17/2021	7:00 PM	3/18/2021	6:53 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	73	CS	Faucet in room 213	FD	3/17/2021	7:00 PM	3/18/2021	6:53 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b74	CF	Bubbler in room 212	FD	3/17/2021	7:00 PM	3/18/2021	6:53 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	75	CS	Faucet in room 212	FD	3/17/2021	7:00 PM	3/18/2021	6:53 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b76	CF	Bubbler in room 211	FD	3/17/2021	7:00 PM	3/18/2021	6:52 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	77	CS	Faucet in room 211	FD	3/17/2021	7:00 PM	3/18/2021	6:52 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b78	CF	Bubbler in room 210	FD	3/17/2021	7:00 PM	3/18/2021	6:51 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	79	CS	Faucet in room 210	FD	3/17/2021	7:00 PM	3/18/2021	6:51 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	80	CR	Faucet in Grade 4 Work Room	FD	3/17/2021	7:00 PM	3/18/2021	6:50 AM	3/25/31	1.0	No
Water Testing	Barstow Elementary School	4/29/2021	2	b81	CF	Bubbler in room 205	FD	3/17/2021	7:00 PM	3/18/2021	6:48 AM	3/25/31	1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	82	CS	Faucet in room 205	FD	3/17/2021	7:00 PM	3/18/2021	6:48 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b83	CF	Bubbler in room 204	FD	3/17/2021	7:00 PM	3/18/2021	6:46 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	84	CS	Faucet in room 204	FD	3/17/2021	7:00 PM	3/18/2021	6:46 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b85	CF	Bubbler in room 203	FD	3/17/2021	7:00 PM	3/18/2021	6:44 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	86	CS	Faucet in room 203	FD	3/17/2021	7:00 PM	3/18/2021	6:44 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b87	CF	Bubbler in room 202	FD	3/17/2021	7:00 PM	3/18/2021	6:42 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	88	CS	Faucet in room 202	FD	3/17/2021	7:00 PM	3/18/2021	6:42 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	2	b89	CF	Bubbler in room 201	FD	3/17/2021	7:00 PM	3/18/2021	6:40 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	90	CS	Faucet in room 201	FD	3/17/2021	7:00 PM	3/18/2021	6:40 AM	3/25/31	1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	93	IM	Ice machine in lounge	FD	3/17/2021	7:00 PM	3/18/2021	6:12 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	94	IM	Ice machine in nurses office	FD	3/17/2021	7:00 PM	3/18/2021	6:12 AM	3/25/31	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	4/29/2021	1	95	CR	Faucet in Band room storage	FD	3/17/2021	7:00 PM	3/18/2021	6:18 AM	3/25/31	6.2	No