



Midlothian Independent School District

Request for Proposal RFP# 2021-022

Monitoring of Fire Alarm Systems, Inspection, Service & Repair

Addendum 3

(issued May 20, 2021)

Response to Questions:

- Does any site currently have cell/radio installed? **After speaking with respective departments, all locations have cellular equipment already installed.**
- If so, what are the manufacturers? **Commercial Fire Dual Path (Cellular & IP) Verizon Communicator, Red metal enclosure, Direct 120V AC Power (built-in power supply)**
- If cell/radio are to be provided, where do we provide that cost on the bid form? **If a column is not provided, please identify and add any additional information in a separate column(s).**
- To reprogram these Fire Alarms, there will be a cost. Where do we provide that cost per system on the bid form? **If a column is not provided, please identify and add any additional information in a separate column(s).**
- Bid form asks for pricing for open/close report. Fire Alarm does not send open/close reports. How would this cost be utilized? **If this is not applicable, please note with N/A.**