

## SPECIFICATIONS FOR BOILER REPAIRS

### Mitchell Elementary School

May 26, 2021

RSD 14 is looking for qualified contractors to re-tube two steam boilers, one Petro, one Johnstone. This includes the following:

1. Replace all tubes in both boilers.
2. Material shall be 3" O.D. , 12 gauge, SA 178 domestic boiler tubes.
3. Tubes shall be rolled, beaded and/or welded as originally installed.
4. All manholes and hand hole gaskets shall be replaced.
5. All debris shall be flushed out of the boiler and the interior cleaned.
6. Low water controls shall be cleaned and re-gasketed.
7. Boiler shall be pressure tested, witnessed by customer, and resealed upon completion.
8. Any welding shall be performed by a National Board "R" stamp holder.
9. Debris including old tubes shall be removed from premises and the area left broom clean.
10. Contractor shall be a National Board R Stamp Holder and will furnish RSD #14 with copies of certifications.
11. Please send bid to "RSD 14 Schools, PO Box 469, 5 Minortown Rd., Woodbury CT 06798. Clearly mark on the **sealed** bid envelope "Boiler Job MES". Bids will be opened at 9 am on June 10, 2021 at the Region 14 Central Office (above address).
12. Work shall begin after July 1, 2021

- No smoking on school grounds per State Law.
- No bid bond is required.
- No bid form is used. Please use your company letterhead.