


**LEGEND**

- WATER SAMPLE LOCATION

**NOTES**

1. BASE MAP IMAGERY FROM DANE COUNTY, 2014.
2. SCHOOL FACILITIES PLAN DRAWINGS SUPPLIED BY MMSD.
3. SAMPLE LOCATIONS AND FEATURES SHOWN ARE APPROXIMATE.



PROJECT:		<b>MMSD WATER SAMPLING</b>	
TITLE:		<b>THOREAU (023) FLOOR 2 SAMPLES</b>	
DRAWN BY:	J. PAPEZ	PROJ NO.:	274235
CHECKED BY:	B. WACHHOLZ	<b>FIGURE 1.B</b>	
APPROVED BY:	J. WEDEKIND		
DATE:	APRIL 2017		
		708 Heartland Trail, Suite 3000 Madison, WI 53717 Phone: 608.826.3600 www.trcsolutions.com	
FILE NO.:	MMSD_FINAL.mxd		

**Appendix B**  
**Analytical Results**

Table 1  
Summary of Lead Results  
Thoreau - 023  
Madison, Wisconsin

SAMPLE NUMBER	FIXTURE TYPE	SAMPLE DATE	LEAD CONCENTRATION (ppb)
023-1-A	Bubbler/fountain	03/17/2017	8.6
023-2-A	Bubbler/fountain	03/17/2017	3.5
023-3-A	Water cooler	03/17/2017	0.36
023-4-TAP1-A	Faucet/sink	03/17/2017	2.5
023-4-TAP2-A	Faucet/sink	03/17/2017	5.3
023-5-A	Bubbler/fountain	03/17/2017	2.4
023-6-A	Water cooler	03/17/2017	<0.060
023-7-A	Water cooler	03/17/2017	0.30
023-8-A	Bubbler/fountain	03/17/2017	3.6
023-9-A	Bubbler/fountain	03/17/2017	0.51
023-12-A	Water cooler	03/17/2017	0.23 J
023-13-A	Bubbler/fountain	03/17/2017	3.0
023-14-A	Bubbler/fountain	03/17/2017	1.3
023-15-A	Bubbler/fountain	03/17/2017	0.85
023-16-A	Bubbler/fountain	03/17/2017	1.2
023-17-A	Bubbler/fountain	03/17/2017	3.6
023-18-A	Water cooler	03/17/2017	0.53
023-20-A	Bubbler/fountain	03/17/2017	1.8
023-21-A	Faucet/sink	03/17/2017	2.2
023-22-A	Water cooler	03/17/2017	<0.060
023-23-A	Service connection	03/17/2017	0.87
023-24-A	Bubbler/fountain	03/17/2017	2.0
023-25-A	Faucet/sink	03/25/2017	1.5

Notes:

1. Flush Sample (B) is only analyzed if the First Draw Sample (A) met or exceeded 15 ppb.
2. Service connection samples are flush samples (one per sample point), but sample IDs end with "A".
3. Samples were not able to be collected at sample points 10, 11, or 19 (no water).
4. J indicates that result is less than the reporting limit but greater than or equal to the method detection limit, and the concentration is an approximate value.
5. The sample number is derived with the MMSD school identification number (e.g., 010) followed by a unique sample point identifier (e.g., 1, 2, 3, etc.). Fixtures with multiple taps include an additional locator (e.g., TAP 1, TAP 2). The first draw sample is then identified with the "A" suffix and the flush sample identified with a "B" suffix.

Created by: LCA 3/29/17

Checked by: JW 3/29/17

Updated by: LCA 4/3/17

Checked by: BJW 4/3/17