

80 Lupes Drive  
Stratford, CT 06615



Tel: (203) 377-9984  
Fax: (203) 377-9952  
e-mail: cet1@cetlabs.com

Client: Mr. Ryan Ebenhak  
Hygenix Inc  
49 Woodside St  
Stamford, CT 06902

# Analytical Report

## CET# 7040248

Report Date: April 14, 2017  
Project: Lead  
Project Number: Hindley School, Darien

Connecticut Laboratory Certificate: PH 0116  
Massachusetts laboratory Certificate: M-CT903



New York NELAP Accreditation: 11982  
Rhode Island Certification: 199

CET # : 7040248

Project: Lead

Project Number: Hindley School, Darien

**SAMPLE SUMMARY**

The sample(s) were received at 14.0°C.

This report contains analytical data associated with following samples only.

Sample ID	Laboratory ID	Matrix	Collection Date/Time	Receipt Date
HIN K1	7040248-01	Drinking Water	4/12/2017 7:40	04/12/2017
HIN K2	7040248-02	Drinking Water	4/12/2017 7:40	04/12/2017
HIN 130 F1	7040248-03	Drinking Water	4/12/2017 7:40	04/12/2017
HIN 130 F2	7040248-04	Drinking Water	4/12/2017 7:40	04/12/2017
HIN 201 F1	7040248-05	Drinking Water	4/12/2017 7:40	04/12/2017
HIN 201 F2	7040248-06	Drinking Water	4/12/2017 7:40	04/12/2017

**Analyte: Total Lead [EPA 200.8]**

**Analyst: SS**

**Matrix: Drinking Water**

Laboratory ID	Client Sample ID	Result	RL	Units	Dilution	Batch	Prepared	Date/Time Analyzed	Notes
7040248-01	HIN K1	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 17:41	
7040248-02	HIN K2	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 17:45	
7040248-03	HIN 130 F1	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 17:49	
7040248-04	HIN 130 F2	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 17:53	
7040248-05	HIN 201 F1	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 17:57	
7040248-06	HIN 201 F2	ND	0.0010	mg/L	1	B7D1324	04/13/2017	04/13/2017 18:05	

CET # : 7040248

Project: Lead

Project Number: Hindley School, Darien

### QUALITY CONTROL SECTION

#### Batch B7D1324 - EPA 200.8

Analyte	Result (mg/L)	RL (mg/L)	Spike Level	Source Result	% Rec	% Rec Limits	RPD	RPD Limit	Notes
<b>Blank (B7D1324-BLK1)</b>									Prepared: 4/13/2017 Analyzed: 4/13/2017
Lead	ND	0.0010							
<b>Blank (B7D1324-BLK2)</b>									Prepared: 4/13/2017 Analyzed: 4/13/2017
Lead	ND	0.0010							
<b>LCS (B7D1324-BS1)</b>									Prepared: 4/13/2017 Analyzed: 4/13/2017
Lead	0.0988	0.0010	0.100		98.8	85 - 115			
<b>LCS (B7D1324-BS2)</b>									Prepared: 4/13/2017 Analyzed: 4/13/2017
Lead	0.0980	0.0010	0.100		98.0	85 - 115			
<b>Matrix Spike (B7D1324-MS4)</b>									Source: 7040248-05 Prepared: 4/13/2017 Analyzed: 4/13/2017
Lead	0.100	0.0010	0.100	ND	100	75 - 125			

CET # : 7040248

Project: Lead

Project Number: Hindley School, Darien



80 Lupes Drive  
Stratford, CT 06615

Tel: (203) 377-9984  
Fax: (203) 377-9952  
email: cet1@cetlabs.com

### Quality Control Definitions and Abbreviations

Internal Standard (IS)	An Analyte added to each sample or sample extract. An internal standard is used to monitor retention time, calculate relative response, and quantify analytes of interest.
Surrogate Recovery	The % recovery for non-target organic compounds that are spiked into all samples. Used to determine method performance.
Continuing Calibration Batch	An analytical standard analyzed with each set of samples to verify initial calibration of the system. Samples that are analyzed together with the same method, sequence and lot of reagents within the same time period.
ND	Not detected at or above the specified reporting limit.
RL	Reporting Limit
Dilution	Multiplier added to detection levels (MDL) and/or sample results due to interferences and/or high concentration of target compounds.
Duplicate	Result from the duplicate analysis of a sample.
Result	Amount of analyte found in a sample.
Spike Level	Amount of analyte added to a sample
Matrix Spike Result	Amount of analyte found including amount that was spiked.
Matrix Spike Dup	Amount of analyte found in duplicate spikes including amount that was spike.
Matrix Spike % Recovery	% Recovery of spiked amount in sample.
Matrix Spike Dup % Recovery	% Recovery of spiked duplicate amount in sample.
RPD	Relative percent difference between Matrix Spike and Matrix Spike Duplicate.
Blank	Method Blank that has been taken through all steps of the analysis.
LCS % Recovery	Laboratory Control Sample percent recovery. The amount of analyte recovered from a fortified sample.
Recovery Limits	A range within which specified measurements results must fall to be compliant.
CC	Calibration Verification

#### Flags:

- H- Recovery is above the control limits
- L- Recovery is below the control limits
- B- Compound detected in the Blank
- P- RPD of dual column results exceeds 40%
- #- Sample result too high for accurate spike recovery.



Connecticut Laboratory Certification PH0116  
Massachusetts Laboratory Certification M-CT903

New York NELAP Accreditation 11982  
Rhode Island Certification 199

CET # : 7040248


Project: Lead

Project Number: Hindley School, Darien

All questions related to this report should be directed to David Ditta, Timothy Fusco, or Robert Blake at 203-377-9984.

Sincerely,

This technical report was reviewed by Timothy Fusco



David Ditta  
Laboratory Director

Project Manager

Report Comments:

Sample Result Flags:

- E- The result is estimated, above the calibration range.
- H- The surrogate recovery is above the control limits.
- L- The surrogate recovery is below the control limits.
- B- The compound was detected in the laboratory blank.
- P- The Relative Percent Difference (RPD) of dual column analyses exceeds 40%.
- D- The RPD between the sample and the sample duplicate is high. Sample Homogeneity may be a problem.
- + - The Surrogate was diluted out.
- \*C1- The Continuing Calibration did not meet method specifications and was biased low for this analyte. Increased uncertainty is associated with the reported value which is likely to be biased low.
- \*C2- The Continuing Calibration did not meet method specifications and was biased high for this analyte. Increased uncertainty is associated with the reported value which is likely to be biased high.
- \*F1- The Laboratory Control Sample recovery is outside of control limits. Reported value for this analyte is likely to be biased on the low side.
- \*F2- The Laboratory Control Sample recovery is outside of control limits. Reported value for this analyte is likely to be biased on the high side.
- I- The Analyte exceeds %RSD limits for the Initial Calibration. This is a non-directional bias.

All results met standard operating procedures unless indicated by a data qualifier next to a sample result, or a narration in the QC report.

For Percent Solids, if any of the following prep methods (3050B, 3540C, 3545A, 3550C, 5035 and 9013A) were used for samples pertaining to this report, the percent solids procedure is within that prep method.

Complete Environmental Testing is only responsible for the certified testing and is not directly responsible for the integrity of the sample before laboratory receipt.

ND is None Detected at or above the specified reporting limit

RL is the Reporting Limit

All analyses were performed in house unless a Reference Laboratory is listed.

Samples will be disposed of 30 days after the report date.

CET # : 7040248

Project: Lead

Project Number: Hindley School, Darien

**CERTIFICATIONS**

**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	CT,MA,RI,NY

Complete Environmental Testing operates under the following certifications and accreditations:

Code	Description	Number	Expires
CT	Connecticut Public Health	PH0116	09/30/2018
MA	Massachusetts Laboratory Certification	M-CT903	06/30/2017
NY	New York Certification (NELAC)	11982	04/01/2018
RI	Rhode Island Certification	LAO 00227	09/30/2018

7040248



COMPLETE ENVIRONMENTAL TESTING, INC.

### CHAIN OF CUSTODY

Volatile Soils Only:

Date and Time in Freezer

Client:

80 Lupes Drive  
Stratford, CT 06615  
Tel: (203) 377-9984  
Fax: (203) 377-9952  
e-mail: cell1@cellabs.com  
Bottle Request e-mail: bottleorders@cellabs.com

Sample ID	Sample Depths (Units)	Collection Date/Time	Matrix A-Water B-Gal W-Water DW-Dishing W-Water C-Castles Solid W-Water Other (Specify)	Turnaround Time ** (check one)					Organics												Metals (check all that apply)								Additional Analysis		TOTAL # OF CONT.	NOTE #
				Same Day *	Next Day *	2-3 Days *	Sid (5-7 Days)	8260 CT List	8260 Aromatics	8260 Halogens	624	CT ETPH	8270 CT List	8270 PNAs	PCBs	Pesticides	13 Priority Poll	8 RCRA	TOTAL	TCLP	SPLP	Field Filtered	Lab To Filter	Lead in Water								
H120019	K1	7:40	DW				X																				1					
H120020	K2	7:40	DW				X																				1					
H120021	F1	7:40	DW				X																				1					
H120022	F2	7:40	DW				X																				1					
H120023	F1	7:40	DW				X																				1					
H120024	F2	7:40	DW				X																				1					

RELINQUISHED BY: RE  
DATE/TIME: 4/12/17 8:49  
RECEIVED BY: JSS  
DATE/TIME: 4/12/17 8:49  
RECEIVED BY:

#### Client / Reporting Information

Company Name: Hygenix  
Address: 49 Woodside St  
City: Stamford, CT 06811  
State: CT  
Report To: Ebenhack  
E-mail: ebenhack@hygenix.com  
Phone #: 203 324 2272  
Fax #: 203 324 2272

\* Additional charge may apply. \*\* TAT begins when the samples are received at the Lab and all issues are resolved. TAT for samples received after 3 p.m. will start on the next business day. REV. 06/14

NOTES: Detection limit 15 ppb

Project Contact: Ebenhack  
Project: ~~XXXXXXXXXX~~  
Location: Darien, CT  
Collector(s): Ebenhack  
PO #: ~~XXXXXXXXXX~~  
Project #: ~~XXXXXXXXXX~~  
QA/QC:  Sid  Site Specific (MSMSD)  RCP Pkg  DOAW   
Data Report:  PDF  EDD - Specialty Format  Other   
RSH Reporting Units (check one):  GA  GB  SWP  Other   
Laboratory Certification Needed (check one):  DCT  NY  RI  MA   
SHEET 1 OF 1

Environmental Consultants  
And Laboratory Services

(203) 324-2222  
Fax (203) 324-3876



49 Woodside Street Stamford, CT 06902

April 19, 2017

Town of Darien  
Attn. Michael Lynch

RE: Lead in water sampling  
Hindley School – Darien, CT

To Whom It May Concern:

On April 12, 2017, I collected water samples from a kitchen sink, water fountain adjacent to Room 130, and the water fountain adjacent Room 201 at the above mentioned site.

Water samples were collected during the early in the morning during the April vacation to get the "first draw". After a minute flush the 'second draw' was collected from each location. The water samples were sent to Complete Environmental Testing in Stratford, CT to be analyzed for lead by EPA Method 200.8 / EPA 3005A. The results are summarized in the following table:

Sample Location	1 <sup>st</sup> Draw mg/L	2 <sup>nd</sup> Draw mg/L	EPA Standard mg/L
Kitchen Sink	< 0.001	< 0.001	0.015
Water Fountain Room 130	< 0.001	< 0.001	0.015
Water Fountain Room 201	< 0.001	< 0.001	0.015

All samples were below the EPA Action level for lead in tap water of 15 ppb (0.015 mg/L).

More information about lead in water can be found at the following websites:

<https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water>  
[https://www.epa.gov/sites/production/files/2015-09/documents/toolkit\\_leadschools\\_guide\\_3ts\\_leadschools.pdf](https://www.epa.gov/sites/production/files/2015-09/documents/toolkit_leadschools_guide_3ts_leadschools.pdf)

If you have any questions, comments, or concerns please contact me at [rebenhack@hygenix.com](mailto:rebenhack@hygenix.com) or (203) 324-2222. Thank you.

Sincerely,

*Ryan Ebenhack*

Ryan Ebenhack

Hygenix, Inc.

CT Lead Inspector License # 002167

Attachments – Lead in water sampling laboratory reports