

UCFSD- Chadds Ford Elementary School

Lead Sample Results

Sample Date	Sampled	Outlet Description	Lead Result (ppb)	Action Limit (15 ppb)
06-02-2021	684	Hydration Station; Outside RM E202; Floor 2	< 1	Below
06-02-2021	685	Hydration Station; Outside RM E105; Floor 1	< 1	Below
06-02-2021	686	Classroom Faucet; RM B101; Floor 1	3.1	Below
06-02-2021	687	Nurse's Office Faucet; Back of Nurse's Office; Floor 1	3.9	Below
06-02-2021	688	Classroom Faucet; Office Copy Room; Floor 1	4.9	Below
06-02-2021	689	Water Fountain ; Outside Gym; Floor 1	1.7	Below
06-02-2021	690	Water Fountain ; Outside RM B109; Floor 1	< 1	Below
06-02-2021	691	Water Fountain ; Outside RM D124; Floor 1	4.2	Below
06-02-2021	692	Hydration Station; Outside Custodial Closet, C114; Floor 1	< 1	Below
06-02-2021	693	Hydration Station; Outside RM C102; Floor 1	3.4	Below
06-02-2021	694	Kitchen Faucet; Kitchen - Right; Floor 1	10.8	Below
06-02-2021	695	Kitchen Faucet; Kitchen - Left; Floor 1	86.2	Above
06-02-2021	696	Hydration Station; Outside Cafeteria; Floor 1	< 1	Below
06-02-2021	697	Water Fountain ; Cafeteria; Floor 1	1.3	Below
06-02-2021	698	Classroom Faucet; RM E008; Floor 0	14.3	Below
06-02-2021	699	Classroom Faucet; RM E211; Floor 2	9.7	Below

06-02-2021	700	Classroom Faucet; RM E116; Floor 1	30.1	Above
06-02-2021	701	Hydration Station; Outside RM B108; Floor 1	< 1	Below