

UCFSD- Hillendale Elementary School

Lead Sample Results

Sample Date	Sampled	Outlet Description	Lead Result (ppb)	Action Limit (15 ppb)
05-27-2021	702	Kitchen Faucet; Backing up to Walk-in Freezer; Floor 0	3.9	Below
05-27-2021	703	Hydration Station; Outside Cafeteria; Floor 0	< 1	Below
05-27-2021	704	Water Fountain ; Outside Cafeteria; Floor 0	< 1	Below
05-27-2021	705	Hydration Station; Between Office and Nurse; Floor 1	< 1	Below
05-27-2021	706	Hydration Station; Outside RM 28; Floor 1	< 1	Below
05-27-2021	707	Hydration Station; Outside Teacher's RM, by RM 10; Floor 1	< 1	Below
05-27-2021	708	Nurse's Office Faucet; Left in Nurse's Office; Floor 1	< 1	Below
05-27-2021	709	Nurse's Office Faucet; Right in Nurse's Office; Floor 1	< 1	Below
05-27-2021	710	Classroom Faucet; Teacher's RM, by RM 10; Floor 1	1.1	Below
05-27-2021	711	Classroom Faucet; RM 4; Floor 1	1.1	Below
05-27-2021	712	Classroom Faucet; Teacher's RM, by RM 23; Floor 1	2	Below