

UCFSD- Pocopson Elementary School

Lead Sample Results

Sample Date	SampleId	Outlet Description	Lead Result (ppb)	Action Limit (15 ppb)
05-26-2021	653	Kitchen Faucet; Receiving Rm side; Floor 1	< 1	Below
05-26-2021	654	Kitchen Faucet; Office side; Floor 1	1.3	Below
05-26-2021	655	Water Fountain ; Outside Gym; Floor 1	< 1	Below
05-26-2021	656	Hydration Station; Outside Gym; Floor 1	< 1	Below
05-26-2021	657	Water Fountain ; Outside A104; Floor 1	< 1	Below
05-26-2021	658	Hydration Station; Outside A104; Floor 1	< 1	Below
05-26-2021	659	Water Fountain ; Across from B112; Floor 1	< 1	Below
05-26-2021	660	Hydration Station; Across from B112; Floor 1	< 1	Below
05-26-2021	661	Kitchen Faucet; Rm B106; Floor 1	< 1	Below
05-26-2021	662	Water Fountain ; Outside C109; Floor 1	< 1	Below
05-26-2021	663	Hydration Station; Outside C109; Floor 1	< 1	Below
05-26-2021	664	Water Fountain ; Outside A204; Floor 2	< 1	Below
05-26-2021	665	Hydration Station; Outside A204; Floor 2	< 1	Below
05-26-2021	666	Water Fountain ; Across from B207; Floor 2	< 1	Below
05-26-2021	667	Hydration Station; Across from B207; Floor 2	< 1	Below

05-26-2021	668	Water Fountain ; Lower outside Library; Floor 2	< 1	Below
05-26-2021	669	Water Fountain ; Outside C209; Floor 2	< 1	Below
05-26-2021	670	Hydration Station; Outside C209; Floor 2	< 1	Below