

# UCFSD- Unionville Elementary School

## Lead Sample Results

| Sample Date | SampleID | Outlet Description   | Lead Result (ppb) | Action Limit (15 ppb) |
|-------------|----------|--|-------------------|-----------------------|
| 06-02-2021  | 749      | Water Fountain ; Outside Rm 224; Floor 2                       | 1.6               | Below                 |
| 06-02-2021  | 750      | Hydration Station; Outside bathrooms b/n 204/229; Floor 2      | < 1               | Below                 |
| 06-02-2021  | 751      | Water Fountain ; Outside Rm 168; Floor 1                       | < 1               | Below                 |
| 06-02-2021  | 752      | Hydration Station; Outside Rm 168; Floor 1                     | < 1               | Below                 |
| 06-02-2021  | 753      | Food Prep/Pot-Filler/Kitchen Kettle ; West Wall Sink ; Floor 0 | 33                | <b>Above</b>          |
| 06-02-2021  | 754      | Classroom Faucet; Sink in Rm 212; Floor 2                      | 2.3               | Below                 |
| 06-02-2021  | 755      | Classroom Faucet; Sink in Rm 224; Floor 2                      | 5.4               | Below                 |
| 06-02-2021  | 756      | Water Fountain ; Outside Rm 210; Floor 2                       | < 1               | Below                 |
| 06-02-2021  | 757      | Hydration Station; Outside bathrooms b/n 114/110; Floor 1      | < 1               | Below                 |
| 06-02-2021  | 758      | Water Fountain ; Outside Rm 108; Floor 1                       | < 1               | Below                 |
| 06-02-2021  | 759      | Hydration Station; Ramp side of Rm 149; Floor 1                | < 1               | Below                 |
| 06-02-2021  | 760      | Classroom Faucet; Sink in Rm 141; Floor 1                      | 2.4               | Below                 |
| 06-02-2021  | 761      | Classroom Faucet; Sink in Rm 104; Floor 1                      | 9.2               | Below                 |
| 06-02-2021  | 762      | Nurse's Office Faucet; Nurses office on right; Floor 1         | 4.7               | Below                 |
| 06-02-2021  | 763      | Nurse's Office Faucet; Back room on left; Floor 1              | 2.3               | Below                 |

|            |     |  |     |       |
|------------|-----|--|-----|-------|
| 06-02-2021 | 764 | Classroom Faucet; Sink in Rm 182; Floor<br>1               | 2.2 | Below |
| 06-02-2021 | 765 | Hydration Station; Outside gym<br>restrooms; Floor 0       | 1   | Below |
| 06-02-2021 | 766 | Hydration Station; Bottle filler in cafeteria<br>; Floor 0 | < 1 | Below |