



## School Radon Testing Reporting Form

### General Instructions

According to MS 123B.571, radon testing conducted in public school buildings eligible for health and safety (i.e., not charter schools) must be reported to the Minnesota Department of Health.

For the purpose of this form, a building is defined as an occupied facility that has a unique address, including administrative buildings. A building could be a single structure or a complex of structures. For reference, all district owned buildings entered on the Minnesota Department of Education "Facilities Age and Square Footage Report" should be utilized.

Please submit information about the most recent round or cycle of testing conducted for each building, unless this was already reported to MDH in the 4/4/11 survey. We do not need details of prior rounds of testing.

1. Submit summary information and raw data if either of the following apply:
  - a. Radon testing has been completed in a building since the MDH 'School Radon Testing Survey' dated April 4, 2011, or
  - b. Radon testing was completed at some time previously and your district did not report radon testing in the MDH 'School Radon Testing Survey' dated April 4, 2011.
2. Complete one survey for each building tested
3. Submit the survey, raw data (e.g., laboratory analysis report) and a building map to MDH by email, to [health.indoorair@state.mn.us](mailto:health.indoorair@state.mn.us)
4. If follow-up testing, mitigation, and/or post-mitigation testing is not yet completed, please submit a completed form and raw data when the work is completed.

### Contact Person for this Form

Name: DAVID MOREDOCK

Phone: 651-258-6294

Email: dmoredoc@SOWASHCO.K12.MN.US

Mailing Address: 7362 E. POINT DOUGLAS RD S.

COTTAGE GROVE, MN 55016

**Radon Results for Each School Building**

1. District Name & Number: SOUTHERN WASHINGTON COUNTY

2. School Building Name: PARK HILL SCHOOL

3. School Building Address: 8040 80th ST S COTTAGE GROVE, MN 55016

4. What type of test kit was used? Manufacturer: AMSTAR Device name: LIQUID SCINTILLATION

Comments: N/A

5. When were the test kits retrieved? 02/15 (month/year)  
More than one date can be entered if parts of buildings were tested at different times

Comments: N/A

6. How long were the test kits deployed in the rooms? 3 (days)  
More than one number can be noted if durations varied

Comments: N/A

7. Was testing conducted over:  
a. Weekends? Yes \_\_\_ No  b. Holidays or Breaks? Yes \_\_\_ No

Comments: N/A

8. Were all frequently-occupied rooms in contact with the ground tested? Yes \_\_\_ No   
This includes: 1) rooms on grade and; 2) rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

Comments: RANDOM SAMPLE

9. How many frequently-occupied rooms were tested? 16

Comments: N/A

10. How many frequently-occupied rooms were at or above four picocuries per liter ( $\geq 4$  pCi/L)? 0

Comments: N/A

11. Were test results reported at a school board meeting? Yes  No \_\_\_  
If results will be reported at the next meeting, note in comments the month and year of the scheduled meeting in the comments section.

Comments: 03-26-15

**If one or more rooms  $\geq 4$  pCi/L, complete Questions 12-14.**

12. How many of the rooms  $\geq 4$  pCi/L had follow-up testing results that were:

a.  $\geq 4$  pCi/L \_\_\_\_\_ b.  $< 4$  pCi/L \_\_\_\_\_ c. not tested \_\_\_\_\_

'Follow-up' testing means testing done, prior to any radon mitigation, to confirm or verify initial test results in those rooms  $\geq 4$  pCi/L are, in fact,  $\geq 4$  pCi/L. If a continuous radon monitor (CRM) was used, indicate concentration during occupied times. If no follow-up testing was done, write the number of rooms not tested. If follow-up testing will be done in the future, note in comments the planned month and year in the comments section.

Comments: \_\_\_\_\_

13. How many of the rooms  $\geq 4$  pCi/L:

a. were mitigated? \_\_\_\_\_ b. had other corrective measures? \_\_\_\_\_

'Mitigated' means building changes such as adjusting the existing HVAC system, increasing fresh air ventilation rate, balancing air flow to rooms, or other such modifications. 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points. If mitigation or other corrective measure(s) will be completed in the future, note in comments the planned month and year in the comments section.

Comments: \_\_\_\_\_

14. How many rooms re-tested after mitigation were:

a.  $\geq 4$  pCi/L \_\_\_\_\_ b.  $< 4$  pCi/L \_\_\_\_\_ c. not tested \_\_\_\_\_

If post-mitigation re-testing will be completed in the future, note the planned month and year in the comments section.

Comments: \_\_\_\_\_

N  
A

NELAC NY 11769  
NRPP 101193 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested: Project # 15-02-07

South Washington County Schools  
7362 East Point Douglas Road South  
Cottage Grove MN 55016

Park High School  
8040 80th Street South  
Cottage Grove MN 55016

| Log Number | Device Number | Test Exposure Duration: |                    | Area Tested                    | Result (pCi/L) |
|------------|---------------|-------------------------|--------------------|--------------------------------|----------------|
| 1752969    | 2881081       | 02/16/2015 9:50 am      | 02/19/2015 7:30 am | Bldg. PHS Unit 103 First Floor | < 0.4          |
| 1752970    | 2881082       | 02/16/2015 9:53 am      | 02/19/2015 7:32 am | Bldg. PHS Unit 106 First Floor | 0.5            |
| 1752971    | 2881083       | 02/16/2015 9:55 am      | 02/19/2015 7:34 am | Bldg. PHS Unit 109 First Floor | 0.5            |
| 1752972    | 2881084       | 02/16/2015 10:50 am     | 02/19/2015 7:35 am | Bldg. PHS Unit 113 First Floor | 0.5            |
| 1752973    | 2881085       | 02/16/2015 10:52 am     | 02/19/2015 7:36 am | Bldg. PHS Unit 114 First Floor | < 0.4          |
| 1752974    | 2881086       | 02/16/2015 10:55 am     | 02/19/2015 7:37 am | Bldg. PHS Unit 117 First Floor | 1.3            |
| 1752975    | 2881087       | 02/16/2015 10:57 am     | 02/19/2015 7:38 am | Bldg. PHS Unit 118 First Floor | < 0.4          |
| 1752976    | 2881088       | 02/16/2015 10:59 am     | 02/19/2015 7:38 am | Bldg. PHS Unit 123 First Floor | < 0.4          |
| 1752977    | 2881089       | 02/16/2015 10:59 am     | 02/19/2015 7:38 am | Bldg. PHS Unit 123 First Floor | 0.4            |
| 1752978    | 2881090       | 02/16/2015 11:00 am     | 02/19/2015 7:39 am | Bldg. PHS Unit 128 First Floor | < 0.4          |

**Comment:** Confidential: Release results to client only South Washington County Schools was emailed a copy of this report.

Test Performed By: David Moredock

Distributed by: South Washington County Schools

Date Received: 02/24/2015 Date Logged: 02/24/2015 Date Analyzed: 02/25/2015 Date Reported: 02/25/2015

Report Reviewed By: M. Gray

Report Approved By: Carolyn K. Allen

**Disclaimer:**

Carolyn K. Allen, President, AccuStar Labs

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 101193 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested: Project # 15-02-07

South Washington County Schools  
7362 East Point Douglas Road South  
Cottage Grove MN 55016

Park High School  
8040 80th Street South  
Cottage Grove MN 55016

| Log Number | Device Number | Test Exposure Duration:                | Area Tested                    | Result (pCi/L) |
|------------|---------------|--|--------------------------------|----------------|
| 1752979    | 2881091       | 02/16/2015 11:03 am 02/19/2015 7:40 am | Bldg. PHS Unit 175 First Floor | 0.4            |
| 1752980    | 2881092       | 02/16/2015 11:05 am 02/19/2015 7:42 am | Bldg. PHS Unit 172 First Floor | < 0.4          |
| 1752981    | 2881093       | 02/16/2015 11:06 am 02/19/2015 7:43 am | Bldg. PHS Unit 171 First Floor | 0.6            |
| 1752982    | 2881094       | 02/16/2015 11:08 am 02/19/2015 7:44 am | Bldg. PHS Unit 167 First Floor | 0.9            |
| 1752983    | 2881095       | 02/16/2015 11:10 am 02/19/2015 7:45 am | Bldg. PHS Unit 137 First Floor | 0.6            |
| 1752984    | 2881096       | 02/16/2015 11:11 am 02/19/2015 7:47 am | Bldg. PHS Unit 133 First Floor | 0.7            |
| 1752985    | 2881097       | 02/16/2015 11:12 am 02/19/2015 7:48 am | Bldg. PHS Unit 132 First Floor | 0.9            |
| 1752986    | 2881098       | 02/16/2015 11:14 am 02/19/2015 7:50 am | Bldg. PHS Unit 160 First Floor | < 0.4          |

**Comment:** Confidential: Release results to client only South Washington County Schools was emailed a copy of this report.

Test Performed By: David Moredock

Distributed by: South Washington County Schools

Date Received: 02/24/2015 Date Logged: 02/24/2015 Date Analyzed: 02/25/2015 Date Reported: 02/25/2015

Report Reviewed By: M. Gray

Report Approved By: Carolyn K. Allen

**Disclaimer:**

Carolyn K. Allen, President, AccuStar Labs

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.