

Lead in Water Testing Results
South Washington County Schools
Oltman Middle School (new)

On October 3rd, 2018 Oltman Middle School's drinking water was tested for concentration of lead.

All water sources tested less than 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Office	SINK	1.3
Hallway (1, left)	FOUNTAIN	0
Hallway (2, right)	FOUNTAIN	0
Hallway (3, bottle filler)	BOTTLE FILLER	0
Hallway (4, left)	FOUNTAIN	0
Hallway (5, right)	FOUNTAIN	0
Hallway(6, bottle filler)	BOTTLE FILLER	0
Nurse's Office	SINK	3.3
Room 108	SINK	.36
Hallway (7, left)	FOUNTAIN	0
Hallway (8, right)	FOUNTAIN	0
Hallway (9, bottle filler)	BOTTLE FILLER	0
Hallway (10, left)	FOUNTAIN	0
Hallway (11, right)	FOUNTAIN	0
Hallway (12, bottle filler)	BOTTLE FILLER	0
Kitchen	SPRAYER	.16
Kitchen	SINK	.14
Pool (left)	FOUNTAIN	0

LOCATION	SOURCE	RESULTS (in ug/L)
Pool (right)	FOUNTAIN	0
Pool	BOTTLE FILLER	0
Hallway (16, left)	FOUNTAIN	0
Hallway (17, right)	FOUNTAIN	0
Hallway (18, bottle filler)	BOTTLE FILLER	0
Room 110D (left)	SINK	1.1
Room 110D (left)	SPRAYER	1.1
Room 110D (right)	SINK	1.8
Room 110D (right)	SPRAYER	1.3
Room 110B	SINK	2.1
Hallway (2 nd floor, A, left)	FOUNTAIN	0
Hallway (2 nd floor, B, right)	FOUNTAIN	0
Hallway (2 nd floor, C)	BOTTLE FILLER	0
Hallway (2 nd floor, D, left)	FOUNTAIN	0
Hallway (2 nd floor, E, right)	FOUNTAIN	0
Hallway (2 nd floor, F)	BOTTLE FILLER	0
Hallway (cafeteria, left)	FOUNTAIN	0
Hallway (cafeteria, right)	FOUNTAIN	0
Hallway (cafeteria)	BOTTLE FILLER	0