

Lead in Water Testing Results  
South Washington County Schools  
Lake Middle School

On September 19<sup>th</sup>, 2018 the Lake Middle School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room G106	FOUNTAIN	1.4
Pool	FOUNTAIN	2.4
Kitchen (1)	SINK	4.2
Kitchen (2)	SINK	9.7
Kitchen (3)	SINK	6.0
Kitchen (5)	SINK	15.1
Nurse's Office	SINK	3.1
Office	SINK	9.2
Room C124	SINK	1.4
Room A111 (3)	SINK	3.4
Room A114 (1)	SINK	.75
Room A114 (2)	SINK	9.5
Staff off Media	SINK	5.2
Hallway (1)	FOUNTAIN	.22
Hallway (2)	FOUNTAIN	.30
Hallway (3)	FOUNTAIN	.44

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (4)	FOUNTAIN	.27
Hallway (5)	FOUNTAIN	.14
Hallway (6)	FOUNTAIN	.52
Hallway (7)	FOUNTAIN	.24
Hallway (8)	FOUNTAIN	.22
Hallway (9)	FOUNTAIN	.50
Hallway (10)	FOUNTAIN	.70
Hallway (11)	FOUNTAIN	.44
Hallway (12)	FOUNTAIN	.33
Hallway (13)	FOUNTAIN	.18
Hallway (14)	FOUNTAIN	.36
Hallway (15)	FOUNTAIN	.32
Hallway (16)	FOUNTAIN	.33

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources have been replaced and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion, and no further action will be taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Nurse's Bathroom	SINK	22.1	.77
Band Equip Room	SINK	39.0	8.9
Concession Stand	SINK	46.7	18.6
Kitchen (4)	SINK	27.8	12.2
Room A144	SINK	89.5	12.7
Room A141	SINK	22.0	5.9
Room B115	SINK	30.6	12.1

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room B114	SINK	40.6	17.9
Media Center WR	SINK	34.6	7.8
Room C125	SINK	22.6	2.8