

Lead in Water Testing Results  
South Washington County Schools  
Bailey Elementary School

On October 11<sup>th</sup> Bailey Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room 005 (right)	SINK	9.1
Room 005 (left)	SINK	2.7
Room 005	FOUNTAIN	.91
Room 005 (by bathroom)	SINK	2.5
Room 115	FOUNTAIN	8.8
Room 006 (left)	SINK	8.3
Room 006 (right)	SINK	2.1
Room 006	FOUNTAIN	.73
Room 006 (by bathroom)	SINK	3.9
Room 116	FOUNTAIN	7.8
Room 117	FOUNTAIN	7.3
Hallway (outside 118)	SINK	3.8
Room 182	FOUNTAIN	7.6
Room 181	FOUNTAIN	.81
Room 101 (by bathroom)	SINK	2.0
Room 102	FOUNTAIN	2.3
Hallway (SE)	FOUNTAIN	1.2

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (outside 124)	SINK	7.0
Hallway (outside 124)	FOUNTAIN	2.7
Hallway (outside 123)	SINK	5.5
Hallway (outside 123)	FOUNTAIN	2.6
Room 124	FOUNTAIN	4.2
Room 125	SINK	4.5
Room 125	FOUNTAIN	4.8
Hallway (SE, right)	FOUNTAIN	1.1
Hallway (SE, left)	FOUNTAIN	2.7
Room 126	FOUNTAIN	3.4
Room 126	SINK	3.6
Room 118	FOUNTAIN	4.6
Room 119	SINK	9.3
Room 121	FOUNTAIN	6.5
Room 120	FOUNTAIN	3.3
Room 122	FOUNTAIN	5.9
Room 123	FOUNTAIN	4.5
Kitchen (1)	SINK	9.8
Kitchen (2)	SINK	1.1
Kitchen (3)	SINK	6.6
Kitchen (4)	SINK	1.1
Kitchen (5)	SINK	1.2
Kitchen (6)	SINK	1.1
Kitchen (7)	SINK	9.9

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room 144	FOUNTAIN	.53
Room 145	FOUNTAIN	.20
Hallway (outside 145)	FOUNTAIN	1.3
Room 146	FOUNTAIN	.63
Hallway (NE, left)	FOUNTAIN	1.6
Hallway (NE, right)	FOUNTAIN	1.7
Room 138	FOUNTAIN	5.6
Room 137	FOUNTAIN	4.1
Room 136	FOUNTAIN	5.7
Hallway (outside 136)	FOUNTAIN	5.0
Hallway (outside 135)	FOUNTAIN	2.1
Hallway (outside 117)	FOUNTAIN	2.5
Room 130	FOUNTAIN	5.3
Room 131	FOUNTAIN	4.0
Room 133	FOUNTAIN	5.7
Room 132	FOUNTAIN	4.8
Room 134	FOUNTAIN	6.2
Room 135	FOUNTAIN	5.1
Room 127	FOUNTAIN	4.0
Hallway (SW)	FOUNTAIN	1.2
Room 129	FOUNTAIN	5.9
Room 128	FOUNTAIN	3.9
Hallway (outside 130)	SINK	7.8
Hallway (outside 130)	FOUNTAIN	2.4

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (outside 129)	FOUNTAIN	3.0
Room 189	SINK	3.7
Nurse's Office (1)	SINK	1.1
Nurse's Office (2)	SINK	1.2
Office	SINK	.89
Room 188	SINK	5.9
Hallway (W, right)	FOUNTAIN	1.8
Hallway (W, left)	FOUNTAIN	.74
Room 189	FOUNTAIN	4.6
Room 186	SINK	2.7
Room 187	FOUNTAIN	7.0
Room 187	SINK	3.5
Room 188	FOUNTAIN	3.8
Room 184	SINK	4.1
Room 185	FOUNTAIN	5.6
Room 185	SINK	7.6
Room 186	FOUNTAIN	5.6
Room 182	SINK	2.3
Room 183	FOUNTAIN	5.5
Room 183	SINK	5.2
Room 184	FOUNTAIN	2.2
Room 101	FOUNTAIN	.98
Room 102	SINK (by bathroom)	15.1
Room 128	SINK	7.7

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room 129	SINK	12.7
Room 130	SINK	5.0
Room 131	SINK	3.8
Room 138	SINK	17.8
Hallway (outside 129)	SINK	16.1
Hallway (outside 136)	SINK	15.3

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were removed or shut off and are no longer operable.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Media Center WR (L)	SINK	26.8
Hallway (outside 118)	FOUNTAIN	36.9

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were replaced, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room 115	SINK	29.0	7.7
Room 116	SINK	36.0	6.0
Room 117	SINK	30.3	10.8
Room 118	SINK	42.1	10.2
Room 119	SINK	62.6	9.2
Room 120	SINK	24.4	8.6
Room 121	SINK	39.1	.59
Room 122	SINK	32.3	6.7

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room 123	SINK	47.6	6.3
Room 124	SINK	35.9	7.1
Hallway (outside 117)	SINK	27.3	1.3
Room 101	SINK	30.5	.78
Room 102	SINK	21.2	9.2
Room 127	SINK	25.5	.87
Room 132	SINK	26.9	3.4
Room 133	SINK	26.9	7.7
Room 134	SINK	23.0	7.4
Room 135	SINK	22.9	6.7
Room 136	SINK	26.4	7.7
Room 137	SINK	35.8	2.7
Hallway (outside 135)	SINK	24.8	15.8
Media Center WR (R)	SINK	24.6	5.6