

Lead in Water Testing Results  
South Washington County Schools  
District Service Center

On September 12<sup>th</sup>, 2018 the District Program Center's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room A180	FOUNTAIN	1.3
Room A180	SINK	3.8
Room A173	SINK	3.6
Room A132 (right)	SINK	4.6
Hallway (left)	FOUNTAIN	1.1
Hallway (right)	FOUNTAIN	.36
Room A164	SINK	11.0
Room A133	SINK	10.8
Room A132 (left)	SINK	1.1
Room A114	SINK	5.9