

Lead in Water Testing Results  
South Washington County Schools  
Grey Cloud Elementary School

On September 28<sup>th</sup>, 2018 Grey Cloud Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (outside 130)	SINK	4.2
Room 130	FOUNTAIN	2.1
Room 131	FOUNTAIN	1.1
Room 132	FOUNTAIN	.92
Hallway (SE)	FOUNTAIN	.78
Room 102	FOUNTAIN	2.1
Room 101	SINK	18.6
Room 101	FOUNTAIN	.97
Room 005	SINK	9.0
Room 006	SINK	10.2
Room 006	FOUNTAIN	1.5
Hallway (NE)	FOUNTAIN	.67
Room 115	SINK	1.7
Room 115	FOUNTAIN	7.5
Room 116	SINK	2.1
Room 116	FOUNTAIN	3.1

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room 117	FOUNTAIN	3.1
Hallway (outside 117)	FOUNTAIN	3.1
Hallway (outside 117)	SINK	3.0
Hallway (outside 118)	SINK	4.6
Room 122	SINK	10.1
Room 122	FOUNTAIN	5.4
Room 123	FOUNTAIN	4.9
Room 124	SINK	3.7
Room 124	FOUNTAIN	18.8
Hallway (outside 124)	SINK	5.6
Hallway (outside 123)	SINK	6.0
Room 126	SINK	18.6
Room 126	FOUNTAIN	10.3
Room 125	FOUNTAIN	1.6
Room 118	SINK	2.8
Room 118	FOUNTAIN	3.0
Room 119	SINK	15.5
Room 119	FOUNTAIN	2.5
Room 120	FOUNTAIN	2.8
Room 200	SINK	3.9
Room 200	FOUNTAIN	2.6
Room 201	SINK	5.9
Room 201	FOUNTAIN	1.3
Room 201 (middle)	SINK	6.1

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Room 200 (middle)	SINK	.82
Hallway (SW, right)	FOUNTAIN	.29
Hallway (SW, left)	FOUNTAIN	.92
Room 301	SINK	1.5
Room 301	FOUNTAIN	3.8
Room 302	SINK	6.5
Room 302	FOUNTAIN	2.0
Room 303	SINK	12.6
Room 303	FOUNTAIN	2.7
Room 304	SINK	5.5
Room 304	FOUNTAIN	1.3
Room 305	SINK	10.6
Room 305	FOUNTAIN	1.9
Room 306	SINK	8.8
Nurse's Office	SINK	1.7
Office	SINK	.51
Kitchen (HW1)	SINK	17.2
Kitchen (HW2)	SINK	13.7
Kitchen	SPRAYER	9.7
Room 147	SINK	8.0
Room 146	FOUNTAIN	.99
Hallway (outside 146)	FOUNTAIN	.51
Room 145	FOUNTAIN	1.3
Room 144	FOUNTAIN	.31

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (outside 136)	SINK	4.6
Room 134	SINK	3.6
Room 134	FOUNTAIN	2.0
Room 133	FOUNTAIN	2.5
Room 127	SINK	4.4
Room 127	FOUNTAIN	3.4
Room 128	SINK	2.5
Room 128	FOUNTAIN	1.0
Room 129	FOUNTAIN	2.1
Hallway (outside 129)	SINK	6.8
Room 306	FOUNTAIN	.42
Hallway (south, left)	FOUNTAIN	.64
Hallway (south, right)	FOUNTAIN	.93
Room 138	SINK	5.4
Room 138	FOUNTAIN	5.2
Room 137	FOUNTAIN	3.0
Room 136	SINK	12.1
Room 136	FOUNTAIN	.90
Room 135	SINK	2.4
Room 135	FOUNTAIN	1.2
Hallway (outside 135)	SINK	5.3
Room 121	SINK	5.0
Room 121	FOUNTAIN	3.6
Media Workroom	SINK	19.1

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (north, left)	FOUNTAIN	.88
Hallway (north, right)	FOUNTAIN	.78

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were replaced, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion, and no further action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room 102	SINK	36.5	16.8
Room 117	SINK	40.8	9.1
Room 120	SINK	45.7	8.6
Room 123	SINK	29.3	11.6
Room 125	SINK	36.5	7.0
Room 129	SINK	21.3	11.0
Room 130	SINK	30.5	10.2
Room 131	SINK	26.9	9.5
Room 132	SINK	24.1	7.5
Room 133	SINK	22.2	13.9
Room 137	SINK	32.6	4.8
KITCHEN	SINK	25.9	.63